

1 **Re Page B-162:**

2 Q. What, if any, mobile or temporary fall protection equipment has been
3 acquired by Hydro since 2005?

4

5

6 A. Portable Fall Arrest devices have been acquired by our Generation /
7 Terminals department at Bishop's Falls. A total of three units have been
8 acquired, one each for Eastern, Central, and Western regions. The devices
9 are designed by Unique Concept Limited (UCL) Safety Systems for up to
10 three workers attached at any given time. The system is detachable from the
11 base anchor plate which is permanently attached to the equipment to be
12 worked on. This device is generally used for servicing the 138 kV and 230 kV
13 transformers, at a height of 3.05 meters or more.

14

15 This equipment is required to ensure compliance with section 60 of the
16 *Occupational Health & Safety Regulations*, CNR 1165 / 96 (O C 96-478).

17

18 The sites which have been equipped with this device are Oxen Pond
19 Terminal Station, Holyrood Plant, Bay d'Espoir Terminal Station #2, Massey
20 Drive Terminal Station and Corner Brook Frequency Converter Building.