

1   **Re Page B-18:**

2   Q.    At what age was deteriorated condition noted in the structures at Churchill  
3       Falls and at what age were they replaced?

4

5

6   A.    The deteriorated condition was noted in the structures at the age of 30 years.  
7       The deteriorated equipment has been replaced between the ages of 30 years  
8       to 35 years.