

1 **Re: Page B-136, Construct Bushing Storage Building, \$334,900**

2 Q. What is the maximum age of the bushings that have been held in storage?

3

4

5 A. The bushing nameplates do not contain a year of manufacture but we do
6 know some bushings have been in inventory for transformers installed in the
7 mid 1960's and as a result are in the order of 40 years old.