

1 Q. Re: Upgrade Circuit Breakers Volume II (Tab 15)

2 Hydro has outlined that it plans to use a combination of overhauls and replacement
3 for both air blast and SF6 breakers which Hydro argues will extend the life of the
4 existing breakers prior to a replacement. Is Hydro requesting that the Board to
5 approve its overhaul and replacement regime?

6

7

8 A. Hydro is requesting the Board to approve the capital expenditures required for
9 Hydro to execute its current overhaul and replacement regime. Through further
10 engineering analysis and condition assessment, the current replacement regime
11 may change. As new information or testing techniques become available, the
12 overhaul and replacement plans will be reviewed for possible improvements.