

- 1 Q. **B-48, Increase Generation Capacity – Mary’s Harbour \$1,489,000**
- 2 In Table 14, p. 23 of the report in Volume II, Tab 16, Hydro forecasts load for each
- 3 year from 2011 to 2017. Please provide information on the actual load for 2011,
- 4 showing the gross peak and net peak for the summer of 2011.
- 5
- 6
- 7 A. Table 1 presents the gross peak and net peak demand experienced on a monthly
- 8 basis for the year 2011 at the Mary’s Harbour Generating Station as well as the
- 9 gross and net energy produced.

Table 1: 2011 Monthly Production – Mary’s Harbour Generating Station

MONTH	Gross Peak (kW)	Net Peak (kW)	Gross Energy (MWh)	Net Energy (MWh)
JAN	729	694	353.2	341.8
FEB	776	740	334.7	322.7
MAR	731	698	337.0	326.2
APR	679	642	312.1	301.3
MAY	1,041	1,002	448.5	434.2
JUN	954	915	382.3	368.7
JUL	851	809	321.9	307.4
AUG	649	610	273.1	258.8