

1 Q. Re: Account G01: Please provide a detailed description of the various assets and
2 corresponding cost of each set forth in Account G01 – Gas Turbine Systems,
3 including all information and documentation the Company believes is significant or
4 meaningful to the determination of life characteristics. Further, provide the hours
5 of operations by year for each separate system since placed into service as well as
6 all life limitations and expectations of the manufacturer for each system.

7

8

9 A. Please see CA-NLH-83 Attachment 1. This account was analyzed in total, rather
10 than on an asset by asset basis, and the asset specific data was therefore not a
11 consideration.

12

13 CA-NLH-83 Attachment 2 contains hours of operation since 1991 for gas turbines,
14 hydraulic units and Holyrood thermal units. Prior year data is not available. The
15 abbreviations used in Attachment 2 are:

16 Bay d’Espoir - BDE

17 Cat Arm - CAT

18 Hinds Lake - HLK

19 Holyrood - HRD

20 Holyrood Gas Turbine -HRDT

21 Hardwoods Gas Turbine – HWDT

22 Paradise River - PRV

23 Stephenville Gas Turbine – SVLT

24 Upper Salmon - USL

25 Granite Canal – GCL

26

1 Data is not available for the mini-hydro units in Snook's Arm and Venam's Bight
2 Please note that for the Hydro units, the synchronous condenser hours are included
3 in the operating hours, and for the HRD units and Gas Turbines, the synchronous
4 condenser hours are not included in the operating hours. Data regarding life
5 limitations and expectations of the manufacturer for each system is not readily
6 available.

Below is a list of all assets in account G01 - Gas Turbine Systems that were included in the data list used for Gannett's depreciation study.

Asset Number	Description	Asset Cost		Cost Net of CIAC	Final	
		Object	Start Depr		UOP	Final UOP Desc
6613	Jet Engine A	1013	1/1/1977	2,065,597	G01	Gas Turbine Systems
6614	Jet Engine B	1013	1/1/1977	1,203	G01	Gas Turbine Systems
6615	Power Turbine A	1013	1/1/1977	1,189,775	G01	Gas Turbine Systems
6616	Power Turbine B	1013	8/23/1988	1,061,380	G01	Gas Turbine Systems
6619	Clutch A	1013	1/1/1977	89,279	G01	Gas Turbine Systems
6620	Clutch B	1013	7/7/1984	14,679	G01	Gas Turbine Systems
6622	Generator	1013	1/1/1977	1,144,769	G01	Gas Turbine Systems
6637	Fuel Off-Loading	1013	1/1/1977	47,430	G01	Gas Turbine Systems
6638	Fuel Forwarding	1013	1/1/1977	111,954	G01	Gas Turbine Systems
6644	Lube Oil System	1013	1/1/1977	122,759	G01	Gas Turbine Systems
46249	Jet Engine	1013	3/27/1992	6,060,236	G01	Gas Turbine Systems
46251	Power Turbine	1013	3/27/1992	4,713,568	G01	Gas Turbine Systems
46260	Switch Gear	1013	3/27/1992	325,566	G01	Gas Turbine Systems
46264	Fuel Off-Loading	1013	3/27/1992	161,008	G01	Gas Turbine Systems
46266	Fuel Forwarding	1013	3/27/1992	375,777	G01	Gas Turbine Systems
46272	Lubricating System	1013	3/27/1992	707,381	G01	Gas Turbine Systems
46275	Inlet Plenum	1013	3/27/1992	606,026	G01	Gas Turbine Systems
46279	Clutch	1013	3/27/1992	121,207	G01	Gas Turbine Systems
59682	Main Breaker	1013	8/10/1999	281,546	G01	Gas Turbine Systems
88087	Inlet Plenum A	1013	10/31/1976	49,619	G01	Gas Turbine Systems
88092	Inlet Plenum B	1013	10/31/1976	49,619	G01	Gas Turbine Systems
88096	Jet Engine A	1013	10/31/1976	1,969,156	G01	Gas Turbine Systems
88101	Jet Engine B	1013	10/31/1976	19,501	G01	Gas Turbine Systems
88106	Power Turbine A	1013	10/31/1976	1,174,724	G01	Gas Turbine Systems
88113	Power Turbine B	1013	5/31/1988	1,073,844	G01	Gas Turbine Systems
88128	Clutch A	1013	10/31/1976	43,782	G01	Gas Turbine Systems
88133	Clutch B	1013	10/31/1976	43,782	G01	Gas Turbine Systems
88143	Generator	1013	10/31/1976	1,111,793	G01	Gas Turbine Systems
88169	Station Service Transformer	1013	10/7/1983	17,992	G01	Gas Turbine Systems
88222	Fuel Off-Loading	1013	10/31/1976	37,944	G01	Gas Turbine Systems
88227	Fuel Forwarding	1013	10/31/1976	109,929	G01	Gas Turbine Systems
88258	Lube Oil System	1013	10/31/1976	110,914	G01	Gas Turbine Systems
309449	Operator Console, Hwd Gt	1013	12/20/2007	31,100	G01	Gas Turbine Systems
333573	Alternator Assessment, Hwg Gt	1013	12/14/2009	135,036	G01	Gas Turbine Systems
333574	Control Sys Upgrade, Hwd Gt	1013	12/14/2009	10,803	G01	Gas Turbine Systems
333576	Structure Upgrades, Hwd Gt	1013	12/14/2009	118,831	G01	Gas Turbine Systems
333927	Hrd Gas Turb Dcs Control	1013	11/6/2009	876,643	G01	Gas Turbine Systems
99003597	Billing, Metering, Relay Control Panel & Other Misc. Equip.	1013	8/11/1968	20,673	G01	Gas Turbine Systems
99003598	Upgrade Control System (Gas Turbine Rehabilitated)	1013	1/27/1987	879,094	G01	Gas Turbine Systems
99003599	Upgrade Main Lube Oil Set (Gasturbine Rehabilitations)	1013	1/27/1987	17,594	G01	Gas Turbine Systems
99003600	Power Turbine For Hrd. Gas Turbine	1013	8/11/1968	417,399	G01	Gas Turbine Systems
99003601	Materials To Upgrade Power Turbine	1013	1/27/1987	1,097,717	G01	Gas Turbine Systems
99003602	Air Inlet Plenum Chamber	1013	1/21/1981	72,911	G01	Gas Turbine Systems
99003603	Upgrade Inlet Plenum At Hrd During Rehabilitation	1013	1/27/1987	7,051	G01	Gas Turbine Systems
99003605	Jet Engine; Rolls Royce	1013	8/11/1968	557,687	G01	Gas Turbine Systems
99003655	Switchgear Module Hdwd Gas Turbine	1013	1/1/1977	278,000	G01	Gas Turbine Systems
99003661	Repair & Replacement Of 1 Inlet Housing Rear Flange	1013	8/25/1989	41,803	G01	Gas Turbine Systems
99003662	Inlet Plenum Equipment	1013	1/1/1977	53,009	G01	Gas Turbine Systems
99003730	Power Turbine Casing	1013	1/16/1981	68,850	G01	Gas Turbine Systems
99004529	Control System - Happy Valley	1013	3/27/1992	459,085	G01	Gas Turbine Systems
99031317	Gas Turbine Control System	1013	12/4/1997	546,314	G01	Gas Turbine Systems
99031318	Pressure Transmitter For Control System	1013	12/4/1997	1,926	G01	Gas Turbine Systems
99034291	Current Transformer	1013	8/10/1999	6,346	G01	Gas Turbine Systems
99034292	Station Service Equipment	1013	8/10/1999	2,742	G01	Gas Turbine Systems
99038617	Gas Turbine Monitoring Console	1013	9/17/2001	53,174	G01	Gas Turbine Systems
99039098	Extension To Auxiliary Module	1013	12/31/2001	61,838	G01	Gas Turbine Systems
99043168	Power Turbine Casing	1013	1/16/1981	68,850	G01	Gas Turbine Systems
99043171	Repair & Replacement Of 1 T Housing Rear Flange	1013	8/25/1989	41,803	G01	Gas Turbine Systems
99043172	Inlet Plenum Equipment	1013	1/1/1977	53,009	G01	Gas Turbine Systems
Total				30,993,023		

Time Range : 1/1/2011 to 12/31/2011

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	6,912.02	-	8,069.18
BDE 2	3,257.28	-	7,957.98
BDE 3	8,137.88	-	8,476.85
BDE 4	3,196.20	-	8,124.98
BDE 5	4,586.88	-	8,427.57
BDE 6	5,633.60	-	8,107.32
BDE 7	8,164.43	391.47	8,164.43
CAT 1	6,747.70	645.48	8,266.68
CAT 2	8,190.65	1,529.38	8,528.17
HLK 1	5,375.67	-	7,400.65
HRD 1	4,952.12	-	6,724.27
HRD 2	4,469.82	-	6,813.63
HRD 3	2,442.83	4,270.53	4,316.58
HRDT	-	-	6,577.68
HVYT	12.22	5,412.65	8,562.67
HWDT	38.38	3,187.43	8,114.90
PRV 1	4,691.65	-	8,084.37
SVLT	13.03	8,096.07	8,437.53
USL 1	5,915.12	-	8,303.25
GCL	7,542.47	-	7,745.77

Time Range : 1/1/2010 to 12/31/2010

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	6,839.42	-	8,396.67
BDE 2	1,903.12	-	6,397.23
BDE 3	7,488.70	-	7,788.65
BDE 4	2,696.13	-	8,480.77
BDE 5	3,311.75	-	8,253.98
BDE 6	4,133.27	-	8,262.95
BDE 7	7,835.75	399.33	7,878.23
CAT 1	7,832.82	762.67	8,366.73
CAT 2	7,556.00	865.55	8,286.35
HLK 1	5,587.00	-	7,400.40
HRD 1	4,420.35	-	6,463.90
HRD 2	3,953.85	-	7,249.23
HRD 3	2,811.15	3,181.38	5,333.37
HRDT	21.85	-	2,145.28
HVYT	42.62	3,622.73	8,142.60
HWDT	150.00	5,942.62	7,375.33
PRV 1	4,507.35	-	8,074.15
SVLT	51.45	6,432.70	8,102.50
USL 1	6,823.17	-	8,145.93
GCL	7,128.35	-	7,789.03

Time Range : 1/1/2009 to 12/31/2009

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	5,779.23	-	8,455.63
BDE 2	2,266.53	-	8,298.83
BDE 3	7,891.78	-	7,976.98
BDE 4	2,104.08	-	8,295.82
BDE 5	3,604.10	-	8,148.37
BDE 6	3,181.07	-	8,233.72
BDE 7	8,212.40	290.38	8,212.43
CAT 1	7,625.67	314.50	8,356.33
CAT 2	8,150.38	551.67	8,305.35
HLK 1	4,666.83	-	7,892.05
HRD 1	4,519.78	-	5,611.08
HRD 2	4,921.97	-	6,468.12
HRD 3	2,945.60	4,116.52	4,608.32
HRDT	6.77	-	7,420.95
HVYT	83.35	4,775.42	8,633.18
HWDT	104.13	3,457.62	8,464.48
PRV 1	4,464.98	-	8,537.68
SVLT	9.57	6,420.88	8,315.37
USL 1	6,929.05	-	8,316.55
GCL	7,150.20	-	7,695.72

Time Range : 1/1/2008 to 12/31/2008

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	6,496.97	-	8,270.03
BDE 2	3,689.93	-	8,301.38
BDE 3	8,116.55	-	8,258.18
BDE 4	3,263.40	-	8,529.77
BDE 5	4,974.72	-	8,386.88
BDE 6	4,645.12	-	8,389.80
BDE 7	8,292.48	130.42	8,293.52
CAT 1	6,239.08	10.38	6,245.43
CAT 2	6,143.82	301.28	6,153.32
HLK 1	5,372.13	-	8,301.25
HRD 1	3,485.60	-	4,595.17
HRD 2	4,994.13	-	6,783.10
HRD 3	3,082.48	4,403.23	6,569.62
HRDT	41.37	-	8,667.57
HVYT	22.75	3,817.70	8,292.85
HWDT	206.40	3,398.35	8,445.47
PRV 1	4,936.15	-	8,614.92
SVLT	22.97	7,928.80	8,502.47
USL 1	7,915.72	-	8,242.35
GCL	7,671.67	-	7,716.35

Time Range : 1/1/2007 to 12/31/2007

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	5,283.02	-	7,305.95
BDE 2	3,337.87	-	7,295.35
BDE 3	8,227.15	-	8,474.55
BDE 4	2,726.25	-	8,461.35
BDE 5	3,997.30	-	8,309.53
BDE 6	3,998.85	-	8,328.07
BDE 7	8,515.27	209.57	8,517.58
CAT 1	8,192.00	166.33	8,385.55
CAT 2	7,682.85	350.23	7,695.28
HLK 1	6,025.12	-	8,348.58
HRD 1	5,629.40	-	6,359.53
HRD 2	5,107.00	-	5,133.90
HRD 3	4,320.80	569.30	5,073.28
HRDT	3.73	-	7,781.17
HVYT	18.25	4,824.12	8,206.70
HWDT	78.17	4,927.83	8,407.52
PRV 1	4,549.78	-	8,565.80
SVLT	62.37	4,740.02	8,467.25
USL 1	7,971.92	-	8,169.17
GCL	7,485.03	-	7,865.97

Time Range : 1/1/2006 to 12/31/2006

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	7,724.28	-	8,689.60
BDE 2	3,621.42	-	8,278.37
BDE 3	7,932.35	-	8,434.58
BDE 4	3,441.05	-	7,511.57
BDE 5	5,062.00	-	8,119.18
BDE 6	4,359.52	-	7,986.30
BDE 7	8,478.87	819.52	8,500.15
CAT 1	7,434.55	306.53	7,572.07
CAT 2	7,659.00	98.75	7,791.40
HLK 1	5,648.38	-	7,957.77
HRD 1	4,077.33	-	7,160.55
HRD 2	2,489.95	-	2,554.87
HRD 3	4,695.37	3,188.88	6,749.60
HRDT	15.63	-	6,058.62
HVYT	382.73	3,703.35	8,126.62
HWDT	141.45	6,992.65	8,097.52
PRV 1	4,847.08	-	8,503.38
SVLT	81.50	2,288.43	8,718.32
USL 1	7,626.52	-	8,271.82
GCL	7,598.65	-	7,822.38

Time Range : 1/1/2005 to 12/31/2005

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	7,481.65	-	8,414.48
BDE 2	3,093.98	-	8,378.75
BDE 3	7,604.33	-	8,207.30
BDE 4	3,355.52	-	8,189.52
BDE 5	4,354.52	-	7,836.62
BDE 6	4,765.68	-	8,582.48
BDE 7	8,426.67	84.63	8,432.87
CAT 1	7,490.72	251.65	8,068.20
CAT 2	7,788.62	445.57	8,277.32
HLK 1	5,931.07	-	8,432.68
HRD 1	4,116.12	-	4,505.40
HRD 2	4,603.00	-	5,772.98
HRD 3	5,172.03	1,023.75	6,838.90
HRDT	8.83	-	8,747.73
HVYT	36.25	4,477.97	7,600.98
HWDT	83.37	4,745.13	8,226.42
PRV 1	5,155.37	-	8,505.72
SVLT	14.67	845.92	8,672.88
USL 1	8,033.38	-	8,233.17
GCL	7,703.45	-	7,922.00

Time Range : 1/1/2004 to 12/31/2004

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	7,457.25	-	8,309.65
BDE 2	2,832.98	-	8,176.40
BDE 3	7,868.82	-	8,107.83
BDE 4	2,965.80	-	8,049.83
BDE 5	4,494.20	-	8,442.88
BDE 6	4,582.97	-	8,563.00
BDE 7	7,977.62	3.88	7,978.08
CAT 1	7,678.60	145.13	8,269.35
CAT 2	8,077.05	366.82	8,142.48
HLK 1	5,064.30	-	8,555.53
HRD 1	5,419.65	-	7,273.75
HRD 2	4,392.88	-	6,969.28
HRD 3	5,197.68	1,024.65	7,083.05
HRDT	9.55	-	8,628.77
HVYT	38.37	4,824.47	8,064.20
HWDT	16.12	1,487.52	8,682.83
PRV 1	4,269.83	-	8,570.25
SVLT	5.13	681.48	8,734.38
USL 1	8,087.10	-	8,397.85
GCL	7,558.50	-	7,712.95

Time Range : 1/1/2003 to 12/31/2003

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	6,421.97	-	8,080.03
BDE 2	2,351.27	-	8,149.42
BDE 3	7,998.95	-	8,224.48
BDE 4	2,558.42	-	8,104.77
BDE 5	3,521.43	-	7,826.97
BDE 6	3,776.60	-	8,066.47
BDE 7	8,127.87	900.08	8,133.53
CAT 1	7,940.22	68.08	8,328.72
CAT 2	8,489.23	299.40	8,490.78
HLK 1	5,367.48	-	8,068.30
HRD 1	4,983.92	-	5,487.05
HRD 2	6,083.42	-	7,467.28
HRD 3	5,273.13	1,707.20	7,268.25
HRDT	25.67	-	8,675.92
HVYT	9.83	5,028.02	7,735.15
HWDT	50.55	361.15	8,316.23
PRV 1	4,213.98	-	7,699.83
SVLT	108.50	323.83	8,739.98
USL 1	7,265.77	-	8,251.92
GCL	2,617.28	-	3,131.90

Time Range : 1/1/2002 to 12/31/2002

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	5,260.62	-	7,235.72
BDE 2	1,358.78	-	6,036.32
BDE 3	7,988.77	-	8,293.35
BDE 4	1,952.88	-	8,557.38
BDE 5	3,423.10	-	8,288.92
BDE 6	2,858.80	-	8,067.38
BDE 7	8,322.92	399.57	8,324.05
CAT 1	7,600.13	56.67	7,829.80
CAT 2	8,234.97	67.27	8,375.28
HLK 1	5,718.02	-	8,400.48
HRD 1	5,774.27	-	7,109.00
HRD 2	6,065.87	-	6,587.12
HRD 3	5,716.00	845.92	5,861.40
HRDT	14.23	-	8,523.12
HVYT	35.37	4,456.07	8,753.58
HWDT	30.40	1,912.45	8,647.57
PRV 1	4,262.25	-	8,469.05
SVLT	2.35	659.53	8,694.87
USL 1	6,931.82	-	7,895.58

Time Range : 1/1/2001 to 12/31/2001

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	6,091.05	-	8,208.98
BDE 2	1,956.05	-	7,933.07
BDE 3	6,674.77	-	6,852.57
BDE 4	1,935.67	-	7,077.67
BDE 5	3,583.80	-	8,392.65
BDE 6	3,099.62	-	8,339.02
BDE 7	8,217.40	323.77	8,223.02
CAT 1	8,088.68	752.53	8,352.13
CAT 2	7,759.97	236.60	8,267.73
HLK 1	4,890.17	-	8,036.13
HRD 1	6,560.58	-	7,377.85
HRD 2	6,884.07	-	7,432.88
HRD 3	5,239.27	-	6,025.57
HRDT	15.32	-	8,650.37
HVYT	229.02	4,489.32	8,471.62
HWDT	11.67	2,510.18	8,588.23
PRV 1	3,882.02	-	8,321.57
SVLT	2.33	855.83	8,701.50
USL 1	7,108.88	-	8,231.05

Time Range : 1/1/2000 to 12/31/2000

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	7,385.15	-	7,614.97
BDE 2	3,562.18	-	7,812.05
BDE 3	7,928.80	-	8,043.02
BDE 4	4,509.52	-	8,126.23
BDE 5	5,378.70	-	8,105.67
BDE 6	5,823.75	-	8,300.25
BDE 7	8,506.17	215.22	8,508.25
CAT 1	8,535.88	239.47	8,548.42
CAT 2	8,416.90	384.18	8,418.03
HLK 1	5,817.85	-	8,471.20
HRD 1	5,227.80	-	6,954.55
HRD 2	5,411.98	-	7,337.87
HRD 3	2,322.98	2,834.98	6,833.67
HRDT	20.62	-	8,297.85
HVYT	314.60	5,237.45	8,657.28
HWDT	23.97	3,016.42	7,807.72
PRV 1	4,874.18	-	8,299.87
SVLT	1.15	1,053.43	8,472.57
USL 1	8,044.35	-	8,446.28

Time Range : 1/1/1999 to 12/31/1999

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	8,102.62	-	8,489.50
BDE 2	4,171.13	-	8,105.83
BDE 3	7,351.28	-	8,060.23
BDE 4	4,634.50	-	8,433.18
BDE 5	5,671.03	-	8,343.95
BDE 6	5,313.67	-	8,412.87
BDE 7	8,298.48	-	8,320.85
CAT 1	6,747.65	1,050.75	7,225.67
CAT 2	7,145.95	458.62	7,157.93
HLK 1	5,233.92	-	8,513.48
HRD 1	4,813.33	-	7,173.53
HRD 2	3,800.80	-	4,636.60
HRD 3	5,185.37	1,799.00	6,890.83
HRDT	41.75	-	8,644.18
HVYT	512.05	4,151.93	8,657.87
HWDT	47.02	3,808.87	8,564.18
PRV 1	4,941.12	-	8,517.60
SVLT	1.38	226.18	6,912.57
USL 1	8,193.55	-	8,343.57

Time Range : 1/1/1998 to 12/31/1998

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	4,945.02	-	5,430.18
BDE 2	4,773.38	-	8,621.57
BDE 3	8,352.25	-	8,457.65
BDE 4	3,387.32	-	7,543.17
BDE 5	5,473.97	-	8,199.70
BDE 6	4,741.37	-	7,926.42
BDE 7	8,008.38	1,886.67	8,073.88
CAT 1	8,118.60	527.23	8,218.57
CAT 2	7,953.33	1,575.90	8,033.70
HLK 1	6,174.13	-	8,538.42
HRD 1	4,717.20	-	6,831.68
HRD 2	4,586.15	-	7,213.42
HRD 3	2,475.08	4,644.95	5,690.52
HRDT	34.05	-	7,755.13
HVYT	16.33	5,706.43	8,675.63
HWDT	35.38	3,431.07	8,710.80
PRV 1	4,201.23	-	7,983.40
SVLT	16.00	3,990.90	8,708.33
USL 1	7,544.92	-	8,578.75

Time Range : 1/1/1997 to 12/31/1997

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	7,598.62	-	8,403.12
BDE 2	3,426.10	-	7,631.52
BDE 3	7,267.63	-	7,445.55
BDE 4	3,979.28	-	8,473.35
BDE 5	4,869.23	-	8,340.25
BDE 6	4,815.72	-	8,515.77
BDE 7	8,406.95	610.23	8,432.85
CAT 1	7,754.68	394.05	7,774.40
CAT 2	8,366.83	260.48	8,385.72
HLK 1	6,349.27	-	7,605.75
HRD 1	4,744.15	-	5,917.65
HRD 2	5,203.78	-	5,791.78
HRD 3	4,321.58	2,304.92	5,494.55
HRDT	21.05	-	8,660.58
HVYT	29.32	5,266.52	8,696.68
HWDT	10.00	229.65	7,194.05
PRV 1	4,524.60	-	8,390.12
SVLT	1.77	341.23	8,759.32
USL 1	8,135.82	-	8,376.50

Time Range : 1/1/1996 to 12/31/1996

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	1,902.18	-	5,197.00
BDE 2	5,481.85	-	7,863.45
BDE 3	8,582.82	-	8,634.97
BDE 4	3,714.00	-	8,594.43
BDE 5	5,928.37	-	8,556.38
BDE 6	4,515.40	-	8,632.98
BDE 7	8,431.12	154.95	8,508.95
CAT 1	8,163.28	136.67	8,164.10
CAT 2	8,071.80	70.28	8,123.97
HLK 1	5,565.82	-	8,509.17
HRD 1	4,467.10	-	6,131.50
HRD 2	5,095.68	-	5,138.85
HRD 3	3,697.53	2,599.75	5,906.30
HRDT	27.87	-	8,426.77
HVYT	35.50	5,826.38	8,711.63
HWDT	40.38	832.70	8,341.73
PRV 1	4,923.48	-	8,410.37
SVLT	40.73	883.68	8,712.60
USL 1	8,204.17	-	8,527.35

Time Range : 1/1/1995 to 12/31/1995

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	2,270.38	-	8,613.03
BDE 2	6,442.02	-	8,543.15
BDE 3	8,215.75	-	8,446.33
BDE 4	3,677.60	-	8,618.73
BDE 5	3,109.80	-	5,962.18
BDE 6	3,089.10	-	6,040.70
BDE 7	8,400.88	-	8,541.48
CAT 1	8,133.37	12.17	8,169.50
CAT 2	8,530.22	47.22	8,534.18
HLK 1	6,306.28	-	8,335.50
HRD 1	5,521.22	-	6,766.80
HRD 2	4,004.75	-	5,354.12
HRD 3	3,621.52	2,592.20	4,261.52
HRDT	18.03	-	5,138.03
HVYT	34.60	5,160.60	7,934.48
HWDT	29.95	609.23	4,695.92
PRV 1	4,690.48	-	8,262.48
SVLT	15.72	390.00	8,399.78
USL 1	7,628.45	-	8,442.88

Time Range : 1/1/1994 to 12/31/1994

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	6,292.83	-	8,582.62
BDE 2	7,429.27	-	8,494.20
BDE 3	5,978.53	-	6,048.52
BDE 4	4,365.22	-	6,217.55
BDE 5	6,198.50	-	8,203.35
BDE 6	6,180.78	-	8,493.42
BDE 7	7,992.20	-	8,063.40
CAT 1	8,216.92	999.70	8,228.30
CAT 2	8,108.05	709.85	8,189.67
HLK 1	6,681.58	-	8,288.48
HRD 1	3,417.88	-	5,943.62
HRD 2	4,297.02	-	6,838.65
HRD 3	2,975.93	-	3,340.22
HRDT	78.68	-	8,683.08
HVYT	176.85	5,670.22	8,006.20
HWDT	136.30	5,499.57	8,213.22
PRV 1	4,464.85	-	8,443.32
SVLT	41.92	466.60	6,626.97
USL 1	8,176.40	-	8,573.80

Time Range : 1/1/1993 to 12/31/1993

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	6,167.82	-	7,058.10
BDE 2	2,549.90	-	5,338.92
BDE 3	6,769.40	-	7,857.15
BDE 4	3,751.53	-	7,941.03
BDE 5	5,428.72	-	8,534.40
BDE 6	5,077.02	-	8,607.63
BDE 7	8,223.75	-	8,270.70
CAT 1	8,063.23	440.15	8,208.13
CAT 2	8,477.68	254.97	8,500.80
HLK 1	5,190.45	-	7,571.20
HRD 1	6,573.93	-	6,573.93
HRD 2	3,992.27	-	3,992.27
HRD 3	4,827.38	-	6,313.75
HRDT	20.72	-	8,526.32
HVYT	16.90	4,427.68	6,450.77
HWDT	38.00	3,980.12	8,051.85
SVLT	48.85	884.37	8,016.28
USL 1	7,528.53	-	8,062.47

Time Range : 1/1/1992 to 12/31/1992

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	6,281.47	-	8,306.55
BDE 2	3,105.00	-	8,261.77
BDE 3	7,916.42	-	8,213.25
BDE 4	3,918.13	-	8,191.28
BDE 5	3,781.33	-	6,335.10
BDE 6	3,624.23	-	6,368.33
BDE 7	7,678.10	-	7,686.62
CAT 1	8,032.65	496.60	8,056.57
CAT 2	8,452.08	423.68	8,464.08
HLK 1	4,515.28	-	7,049.17
HRD 1	4,851.45	-	4,851.45
HRD 2	4,699.98	-	6,020.57
HRD 3	6,434.70	-	6,434.70
HRDT	32.83	-	8,081.87
HWDT	76.13	4,058.33	8,624.45
SVLT	426.95	1,325.50	8,630.95
USL 1	7,902.88	-	8,614.67

Time Range : 1/1/1991 to 12/31/1991

UnitName	OperatingHours	SynchHours	AvailableHours
BDE 1	7,723.47	-	8,498.45
BDE 2	3,162.40	-	8,234.32
BDE 3	7,233.33	-	7,462.38
BDE 4	4,278.63	-	8,525.82
BDE 5	4,262.22	-	6,815.48
BDE 6	4,376.98	-	6,249.83
BDE 7	7,160.45	-	7,404.42
CAT 1	7,623.55	316.13	7,634.65
CAT 2	8,144.33	1,370.90	8,145.58
HLK 1	5,308.65	-	8,346.33
HRD 1	7,023.88	-	7,023.88
HRD 2	3,808.35	-	4,568.52
HRD 3	3,922.57	-	6,229.57
HRDT	27.27	-	4,850.08
HWDT	233.28	405.72	6,789.08
SVLT	48.78	796.23	8,354.50
USL 1	7,177.07	-	8,495.48