

1 Q. [B01-Batteries] - Please provide the level of investment in Account B01-Batteries
2 segregated between old versus new type of both batteries and battery chargers.

3

4

5 A. Below is a table with the level of investment in Account B01–Batteries segregated
6 between old Flooded Cell versus new Valve Regulated Lead Acid (VRLA) type of
7 batteries. The investment in battery chargers is also outlined in the table. There is
8 no distinction within battery chargers since chargers for both flooded cell and VRLA
9 are the same.

Asset Type	Total Investment (\$)	Percentage
Charger	2,769,119	33%
VRLA	555,650	7%
Flooded	4,271,706	52%
Other	693,251	8%
Total	8,289,726	100%