

1 Q. Please provide the previous operating and/or maintenance records of this unit prior
2 to purchase.

3

4

5 A. The unit being supplied for the project is a Siemens SGT6-3000 unit that was
6 manufactured in 2007 (generator in 2009) but never delivered, installed or
7 operated. The unit was prepared for and placed into controlled storage in October
8 2009. Ongoing storage procedures designed to maintain equipment condition have
9 been carried out and monitored since that time. Since the unit was not installed,
10 commissioned or placed into operation, no operational or maintenance records are
11 available.