

1 Q. Please confirm if you were aware that this Complete Package was advertised for
2 \$23 million US. If so, did you bring this to the attention of ProEnergy Services.

3

4

5 A. Hydro was aware that this Complete Package was advertised for \$23 million US and
6 Hydro brought this to the attention of Pro Energy. The Complete Package as
7 advertised for \$23 million US allowed for the supply of the core plant equipment at
8 its storage site in the United States. It did not allow for any other costs that would
9 be incurred in completing an operational installation including transport to site,
10 engineering and project management, site preparation, foundations, weather
11 protection building, fuel storage and distribution, power transformer, power
12 transmission connection to Hydro's terminal station, water treatment plant,
13 connection to local power supply, and connection to underground water/waste
14 piping systems. All of these items are required to make the plant operational and
15 are provided under the EPC contract with Pro Energy.