

1 Q. Please provide confirmation that this equipment is compatible with the equipment
2 at the Holyrood Station.

3

4

5 A. The equipment is compatible with the equipment at the Holyrood plant. The new
6 combustion turbine plant is located at the Holyrood site but is a stand-alone plant.
7 It is only connected to the existing station's systems through its underground raw
8 water supply, underground drainage system and the blackstart electrical service at
9 the Holyrood plant. It can provide service power to start up the Holyrood Thermal
10 Generating Station and can provide power to the Island Integrated System in
11 parallel with the Holyrood Thermal Generating Station.