

1 Q. Please confirm that the criteria outlined on pages 8-10 of the Upgrade Transmission
2 Line Corridor Report are the only criteria used by Hydro to analyze steady state and
3 transient stability performance of the Newfoundland and Labrador electrical
4 system. If no, then explain what other criteria are included.

5

6

7 A. The transmission planning criteria outline on pages 8 – 13 of the Upgrade
8 Transmission Line Corridor Report are the only criteria used by Hydro to analyze
9 steady state and transient stability performance of the Island Interconnected
10 System when analysis considers the addition of the Labrador – Island HVdc Link.
11 Hydro continues to apply under frequency load shedding for loss of on island
12 generation on the existing electrically isolated Island Interconnected System.