

1 Q. Please refer to Appendix C10, section 2. Confirm that single contingency outages on
2 the ac network were not considered as the starting condition for any of the stability
3 studies.

4

5

6 A. There were no ac transmission lines out of service as the starting point for any of
7 the 19 base cases studies in the Appendix C10 analyses. As noted in Section 2 of
8 Appendix C10, base cases BC14 to BC17 considered the Labrador – Island HVdc Link
9 in monopolar mode as the starting point for the analysis.