

1 **B-97 Battery Replacements, \$485,000**

2 Q. What is the age of the 48V battery at West Salmon Spillway that is proposed  
3 to be replaced in 2007?

4

5

6 A. The West Salmon Spillway battery bank will be 20 years old in 2007.