

1 Q. What will be the estimated remaining useful life of the units at the end of the
2 assessment and at the end of the estimated resulting changes to plant?

3

4

5 A. It is estimated that, with normal maintenance and sustaining capital
6 expenditures, the plant in its present form should continue to operate until
7 2019. The object of this assessment is to determine what life extension
8 activities would be required to extend the plant life to 2043, at which time it is
9 expected that energy would be brought to the Island from the Upper Churchill
10 development.