

Newfoundland Labrador Hydro (NLH)

As of 0732 hours, February 29, 2016, Hardwoods Gas Turbine derated to 38 MW (50 MW). End A 19 MW, End B 25 MW.

- С As of 1526 hours, March 26, 2016, Stephenville Gas Turbine End A unavailable (25 MW).
- D As of 0848 hours, April 03, 2016, Bay d'Espoir Unit 1 unavailable (76.5 MW).
- As of 1029 hours, April 15, 2016, Holyrood Unit 3 unavailable (150 MW). Ε
- F As of 2209 hours, April 30, 2016, Holyrood Unit 1 derated to 120 MW (170 MW).
- As of 1200 hours, May 07, 2016, Holyrood Unit 2 derated to 120 MW (170 MW). G
- As of 0937 hours, May 10, 2016, Bay d'Espoir Unit 6 unavailable (76.5 MW). Н
- At 1405 hours, May 14, 2016, Paradise River Unit unavailable (8 MW).
- At 1500 hours, May 14, 2016, Paradise River Unit available (8 MW).

Section 2 Island Interconnected Supply and Demand								
Sun, May 15, 2016 Island System Outlook ³			Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)		
				Morning	Evening	Forecast		
Available Island System Supply: ⁵	1,570	MW	Sunday, May 15, 2016	4	6	940		
NLH Generation: ⁴	1,255	MW	Monday, May 16, 2016	6	7	1,005		
NLH Power Purchases: ⁶	110	MW	Tuesday, May 17, 2016	5	5	1,050		
Other Island Generation:	205	MW	Wednesday, May 18, 2016	6	8	1,025		
Current St. John's Temperature:	3	°C	Thursday, May 19, 2016	6	7	945		
Current St. John's Windchill:	N/A	°C	Friday, May 20, 2016	8	10	895		
7-Day Island Peak Demand Fored	cast: 1,050	MW	Saturday, May 21, 2016	10	10	795		

Supply Notes For May 15, 2016

- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 - 3. As of 0800 Hours.
 - 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 - 5. Gross output from all Island sources (including Note 4).
 - 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak						
Sun, May 15, 2016	Forecast Island Peak Demand		940 MW			