

- **c** As of 1029 hours, April 15, 2016, Holyrood Unit 3 unavailable (150 MW).
- **D** As of 0937 hours, May 10, 2016, Bay d'Espoir Unit 6 unavailable (76.5 MW).
- E As of 0822 hours, June 05, 2016, Bay d'Espoir Unit 3 unavailable (76.5 MW).
- **F** As of 0822 hours, June 05, 2016, Bay d'Espoir Unit 4 unavailable (76.5 MW).
- **G** As of 1059 hours, June 05, 2016, Nalcor Exploits Grand Falls Unit 9 (30 MW) unavailable. Net impact to the Island Interconnected System is 7 MW.
- **H** As of 2008 hours, June 06, 2016, Stephenville Gas Turbine End B unavailable (25 MW).
- As of 2315 hours, June 08, 2016, Holyrood Unit 1 derated to 120 MW (170 MW).
- As of 1411 hours, June 09, 2016, Hardwoods Gas Turbine derated to 38 MW (50 MW). End A 19 MW, End B 25 MW.
- K As of 1425 hours, June 16, 2016, Holyrood Unit 2 unavailable. Previously derated to 120 MW (170 MW).
- L At 0826 hours, June 22, 2016 St. Anthony Diesel Plant G4 (Unit 521) unavailable (1 MW).
- M At 0826 hours, June 22, 2016 St. Anthony Diesel Plant G5 (Unit 546) unavailable (2 MW).
- N At 1259 hours, June 22, 2016 St. Anthony Diesel Plant G4 (Unit 521) available (1 MW).
- o At 1259 hours, June 22, 2016 St. Anthony Diesel Plant G5 (Unit 546) available (2 MW).

	ls	land Int	Section 2 erconnected Supply and Demand			
Thu, Jun 23, 2016	Island System Outl	look <sup>3</sup>	Seven-Day Forecast	· ·	erature C)	Island System Daily Peak Demand (MW)
				Morning	Evening	Forecast
Available Island System Suppl	y:⁵ <b>1,335</b>	MW	Thursday, June 23, 2016	16	15	785
NLH Generation: <sup>4</sup>	1,030	MW	Friday, June 24, 2016	13	12	785

NLH Power Purchases: <sup>6</sup>	135	MW	Saturday, June 25, 2016	13	15	750
Other Island Generation:	170	MW	Sunday, June 26, 2016	16	14	750
Current St. John's Temperature:	16	°C	Monday, June 27, 2016	14	17	780
Current St. John's Windchill:	N/A	°C	Tuesday, June 28, 2016	18	17	765
7-Day Island Peak Demand Forecast:	785	MW	Wednesday, June 29, 2016	18	18	765
Supply Notes For June 23, 2016	3					

Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.

- 3. As of 0800 Hours.
- 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
- 5. Gross output from all Island sources (including Note 4).
- 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.

	Section 3 Island Peak Demand Info	ormation				
Previous Day Actual Peak and Current Day Forecast Peak						
Wed, Jun 22, 2016	Actual Island Peak Demand <sup>8</sup>	16:50	799 MW			
Thu, Jun 23, 2016	Forecast Island Peak Demand		785 MW			