


**Newfoundland Labrador Hydro (NLH)  
Supply and Demand Status Report Filed Monday, December 05, 2016**

**Section 1  
Island Interconnected System Supply and Demand  
Actual 24 Hour System Performance For Saturday, December 03, 2016**



**Supply Notes For December 03, 2016**

- 1,2
- A As of 1956 hours, January 14, 2016, Nalcor Exploits Grand Falls Unit 7 unavailable. No net impact to the Island Interconnected System.
  - B As of 1526 hours, March 26, 2016, Stephenville Gas Turbine End A unavailable (25 MW).
  - C As of 1316 hours, July 15, 2016, Nalcor Exploits Grand Falls Unit 4 unavailable. Net impact to the Island Interconnected System is 7 MW.
  - D As of 1719 hours, September 09, 2016, Nalcor Exploits Bishop's Falls plant unit 9 unavailable. No net impact to the Island Interconnected System.
  - E As of 2132 hours, October 10, 2016, Nalcor Exploits Bishop's Falls plant unit 8 unavailable. Net impact to the Island Interconnected System is 1 MW.
  - F As of 1007 hours, November 04, 2016, Nalcor Exploits Bishop's Falls plant unit 2 unavailable. Net impact to the Island Interconnected System is 2 MW.
  - G As of 1245 hours, November 13, 2016, Star Lake Unit unavailable (18 MW).
  - H As of 0842 hours, November 19, 2016, Hardwoods Gas Turbine End A unavailable. Previously derated to to 19 MW (25 MW).
  - I As of 1525 hours, November 30, 2016, Nalcor Exploits Bishop's Falls Unit 6 unavailable. Net impact to the Island Interconnected System is 2 MW.
  - J As of 1844 hours, December 02, 2016, Holyrood Unit 3 unavailable (150 MW).
  - K At 1105 hours, December 03, 2016, Stephenville Gas Turbine End B available (25 MW).

**Section 2  
Island Interconnected Supply and Demand**

Sun, Dec 04, 2016	Island System Outlook <sup>3</sup>	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
			Morning	Evening	Forecast	Adjusted <sup>7</sup>
Available Island System Supply: <sup>5</sup>	1,835 MW	Sunday, December 04, 2016	1	0	1,350	1,254
NLH Generation: <sup>4</sup>	1,495 MW	Monday, December 05, 2016	-2	-4	1,470	1,373
NLH Power Purchases: <sup>6</sup>	135 MW	Tuesday, December 06, 2016	-6	-5	1,470	1,373
Other Island Generation:	205 MW	Wednesday, December 07, 2016	-6	-5	1,450	1,353
Current St. John's Temperature:	0 °C	Thursday, December 08, 2016	-4	1	1,425	1,328
Current St. John's Windchill:	N/A °C	Friday, December 09, 2016	-4	-1	1,425	1,328
7-Day Island Peak Demand Forecast:	1,470 MW	Saturday, December 10, 2016	1	0	1,375	1,279

**Supply Notes For December 04, 2016**

- 3
- L At 0743 hours, December 04, 2016, Star Lake Unit available (18 MW).

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
  2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
  3. As of 0800 Hours.
  4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
  5. Gross output from all Island sources (including Note 4).
  6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.
  7. Adjusted for CBP&P interruptible load and the impact of voltage reduction, when applicable.

**Section 3  
Island Peak Demand Information  
Previous Day Actual Peak and Current Day Forecast Peak**

Sat, Dec 03, 2016	Actual Island Peak Demand <sup>8</sup>	16:45	1,298 MW
Sun, Dec 04, 2016	Forecast Island Peak Demand		1,350 MW

- Notes: 8. Island Demand is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).