

Newfoundland Labrador Hydro (NLH)

es:	1	Generation outages for running and corrective maintenance	are included. These a	re not unusual for power system operations	s. They generally do not imr	pact customer	supply The powe	er	
C 3.		system operators schedule outages to system equipment w							
		from time to time equipment outages are necessary and res	erves may be impacte	d.					
	2.	Due to the Island system having no synchronous connection	-	-		•	•		
		customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency							
		load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island							
		Interconnected System and the resultant customer load inte	rruptions are generall	y less than 30 minutes. With the activation	of the Maritime Link freque	ency controller	r during the winte	er of	
		2018, UFLS events have occurred less frequently.							
	3.	As of 0800 Hours.							
	4.	Gross output including station service at Holyrood (24.5 MW	() and improved NLH h	lydraulic output due to water levels (35 MM	V).				
	5.	Gross output from all Island sources (including Note 4).							
	6.	NLH Island Power Purchases include: CBPP Co-Gen, Nalcor E	•		sistance (when applicable).				
	7.	Adjusted for curtailable load, market activities and the impa	ct of voltage reductior	n when applicable.					

	Section 3 Island Peak Demand Informatio	on							
Previous Day Actual Peak and Current Day Forecast Peak									
Tue, Apr 09, 2019	Actual Island Peak Demand ⁸	07:50	1,415 MW						
Wed, Apr 10, 2019	Forecast Island Peak Demand		1,290 MW						