


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Tuesday, August 20, 2019**

**Section 1
Island Interconnected System Supply, Demand & Exports
Actual 24 Hour System Performance For Monday, August 19, 2019**



Supply Notes For August 19, 2019

- A As of 1303 hours, May 26, 2019, Bay d'Espoir Unit 7 unavailable due to planned outage (153.4 MW).
- B As of 0800 hours, June 17, 2019, Holyrood Unit 2 unavailable due to planned outage (170 MW).
- C As of 1457 hours, June 28, 2019, Stephenville Gas Turbine available at 25 MW (50 MW).
- D As of 0800 hours, July 29, 2019, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- E As of 0800 hours, July 29, 2019, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- F As of 1150 hours, August 18, 2019, Hinds Lake Unit unavailable due to planned outage (75 MW).

**Section 2
Island Interconnected Supply and Demand**

Tue, Aug 20, 2019	Island System Outlook ³	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
			Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	1,215 MW	Tuesday, August 20, 2019	18	20	775	775
NLH Island Generation: ⁴	950 MW	Wednesday, August 21, 2019	18	18	795	795
NLH Island Power Purchases: ⁶	80 MW	Thursday, August 22, 2019	15	16	790	790
Other Island Generation:	185 MW	Friday, August 23, 2019	18	18	805	805
ML/LIL Imports:	-	Saturday, August 24, 2019	14	9	780	780
Current St. John's Temperature & Windchill:	15 °C	Sunday, August 25, 2019	12	11	805	805
7-Day Island Peak Demand Forecast:	840 MW	Monday, August 26, 2019	11	12	840	840

Supply Notes For August 20, 2019

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Mon, Aug 19, 2019	Actual Island Peak Demand ⁸	12:05	753 MW
Tue, Aug 20, 2019	Forecast Island Peak Demand		775 MW

- Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).