


Newfoundland Labrador Hydro (NLH)

Supply and Demand Status Report Filed Monday, December 01, 2025

Section 1

Island Interconnected System - Supply, Demand & Exports

Actual 24 Hour System Performance For Friday, November 28, 2025



Island Supply Notes For November 28, 2025¹

- A** As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).
- B** As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 1 unavailable due to planned outage (76.5 MW).
- C** As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 2 unavailable due to planned outage (76.5 MW).
- D** As of 1400 hours, November 04, 2025, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).
- E** As of 1423 hours, November 20, 2025, Hardwoods Gas Turbine available at 25 MW due to forced derating (50 MW).
- F** As of 1841 hours, November 27, 2025, Holyrood Unit 1 available at 150 MW due to planned derating (170 MW).

Section 2

Island Interconnected System - Supply, Demand & Outlook

Sat, Nov 29, 2025	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴ NLH Island Generation: ^{3,7} NLH Island Power Purchases: ⁵ NP and CBPP Owned Generation: LIL/ML Net Imports to Island: ⁹	1,666 MW 1,345 MW 125 MW 180 MW 16 MW	Saturday, November 29, 2025	1,105	1,012
		Sunday, November 30, 2025	1,165	1,072
		Monday, December 1, 2025	1,175	1,081
		Tuesday, December 2, 2025	1,320	1,225
		Wednesday, December 3, 2025	1,305	1,210
		Thursday, December 4, 2025	1,310	1,215
7-Day Island Peak Demand Forecast:	1,395 MW	Friday, December 5, 2025	1,395	1,299

Island Supply Notes For November 29, 2025

- Notes:**
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 3).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3

Island Peak Demand and Exports Information

Previous Day Actual Peak and Current Day Forecast Peak

Fri, Nov 28, 2025	Island Peak Demand ¹⁰	17:10	1,046 MW
	Exports at Peak		345 MW
	LIL Net Imports to Island		3,750 MWh
Sat, Nov 29, 2025	Forecast Island Peak Demand		1,105 MW

- Notes:**
10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).