

October 13, 2016

The Board of Commissioners of Public Utilities
Prince Charles Building
120 Torbay Road, P.O. Box 21040
St. John's, NL A1A 5B2

Attention: Ms. Cheryl Blundon
Director Corporate Services & Board Secretary

Dear Ms. Blundon:

**Re: Newfoundland and Labrador Hydro - the Board's Investigation and Hearing into
Supply Issues and Power Outages on the Island Interconnected System – Nostradamus
Upgrades Monthly Report**

In accordance with item 2.1 of the Liberty Report Recommendations dated December 17, 2014, wherein Hydro is required to "provide the Board with monthly updates on the status of Nostradamus upgrades until the production model is fully in-service and shaken down", please find enclosed the original plus 12 copies of Hydro's report entitled *Accuracy of Nostradamus Load Forecasting at Newfoundland and Labrador Hydro Monthly Report: September 2016*.

We trust the foregoing is satisfactory. If you have any questions or comments, please contact the undersigned.

Yours truly,

NEWFOUNDLAND AND LABRADOR HYDRO



Kyle B. Tucker, M. Eng., P. Eng.
Manager, Regulatory Engineering

KT/bs

cc: Gerard Hayes – Newfoundland Power
Paul Coxworthy – Stewart McKelvey Stirling Scales
Sheryl Nisenbaum – Praxair Canada Inc.
ecc: Roberta Frampton Benefiel – Grand Riverkeeper Labrador

Thomas Johnson – Consumer Advocate
Thomas O' Reilly – Cox & Palmer
Danny Dumaresque

**Accuracy of Nostradamus Load Forecasting at
Newfoundland and Labrador Hydro
Monthly Report: September 2016**

Newfoundland and Labrador Hydro

October 13, 2016



Table of Contents

1 NOSTRADAMUS LOAD FORECASTING 1

1.1 Nostradamus 1

1.2 Short-Term Load Forecasting 1

1.2.1 Utility Load 1

1.2.2 Industrial Load 3

1.2.3 Supply and Demand Status Reporting 3

1.3 Potential Sources of Variance 3

2 SEPTEMBER 2016 FORECAST ACCURACY 4

2.1 Description 4

2.2 Data Adjustment 10

2.3 September 3, 2016 10

2.4 September 10, 2016 13

2.5 September 15, 2016 16

1 **1 NOSTRADAMUS LOAD FORECASTING**

2 **1.1 Nostradamus**

3 Newfoundland and Labrador Hydro (Hydro) uses software called Nostradamus, by
4 Ventyx, for short-term load forecasting with a time frame of seven days. “The
5 Nostradamus Neural Network Forecasting system is a flexible neural network based
6 forecasting tool developed specifically for utility demand forecasting. Unlike
7 conventional computing processes, which are programmed, neural networks use
8 sophisticated mathematical techniques to train a network of inputs and outputs. Neural
9 networks recognize and learn the joint relationships (linear or non-linear) between the
10 ranges of variables considered. Once the network learns these intricate relationships,
11 this knowledge can then easily be extended to produce accurate forecasts.”
12 (Nostradamus User Guide, Release 8.2, Ventyx, an ABB Company, May 2014).

13 The Nostradamus model is trained using a sequence of continuous historic periods of
14 hourly weather and demand data, then forecasts system demand using predictions of
15 those same weather parameters for the next seven days.

16

17 **1.2 Short-Term Load Forecasting**

18 Hydro uses its short-term load forecast to manage the power system and ensure
19 adequate generating resources are available to meet customer demand.

20

21 **1.2.1 Utility Load**

22 Hydro contracts Amec Foster Wheeler (Amec) to provide the weather parameters in the
23 form of twice daily hourly weather forecasts for a seven-day period. At the same time as
24 the weather forecast data are provided, Amec also provides recent observed data at the
25 same locations. The forecast and actual data are automatically retrieved from Amec and
26 input to the Nostradamus database.

27

28 Nostradamus can use a variety of weather parameters for forecasting as long as a
29 historical record is available for training. Hydro currently uses: air temperature, wind

1 speed, and cloud cover. Nostradamus can use each variable more than once, for
2 example both the current and forecast air temperatures are used in forecasting load.
3 Wind chill is not used explicitly as the neural network function of Nostradamus will form
4 its own relationships between load, wind and temperature, which should be superior to
5 the one formula used by Environment Canada to derive wind chill.

6
7 Weather data for four locations are used in Nostradamus: St. John's, Gander and Deer
8 Lake. Data from August 1, 2013 to June 30, 2016 are being used for training and
9 verification purposes. The training and verification periods are selected to provide a
10 sufficiently long period to ensure that a range of weather parameters are included, e.g.,
11 high and low temperatures, but short enough that the historic load is still representative
12 of loads that can be expected in the future.

13
14 In addition to the weather and demand data, a parameter that indicates daylight hours
15 each day is input to Nostradamus.

16
17 Demand data for the Avalon Peninsula alone and for the Island Interconnected System
18 as a whole are input to Nostradamus automatically each hour. Only total utility load
19 (conforming), Newfoundland Power's and Hydro's, is input in the Nostradamus model.
20 Industrial load (non-conforming), which is not a function of weather, is forecast outside
21 the Nostradamus program and added to the forecasts from Nostradamus to derive the
22 total load forecast.

23
24 During the process of training the Nostradamus model, it creates separate submodels
25 for weekdays, weekends and holidays to account for the variation in customer use of
26 electricity. Nostradamus has separate holiday groups for statutory holidays and also for
27 days that are known to have unusual loads, for instance the days between Christmas
28 and New Year's and the school Easter break.

1 **1.2.2 Industrial Load**

2 Industrial load tends to be almost constant, as industrial processes are independent of
3 weather. Under the current procedure, the power-on-order for each Industrial
4 Customer, plus the expected owned generation from Corner Brook Pulp and Paper
5 (CBPP), is used as the industrial load forecasts unless System Operations engineers
6 modify the forecast based on some knowledge of customer loads, for instance a
7 decrease due to reduced production at CBPP or a ramp up in the load expected at Vale.
8 Engineers can change the expected load in one or more cells of a seven by twenty-four
9 hour grid, or can change the default value to be used indefinitely.

10

11 **1.2.3 Supply and Demand Status Reporting**

12 The forecast peak reported to the Board of Commissioners of Public Utilities (the Board)
13 on the daily Supply and Demand Status Report is the forecast peak as of 7:20 am. The
14 weather forecast for the next seven days and the observed weather data for the
15 previous day are input at approximately 5:00 am. Nostradamus is then run every hour of
16 the day and the most recent forecast is available for reference by System Operations
17 engineers and the Energy Control Centre operators for monitoring and managing
18 available spinning reserves. The within day forecast updates are used by operators to
19 decide if additional spinning reserve is required in advance of forecast system peaks.

20

21 **1.3 Potential Sources of Variance**

22 As with any forecasting there will be discrepancies between the forecast and the actual
23 values. Typical sources of variance in the load forecasting are as follows:

- 24 • Differences in the industrial load forecast due to unexpected changes in
25 customer loads;
- 26 • Inaccuracies in the weather forecast, particularly temperature, wind speed or
27 cloud cover; and
- 28 • Non-uniform customer behaviour which results in unpredictability.

1 **2 SEPTEMBER 2016 FORECAST ACCURACY**

2 **2.1 Description**

3 Table 1 presents the daily forecast peak, the observed peak, and the available system
4 capacity, as included in Hydro’s daily Supply and Demand Status Reports submitted to
5 the Board for each day in September 2016. The data are also presented in Figure 1. The
6 actual peaks, as reported to the Board, varied from 737 MW on September 22 to
7 962 MW on September 29.

8
9 The available capacity during the month was between 1120 MW on September 14 and
10 1405 MW on September 17. Reserves were sufficient throughout the period.

11
12 Table 2 presents error statistics for the peak forecasts during the month of September
13 2016. Figure 2 is a plot of the forecast and actual peaks, as shown in Figure 1, but with
14 the addition of a bar chart showing the difference between the two data series. In both
15 the tables and the figures, a positive error is an overestimate; a negative error is an
16 underestimate.

17
18 In the month of September the forecast peak was in a range between 3.8% below the
19 actual peak and 11.8% above the actual peak. On the best day the forecast peak was
20 essentially the same as the actual peak; on the worst day it was 88 MW too high. On
21 average, the forecast peak was 21 MW different than the actual peak, or 2.7%.

22
23 Figure 2 shows that the total island load was frequently overestimated through
24 September. A review of the CBPP load shows that, again, it was below the forecasted
25 107 MW for much of the month. The average load was 95 MW, 12 MW below the
26 forecast of 107 MW, but several times the load dipped below 50 MW. Since the total
27 load forecast is a sum of both the utility and industrial load forecasts, an industrial
28 customer using less than forecast energy is a common cause of an overestimate in the
29 load forecast. Figure 3 reproduces Figure 2 but analyzes the utility load, rather than the

1 total load. The error is generally significantly less, and more random, than the error in
2 the total forecast.

3

4 This report will further examine the forecasts for September 3, September 10, and
5 September 15. In all cases both the total and utility-only forecast overestimated the
6 load.

Table 1 Sep 2016 Load Forecasting Data

| Date | Available | | | |
|-----------|-------------------|-----------------|-------------------|----------------------|
| | Forecast Peak, MW | Actual Peak, MW | Island Supply, MW | Forecast Reserve, MW |
| 1-Sep-16 | 780 | 751 | 1320 | 540 |
| 2-Sep-16 | 785 | 799 | 1345 | 560 |
| 3-Sep-16 | 835 | 747 | 1325 | 490 |
| 4-Sep-16 | 820 | 794 | 1330 | 510 |
| 5-Sep-16 | 765 | 760 | 1355 | 590 |
| 6-Sep-16 | 755 | 776 | 1345 | 590 |
| 7-Sep-16 | 775 | 756 | 1335 | 560 |
| 8-Sep-16 | 815 | 797 | 1340 | 525 |
| 9-Sep-16 | 795 | 793 | 1330 | 535 |
| 10-Sep-16 | 845 | 765 | 1305 | 460 |
| 11-Sep-16 | 790 | 785 | 1265 | 475 |
| 12-Sep-16 | 805 | 759 | 1380 | 575 |
| 13-Sep-16 | 760 | 747 | 1345 | 585 |
| 14-Sep-16 | 780 | 772 | 1120 | 340 |
| 15-Sep-16 | 890 | 830 | 1375 | 485 |
| 16-Sep-16 | 830 | 822 | 1365 | 535 |
| 17-Sep-16 | 750 | 740 | 1405 | 655 |
| 18-Sep-16 | 755 | 768 | 1385 | 630 |
| 19-Sep-16 | 920 | 872 | 1370 | 450 |
| 20-Sep-16 | 860 | 851 | 1185 | 325 |
| 21-Sep-16 | 790 | 783 | 1170 | 380 |
| 22-Sep-16 | 745 | 737 | 1250 | 505 |
| 23-Sep-16 | 785 | 790 | 1170 | 385 |
| 24-Sep-16 | 810 | 807 | 1285 | 475 |
| 25-Sep-16 | 860 | 846 | 1270 | 410 |
| 26-Sep-16 | 930 | 912 | 1240 | 310 |
| 27-Sep-16 | 900 | 905 | 1255 | 355 |
| 28-Sep-16 | 915 | 925 | 1280 | 365 |
| 29-Sep-16 | 925 | 962 | 1300 | 375 |
| 30-Sep-16 | 945 | 954 | 1340 | 395 |
| Minimum | 745 | 737 | 1120 | 310 |
| Average | 824 | 810 | 1303 | 479 |
| Maximum | 945 | 962 | 1405 | 655 |

Notes:

Forecast peak, available capacity and forecast reserve are rounded to the nearest 5 MW.

Forecast peak and available capacity presented is as reported to the Board. The forecast is updated hourly throughout the day for use in maintaining adequate generation reserves.

Forecast Reserve = Available Island Supply - (Forecast Peak - CBPP Interruptible Load (when applicable) - the impact of voltage






Table 2 Sep 2016 Analysis of Forecast Error

| Date | Actual Peak, MW | Forecast Peak, MW | Error, MW | Absolute Error, MW | Percent Error | Absolute Percent Error | Actual/Forecast |
|-----------|-----------------|-------------------|-----------|--------------------|---------------|------------------------|-----------------|
| 1-Sep-16 | 751 | 780 | 29 | 29 | 3.9% | 3.9% | 3.7% |
| 2-Sep-16 | 799 | 785 | -14 | 14 | -1.8% | 1.8% | -1.8% |
| 3-Sep-16 | 747 | 835 | 88 | 88 | 11.8% | 11.8% | 10.5% |
| 4-Sep-16 | 794 | 820 | 26 | 26 | 3.3% | 3.3% | 3.2% |
| 5-Sep-16 | 760 | 765 | 5 | 5 | 0.7% | 0.7% | 0.7% |
| 6-Sep-16 | 776 | 755 | -21 | 21 | -2.7% | 2.7% | -2.8% |
| 7-Sep-16 | 756 | 775 | 19 | 19 | 2.5% | 2.5% | 2.5% |
| 8-Sep-16 | 797 | 815 | 18 | 18 | 2.3% | 2.3% | 2.2% |
| 9-Sep-16 | 793 | 795 | 2 | 2 | 0.3% | 0.3% | 0.3% |
| 10-Sep-16 | 765 | 845 | 80 | 80 | 10.5% | 10.5% | 9.5% |
| 11-Sep-16 | 785 | 790 | 5 | 5 | 0.6% | 0.6% | 0.6% |
| 12-Sep-16 | 759 | 805 | 46 | 46 | 6.1% | 6.1% | 5.7% |
| 13-Sep-16 | 747 | 760 | 13 | 13 | 1.7% | 1.7% | 1.7% |
| 14-Sep-16 | 772 | 780 | 8 | 8 | 1.0% | 1.0% | 1.0% |
| 15-Sep-16 | 830 | 890 | 60 | 60 | 7.2% | 7.2% | 6.7% |
| 16-Sep-16 | 822 | 830 | 8 | 8 | 1.0% | 1.0% | 1.0% |
| 17-Sep-16 | 740 | 750 | 10 | 10 | 1.4% | 1.4% | 1.3% |
| 18-Sep-16 | 768 | 755 | -13 | 13 | -1.7% | 1.7% | -1.7% |
| 19-Sep-16 | 872 | 920 | 48 | 48 | 5.5% | 5.5% | 5.2% |
| 20-Sep-16 | 851 | 860 | 9 | 9 | 1.1% | 1.1% | 1.0% |
| 21-Sep-16 | 783 | 790 | 7 | 7 | 0.9% | 0.9% | 0.9% |
| 22-Sep-16 | 737 | 745 | 8 | 8 | 1.1% | 1.1% | 1.1% |
| 23-Sep-16 | 790 | 785 | -5 | 5 | -0.6% | 0.6% | -0.6% |
| 24-Sep-16 | 807 | 810 | 3 | 3 | 0.4% | 0.4% | 0.4% |
| 25-Sep-16 | 846 | 860 | 14 | 14 | 1.7% | 1.7% | 1.6% |
| 26-Sep-16 | 912 | 930 | 18 | 18 | 2.0% | 2.0% | 1.9% |
| 27-Sep-16 | 905 | 900 | -5 | 5 | -0.6% | 0.6% | -0.6% |
| 28-Sep-16 | 925 | 915 | -10 | 10 | -1.1% | 1.1% | -1.1% |
| 29-Sep-16 | 962 | 925 | -37 | 37 | -3.8% | 3.8% | -4.0% |
| 30-Sep-16 | 954 | 945 | -9 | 9 | -0.9% | 0.9% | -1.0% |
| Minimum | 737 | 745 | -37 | 2 | -3.8% | 0.3% | -4.0% |
| Average | 810 | 824 | 14 | 21 | 1.8% | 2.7% | 1.6% |
| Maximum | 962 | 945 | 88 | 88 | 11.8% | 11.8% | 10.5% |

Notes:

Forecast peak is rounded to the nearest 5 MW

Forecast peak presented is as reported to the Board. The forecast is updated hourly throughout the day for use in maintaining adequate generation reserves.



1 **2.2 Data Adjustment**

2 On September 7, the actual total load was not calculated for two hours because of a
3 database problem so the forecast value was input to prevent a gap in the data.
4 Replacing the data meant that forecast accuracy was not affected, and in future, when
5 the data is used for training, realistic load data will be used.

6
7 **2.3 September 3, 2016**

8 On September 3, the forecast peak at 7:20 am, as reported to the Board, was 835 MW;
9 the actual reported peak was 747 MW. The absolute difference was 88 MW, 11.8% of
10 the actual. Figure 4 includes an hourly plot of the load forecast for September 3 as well
11 as several charts which examine components of the load forecast to assist in
12 determining the sources of the differences between actual and forecast loads.

13
14 Figure 4(a) shows the hourly distribution of the load forecast compared to the actual
15 load. The hourly forecast predicted a noon peak of 837 MW; the peak was actually at
16 10:00 am, and was 739 MW.


17
18 Figure 4(b) shows the hourly distribution of the utility load forecast only, i.e., the load
19 forecast with the industrial component removed. The forecast utility load was
20 somewhat closer to the actual utility load, especially later in the day and through the
21 evening. Both the total and the utility forecasts predicted a strong midday peak; in
22 actual fact the load was quite flat with three smaller, similar peaks in the late morning,
23 the late afternoon and mid evening.

24
25 Figure 4(c) shows the actual temperature in St. John's compared to the forecast. The
26 temperature forecast was poor for most of the day with the actual midday temperature
27 being 2 degrees higher than forecast, so errors in the temperature forecast may explain
28 some of the error in the load forecast.

1 Figure 4(d) shows the actual wind speed in St. John's compared to the forecast. For
2 most of the day the wind forecast overestimated the wind speed which could also have
3 contributed to an overestimate of the load. Figure 4(e) shows the actual cloud cover in
4 St. John's compared to the forecast; it was relatively accurate for most of the day.

5
6 The relationship between load and weather is harder to predict during the summer. Up
7 to a certain temperature load continues to drop as heating load reduces but as
8 temperature continues to rise, air conditioning load could become a factor. Higher
9 winds than forecast could possibly increase heat load or decrease air conditioning load.
10 Relative humidity likely also influences load, but currently humidity is not considered by
11 the Nostradamus models.

12
13 The discrepancy between actual and forecast utility load for September 3 was a result of
14 errors in the temperature and wind. An overestimate of the load results in more than
15 enough reserve being available.



1 **2.4 September 10, 2016**

2 On September 10, the forecast peak at 7:20 am, as reported to the Board, was 845 MW;
3 the actual reported peak was 765 MW. The absolute difference was 80 MW, 10.5% of
4 the actual load. Figure 5 includes an hourly plot of the load forecast for September 10 as
5 well as several charts which examine components of the load forecast to assist in
6 determining the sources of the differences between actual and forecast loads.

7
8 Figure 5(a) shows the hourly distribution of the load forecast compared to the actual
9 load. The forecast overestimated the load for the whole day. The forecast was for a 1:00
10 pm peak of 843 MW; the actual peak occurred at 8:00 pm and was only 759 MW.


11
12 Figure 5(b) shows the hourly distribution of the utility load forecast only. The forecast
13 utility load was somewhat closer to the actual load for most of the day. Again
14 Nostradamus predicted a midday peak but the load was quite flat, with three smaller
15 peaks in the late morning, the late afternoon and mid evening.

16
17 Figures 5(c) through 5(d) shows the actual temperature, wind and cloud cover in
18 St. John's compared to the forecasts. The temperature during the late morning was
19 lower than forecast so if heating load were a factor the forecast should have
20 underestimated the peak. The temperature trend on September 10 was unusual – the
21 daily high temperature occurred at midnight and the temperature steadily decreased
22 during the day. It has been noted in the past that the Nostradamus forecasts tend to be
23 less accurate when the temperature trend is unusual.

24
25 The wind and cloud cover forecasts were relatively accurate.

26
27 It is difficult to know why the forecast was erroneous on September 10; it was likely due
28 to factors not modelled by Nostradamus. It has been noted in the past that the
29 Nostradamus forecasts tend to be less accurate when the temperature pattern through

- 1 the day is unusual and when the peak is at an unusual time, in this case in mid evening.
- 2 An overestimate of the load results in more than enough reserve being available. By the
- 3 time of the peak, the forecast had improved and was approximately 4% higher than the
- 4 actual.



1 **2.5 September 15, 2016**

2 On September 15, the forecast peak at 7:20 am, as reported to the Board, was 890 MW;
3 the actual reported peak was 830 MW. The absolute difference was 60 MW, 7.2% of the
4 actual.

5

6 Figure 6 includes an hourly plot of the load forecast for September 15 as well as several
7 charts which examine components of the load forecast to assist in determining the
8 sources of the differences between actual and forecast loads.

9

10 Figure 6(a) shows the hourly distribution of the load forecast compared to the actual
11 load. The forecast overestimated the load for the whole day. The forecast was for a 8:00
12 pm peak of 889 MW; the peak did occur at 8:00 pm but was only 825 MW.

13

14 Figure 6(b) shows the hourly distribution of the utility load forecast only. The forecast
15 utility load was generally closer to the actual load for most of the day, but
16 percentagewise, the error in the peak was similar.

17

18 Figures 6(c) through 6(d) shows the actual temperature, wind and cloud cover in
19 St. John's compared to the forecasts. The temperature during the afternoon and early
20 evening was lower than forecast, which, if heating load were a factor, should have led to
21 an underestimate of the peak; but the actual wind speed was lower than forecast which
22 would have had an opposite effect. As on September 10, the temperature trend on
23 September 15 was unusual which may have contributed to the forecast error. The cloud
24 cover forecast was relatively accurate.

25

26 It is difficult to know why the forecast was erroneous on September 15; it was likely due
27 to factors not modelled by Nostradamus. It has been noted in the past that the
28 Nostradamus forecasts tend to be less accurate when the temperature pattern through
29 the day is unusual and when the peak is at an unusual time, in this case in mid evening.

- 1 An overestimate of the load results in more than enough reserve being available. By the
- 2 time of the peak, the forecast had improved and was approximately 3% higher than the
- 3 actual.

