

1 Q. Reference PUB-NLH-440: Please confirm whether the Holyrood Thermal Generating
2 station would ever be in operational service when the LIL is in service.

3

4

5 A. It is possible that the Holyrood Thermal Generating Station would be in operational
6 service when the LIL is in service to meet customer requirements. If the LIL is in
7 service before the third unit is in service at Muskrat Falls, then the maximum
8 capacity of the LIL is approximately 175 MW. In this circumstance, Hydro would
9 have Holyrood in operation at times of the year, dictated by system and customer
10 requirements, until the third unit came in service.

11

12 As was stated in the original Muskrat Falls system planning, the intention is to
13 permanently remove Holyrood from service within two years after the completion
14 of Muskrat Falls, with the exception of the components remaining to offer
15 synchronous condenser capability.