



NEWFOUNDLAND AND LABRADOR
BOARD OF COMMISSIONERS OF PUBLIC UTILITIES
120 Torbay Road, P.O. Box 21040, St. John's, Newfoundland and Labrador, Canada, A1A 5B2

E-mail: gyoung@nlh.nl.ca

2014-03-04

Mr. Geoffrey Young
Newfoundland and Labrador Hydro
P.O. Box 12400
St. John's, NL A1B 4K7

Dear Mr. Young:

Re: Daily system status report dated March 3, 2014

This is further to the daily NLH System Supply and Demand Report filed for March 3, 2014. In that report, under the heading "Previous Day's Supply Notes", the observation is made that "CBP&P experienced frazil ice conditions overnight (March 3 into March 4) and their generation is being restored at the time of this report".

The Board requests additional information as follows:

1. Should the generation source be identified as CBP&P or is it Deer Lake Power?
2. What was the reduction in available generation capacity as a result of the frazil ice condition?
3. Has the generation capacity been restored at this time?
4. What are the expectations for the condition continuing/recurring over the next two days?
5. In addition for all future reports please identify the name plate rating for any offline or derated generation units, as is being done for Bay d'Espoir Unit #6.

If you have any questions, please do not hesitate to contact the Board's Director of Regulatory and Advisory Services, Mr. Robert Byrne by email rbyrne@pub.nl.ca or telephone (709)726-0742.

Yours truly,

A handwritten signature in cursive script, appearing to read "Cheryl Blundon".

Cheryl Blundon
Board Secretary

/epj