

NEWFOUNDLAND AND LABRADOR BOARD OF COMMISSIONERS OF PUBLIC UTILITIES 120 Torbay Road, P.O. Box 21040, St. John's, Newfoundland and Labrador, Canada, A1A 5B2

E-mail: gyoung@nlh.nl.ca

2015-09-11

Mr. Geoff Young Newfoundland and Labrador Hydro P.O. Box 12400 St. John's, NL A1B 417

Dear Mr. Young:

Re: Board's Investigation and Hearing into Supply Issues and Power Outages on the Island Interconnected System – Request to Hydro to file 2015-2016 Winter Readiness Planning Report

The Board believes that Hydro's winter readiness planning and scheduling should be monitored as it was in advance of last winter. The Board requires that Hydro confirm that generation capacity on the Island Interconnected system is ready to reliably operate prior to the start of the 2015-2016 winter period and that Hydro has taken the necessary steps to ensure that generation and transmission equipment are available when needed during winter demand periods.

Hydro should provide a report no later than September 30, 2015 setting out the following:

- The status of annual work plans items, in the format previously reported to the Board, for Hydro's generating plant and transmission and terminal stations, including the completion to date, outstanding items to complete and any risks to completion or as a result of failure to complete.
- A description and schedule for all outstanding 2015 capital projects for Hydro's generating plant and transmission and terminal stations, including progress on completion status to date and expected completion date.
- Identification of all equipment and plant testing to be carried out in advance of the winter period (generation plant, emergency diesels, black start generators, fire systems, transmission system equipment), including progress on completion status to date.
- The planned generation outage schedule for the period September 1 to December 31, 2015, including an explanation for any planned outages extending beyond December 1, 2015.
- An update of critical spares assessment and procurement.
- The forecast loads and expected generation capacity and reserves (setting out the basis for calculation) for the upcoming winter, as of December 1, 2015, and including capacity assistance agreements in place or planned.

• Identification of any risks that could impact the winter readiness of assets as of December 1, 2015 and associated contingency plans.

Following review of this report the Board will set out further requirements for ongoing monitoring of Hydro's winter readiness for the 2015-2016 winter.

If you have any questions, please do not hesitate to contact the Board's Legal Counsel, Ms. Jacqui Glynn, by email, jgylnn@pub.nl.ca or telephone (709) 726-6781.

Yours truly,

lido

Cheryl Blundon Board Secretary

/cpj

ecc. Newfoundland and Labrador Hydro NLH Regulatory, E-mail: NLHRegulatory@nlh.nl.ca Newfoundland Power Inc. Mr. Gerard Hayes, E-mail: ghayes@newfoundlandpower.com Mr. Ian Kelly, QC, E-mail: ikelly@curtisdawe.com Consumer Advocate Mr. Thomas Johnson, E-mail: tjohnson@odeaearle.ca Ms. Colleen Lacey, E-mail: clacey@odeaearle.ca Mr. Raman Balakrishnan, E-mail: rbalakrishnan@odeaearl.ca Island Industrial Customer Group Mr. Paul Coxworthy, E-mail: pcoxworthy@stewartmckelvey.com Mr. Dean Porter, E-mail: dporter@poolealthouse.ca Grand Riverkeeper® Labrador Inc. Ms. Roberta Frampton Benefiel, E-Mail: rebnfl@gmail.com Mr. Charles O'Brien, E-mail; bluegreenlaw@gmail.com Mr. Philip Raphals, E-mail: Philip@centrehelios.org Mr. Danny Dumarcsque Mr. Danny Dumaresque, E-mail: danny.liberal@gmail.com Mr. William Kennedy, E-mail:wkennedy@kennedylawoffice.ca