Page 1 of 1

Liberty has observed (p.5) that the penetration of electric space heating has 1 Q: 2 increased the likely adverse impact of outages. 3 4 Does Liberty agree that conversions to electric heat add to peak load? 5 6 Did Liberty ask Hydro whether it was considering actions that might serve **(b)** 7 to deter further conversions from oil-furnace space heating to electric 8 space heating and, if so, what possible actions were identified? 9 Yes. As a winter peaking system, additions to heating load are likely to 10 A. (a) contribute to a higher annual peak. 11 12 13 No, Liberty did not have any discussions with Hydro concerning the possible 14 discouraging of future heating load.