

1 Q. For each year from 2023 to 2027, does Hydro have an estimate of the minimum capacity the LIL
2 bipole could reliably provide in a plausible worst-case scenario? If so, please provide and
3 explain.

4

5

6 A. To date, the Labrador-Island Link (“LIL”) has been successfully tested and operated up to a
7 capacity of 475 MW. Newfoundland and Labrador Hydro would consider the LIL’s 475 MW
8 capacity to be a reasonable minimum capacity for system planning purposes.