

1 Q. **Reference: *TP-TN-068 – Application of Emergency Transmission Planning Criteria for a***
2 ***Labrador Island Link Bipole Outage, July 30, 2019, Section 4 – Base Case Analysis.***

3 Please list all contingencies analyzed for both base cases (Base Case 1 and Base Case 2).

4

5

6 A. The analysis included contingencies to assess worst-case conditions for delivery to the Avalon
7 Peninsula. Steady-state analysis as well as dynamic analysis of three-phase faults and trips were
8 considered for the following transmission lines:

9 • TL217;

10 • TL201;

11 • TL203;

12 • TL237;

13 • TL206;

14 • TL202; and

15 • TL267.