

1 Q. **Reference: *Engineering Support Services for: Stage 4D LIL Bipole: Transition to High Power***  
2 ***Operation*, TransGrid Solutions, April 7, 2020, Section 3.2.3.**

3 What will be the implications of restricting the pre-contingency power flow on supply  
4 requirements on the Avalon if customer impacts are to be avoided prior to the decommissioning  
5 of production from Holyrood Thermal Generating Station and the Hardwoods Gas Turbine?

6

7

8 A. As per the results presented in Section 3.2.3 of the Stage 4D study report, power flow to the  
9 Avalon Peninsula is restricted as a result of electromechanical oscillations. Similar restrictions  
10 exist in the existing system as power system stabilizers are not active and there is a risk of  
11 oscillation for ac transmission line contingencies when power flows are in the order of those  
12 presented in the study report (i.e. in excess of 500 MW).

13 There would not be a customer impact as a result of this restriction prior to the  
14 decommissioning of production from Holyrood Thermal Generating Station and the Hardwoods  
15 Gas Turbine. As is the case with the existing transmission system, generation on the Avalon  
16 Peninsula serves to offload the 230 kV network and power flows are therefore maintained  
17 below acceptable limits. As per Newfoundland and Labrador Hydro's response to PUB-NLH-171,  
18 the activation and tuning of power system stabilizers is planned to be completed in advance of  
19 the retirement of these assets.