

1 Q. **Reference Avalon Capacity Study, Section 4:**

2 Please list the number of times there has been a three phase fault at Bay d’Espoir.

3

4

5 A. Based on all available information, Newfoundland and Labrador Hydro advises that there

6 has not been a three-phase fault at Bay d’Espoir.