

1 Q. **Reference: Newfoundland and Labrador Hydro – Near-Term Reliability Report, May 15, 2020**

2 ***Demand Forecast***

3 Please provide a P90 forecast for the coming winter.

4

5

6 A. The P90 forecast for the Island Interconnected System customer coincident demand is 1,722
7 MW.¹ This results in a total Island Interconnected System requirement of approximately 1,798
8 MW.

¹ This Island Interconnected System customer coincident demand forecast excludes transmission losses and station service.