## 1 Q. Reference: Reliability and Resource Adequacy Study 2022 Update, Volume I, page 26.

Table 3, page 26, Holyrood TGS and Hardwoods and Stephenville GTs all retire on April 1, 2024.

In Table 4, page 27, Hardwoods and Stephenville GTs retire on April 1, 2024, but HTGS continues operating until 2030. In Table 5, page 28, only Stephenville GT retires on April 1, 2024.

The descriptions of the three cases do not indicate any other difference in assumptions between Tables 3, 4, and 5. Therefore, it seems that the assumptions underlying Tables 3, 4, and 5 are identical for 2023. However, there is a significant difference in the LOLH results for 2023 as shown in the following comparison. Explain the differences.

	2023							
Scenario	Table 3	Table 4	Table 5					
1	1.9	0.2	0.1					
2	9.7	0.8	0.7					
3	9.6	0.8	0.7					
4	9.6	0.8	0.7					
5	9.8	0.8	0.7					
6	19.1	1.5	1.4					
7	21 7	17	1 4					

9

5

6

7 8

10

11

12 13 A. There was an inaccuracy between the modelling assumptions used to produce the results in Table 3, Table 4, and Table 5<sup>1</sup> and the description of the assumptions. The tables, with corrected results for the years 2023 and 2024, are provided herein.

<sup>&</sup>lt;sup>1</sup> "Reliability and Resource Adequacy Study - 2022 Update," Newfoundland and Labrador Hydro, October 3, 2022, vol. I, p. 26, Table 3; p. 27, Table 4; and p. 28, Table 5.

Table 1: LOLH<sup>2</sup> Results – No Generation Capacity Additions through 2030 Holyrood TGS,<sup>3</sup> Hardwoods Gas Turbine, and Stephenville Gas Turbine Retired

Scenario	2023	2024	2025	2026	2027	2028	2029	2030
Scenario 1: LIL <sup>4</sup> 900 MW, FOR <sup>5</sup> 1%,								
Base Island/Base Labrador	0.1	2.1	8.2	7.8	7.7	7.5	8.6	10.4
Scenario 2: LIL 675 MW, FOR 5%,								
Base Island/Base Labrador	0.6	10.4	41.0	38.5	38.9	37.6	43.0	52.6
Scenario 3: LIL 675 MW, FOR 5%,								
High Island/Base Labrador	0.6	10.6	42.5	40.5	42.1	41.8	49.6	66.5
Scenario 4: LIL 675 MW, FOR 5%,								
Base Island/High Labrador	0.6	10.4	41.0	38.7	39.1	37.8	43.3	57.0
Scenario 5: LIL 675 MW, FOR 5%,								
High Island/High Labrador	0.6	10.5	42.5	40.5	42.3	42.2	50.5	73.1
Scenario 6: LIL 675 MW, FOR 10%,								
Base Island/Base Labrador	1.2	20.8	81.6	76.2	77.2	74.4	84.8	103.3
Scenario 7: LIL 475 MW, FOR 10%,								
Base Island/Base Labrador	1.3	23.6	104.6	99.5	101.1	101.4	115.7	152.0

Table 2: LOLH Results – No Generation Capacity Additions Holyrood TGS Extended through 2030

Scenario	2023 <sup>6</sup>	2024	2025	2026	2027	2028	2029	2030
Scenario 1: LIL 900 MW, FOR 1%, Base Island/Base Labrador	N/A	0.2	0.3	0.3	0.4	0.3	0.4	0.5
Scenario 2: LIL 675 MW, FOR 5%, Base Island/Base Labrador	N/A	0.9	1.5	1.5	1.6	1.7	1.8	2.6
Scenario 3: LIL 675 MW, FOR 5%, High Island/Base Labrador	N/A	0.9	1.7	1.7	1.8	1.9	2.3	3.6
Scenario 4: LIL 675 MW, FOR 5%, Base Island/High Labrador	N/A	0.9	1.6	1.6	1.7	1.7	1.9	2.8
Scenario 5: LIL 675 MW, FOR 5%, High Island/High Labrador	N/A	0.8	1.7	1.7	1.8	2.0	2.4	3.7
Scenario 6: LIL 675 MW, FOR 10%, Base Island/Base Labrador	N/A	1.7	3.2	3.2	3.2	3.5	3.7	5.2
Scenario 7: LIL 475 MW, FOR 10%, Base Island/Base Labrador	N/A	1.8	3.6	3.4	3.5	3.7	4.0	5.8

<sup>&</sup>lt;sup>2</sup> Loss of load hours ("LOLH").

<sup>&</sup>lt;sup>3</sup> Holyrood Thermal Generating Station ("Holyrood TGS").

<sup>&</sup>lt;sup>4</sup> Labrador-Island Link ("LIL").

<sup>&</sup>lt;sup>5</sup> Forced outage rate ("FOR").

 $<sup>^{\</sup>rm 6}$  The LOLH results in 2023 are the same as those found in Table 3.

## Table 3: LOLH Results – No Generation Capacity Additions Holyrood TGS and the Hardwoods Gas Turbine Extended through 2030

Scenario	2023 <sup>7</sup>	2024	2025	2026	2027	2028	2029	2030
Scenario 1: LIL 900 MW, FOR 1%,								
Base Island/Base Labrador	N/A	0.2	0.2	0.2	0.2	0.2	0.2	0.4
Scenario 2: LIL 675 MW, FOR 5%,								
Base Island/Base Labrador	N/A	0.8	1.1	1.1	1.1	1.1	1.3	1.8
Scenario 3: LIL 675 MW, FOR 5%,								
High Island/Base Labrador	N/A	0.8	1.1	1.2	1.3	1.4	1.6	2.7
Scenario 4: LIL 675 MW, FOR 5%,								
Base Island/High Labrador	N/A	0.8	1.1	1.1	1.1	1.2	1.3	1.9
Scenario 5: LIL 675 MW, FOR 5%,								
High Island/High Labrador	N/A	0.8	1.2	1.2	1.3	1.3	1.6	2.7
Scenario 6: LIL 675 MW, FOR 10%,								
Base Island/Base Labrador	N/A	1.6	2.2	2.1	2.2	2.3	2.6	3.7
Scenario 7: LIL 475 MW, FOR 10%,								
Base Island/Base Labrador	N/A	1.6	2.3	2.3	2.3	2.6	2.8	3.9

 $<sup>^{7}</sup>$  The LOLH results in 2023 are the same as those found in Table 3.