

1 Q. **Reference: Holyrood Thermal Generating Facility**

2

3 Please provide Hydro's plan pertaining to the retention of the Holyrood Generating Unit after
4 the completion of the LIL and the transmission of Muskrat Falls power to the island of
5 Newfoundland?

6

7

8 A. Please refer to Newfoundland and Labrador Hydro's response to CA-NLH-001. Once the time
9 frame is established for the end of steam generation at the Holyrood Thermal Generation
10 Station ("Holyrood TGS"), all steam generation capability will be decommissioned and the
11 Holyrood TGS Unit 3 generator will remain as a synchronous condenser.