

1 Q. How many feeders does Hydro upgrade each year to improve reliability on its distribution
2 system? Is it always this number? Given that these upgrades are required to meet Hydro's
3 obligations related to providing reliable service, why not do 20 or 30 feeders each year? How do
4 you know when you have met your "*obligation*" relating to the provision of reliable service?

5
6
7 A. There is no specific number of feeders that Newfoundland and Labrador Hydro ("Hydro")
8 upgrades each year; the number varies depending on the worst-performing feeder analysis.

9
10 Hydro maintains two prioritizing lists based on reliability; one is based on CHI¹ and the other one
11 is based on SAIFI²/SAIDI.³ The top 25 worst-performing feeders on each list are analyzed to
12 identify the root cause of the poor performance. Where necessary, a feeder assessment is
13 completed, which includes a review of current inspection data, overall system design, work
14 completed on past capital projects, and a site visit to confirm data collected.

15
16 Once the assessment is complete, Hydro will only propose specific capital work that can improve
17 the reliability of the feeder and is justified by available data. For example, if an issue causing
18 poor performance was due to an isolated incident or was recently addressed by other capital
19 work, Hydro will not undertake any capital upgrade action and the feeder is marked for
20 continued monitoring.

21
22 If in a specific year, there are no identified capital expenditures that could cost-effectively
23 improve reliability on any of the feeders on the worst performing lists, then Hydro would not
24 consider any capital work on the distribution feeders.

¹ Customer Hours of Interruption ("CHI").

² System Average Interruption Frequency Index ("SAIFI").

³ System Average Interruption Duration Index ("SAIDI").