

1 Q. **Reference: Specifically Assigned Assets**

2

3 With reference to Section 3.3 Specifically Assigned Assets, at page 5 of 2020 Capital Projects  
4 Overview, and Hydro's planned 2024 project to replace the neutral bushings on Come-By-  
5 Chance Transformers T1 and T2, does Hydro plan to similarly replace the neutral bushings in all  
6 of its transformers suspected to be contaminated with PCBs, by 2025?

7

8

9 A. Yes. Newfoundland and Labrador Hydro plans to replace bushings, including neutral bushings, in  
10 all of its transformers suspected to contain PCBs<sup>1</sup> with a concentration of 50 ppm or greater by  
11 2025. This is necessary to meet the latest PCB regulations requiring a PCB concentration of less  
12 than 50 ppm for all equipment remaining in service beyond 2025.

---

<sup>1</sup> Polychlorinated biphenyl ("PCB").