

1 Q. **Reference: Volume II, Wood Pole Line Management Program - Various, Tab 11, page 9, Table 7**

2

3 Has Hydro experienced any outages due to conductor damage since 2004?

4

5

6 A. Newfoundland and Labrador Hydro has not experienced any significant issues with conductor on  
7 its transmission lines. Broken strands are occasionally found during inspections and are repaired  
8 as required.