

1 Q. **Reference: Distribution Upgrades (2020–2021) – Various**

2

3 With respect to its Distribution System Upgrades (2020 – 2021) – Various capital project, does  
4 Hydro have a specific “corporate level statistic” target?

5

6

7 A. Newfoundland and Labrador Hydro (“Hydro”) does not have a specific “corporate level statistic”  
8 target for distribution feeder performance. For the Distribution System Upgrade capital projects,  
9 Hydro analyzes the performance of all distribution feeders and selects the 25 worst-performing  
10 feeders for further analysis. When justifiable as a result of detailed analysis, Hydro proposes  
11 capital upgrading on feeders from this 25 worst-performing feeder list to improve customer  
12 reliability.