

Newfoundland and Labrador Hydro Hydro Place. 500 Columbus Drive P.O. Box 12400. St. John's. NL Canada A1B 4K7 t. 709.737.1400 I f. 709.737.1800 nlhydro.com

August 11, 2025

Board of Commissioners of Public Utilities Prince Charles Building 120 Torbay Road, P.O. Box 21040 St. John's, NL A1A 5B2

Attention: Jo-Anne Galarneau

Executive Director and Board Secretary

Re: Reliability and Resource Adequacy Study Review – Final Lower Churchill Project Operational (Stage 4F) Study

Please find enclosed Newfoundland and Labrador Hydro's Final Lower Churchill Project Operational (Stage 4F) Study, provided in accordance with the 2024 Resource Adequacy Plan Settlement Agreement.¹

Should you have any questions, please contact the undersigned.

Yours truly,

NEWFOUNDLAND AND LABRADOR HYDRO

Shirley A. Walsh Senior Legal Counsel, Regulatory

SAW/kd

Encl.

ecc:

Board of Commissioners of Public Utilities

Jacqui H. Glynn Ryan Oake Board General

Island Industrial Customer Group

Paul L. Coxworthy, Stewart McKelvey Denis J. Fleming, Cox & Palmer Glen G. Seaborn, Poole Althouse **Labrador Interconnected Group**

Senwung F. Luk, Olthuis Kleer Townshend LLP Nicholas E. Kennedy, Olthuis Kleer Townshend LLP

Consumer Advocate

Dennis M. Browne, KC, Browne Fitzgerald Morgan & Avis Stephen F. Fitzgerald, KC, Browne Fitzgerald Morgan & Avis Sarah G. Fitzgerald, Browne Fitzgerald Morgan & Avis Bernice Bailey, Browne Fitzgerald Morgan & Avis **Newfoundland Power Inc.**Dominic J. Foley
Douglas W. Wright

Regulatory Email

¹ "2025 Build Application – Bay d'Espoir Unit 8 and Avalon Combustion Turbine," Newfoundland and Labrador Hydro, March 21, 2025, sch. 2.

Final LCP Operational (Stage 4F) Study

Overview

August 11, 2025

A report to the Board of Commissioners of Public Utilities



Contents

| 1.0 | Context within the RRA Study Review | 1 |
|-----|-------------------------------------------------------|------|
| 2.0 | | |
| 2.0 | Background | 2 |
| 2.1 | LIL-Maritime Link Relationship | 3 |
| 2.2 | UFLS Schemes | 4 |
| 2.3 | Existing LIL Bipole Transfer Limits | 5 |
| 3.0 | Summary of Stage 4F Study Results Relevant to the RRA | 6 |
| 3.1 | Underfrequency Event | 6 |
| 3.2 | Overfrequency Event | 7 |
| 3.3 | Updated LIL Bipole Transfer Limits | 7 |
| 3.4 | Improvements to the LIL-Maritime Relationship | . 12 |
| 4.0 | Conclusion and Next Steps | . 13 |
| | | |

List of Attachments

Attachment 1: Final LCP Operational Study (Stage 4F) Report



1.0 Context within the RRA Study Review

- 2 Newfoundland and Labrador Hydro ("Hydro") filed the initial "Reliability and Resource Adequacy Study"
- 3 ("RRA Study") with the Board of Commissioners of Public Utilities ("Board") in November 2018 ("2018
- 4 Filing"). Since the 2018 Filing, throughout the continued Reliability and Resource Adequacy Study
- 5 Review proceeding ("RRA Study Review"), Hydro has filed regular updates to the RRA Study, including
- 6 numerous technical notes, additional studies, and third-party reports. The regulatory record for this
- 7 proceeding is robust, with good reason. The provincial electrical grid is in the midst of unprecedented
- 8 change—it is evolving from an isolated to an interconnected system, some of the assets the province
- 9 has historically relied on most are aging and nearing retirement, there are significant new assets
- integrated into the electrical system and being proven reliable, and the province is facing an increase in
- 11 demand driven by electrification.

1

- 12 Hydro's most recent study submitted to the Board on July 9, 2024, is its 2024 Resource Adequacy Plan,
- 13 containing Hydro's recommended Minimum Investment Required Expansion Plan.² Subsequent to filing
- its 2024 Resource Adequacy Plan, Hydro and its experts participated in a series of technical conferences
- in the fall of 2024 with Board staff and intervening parties, along with their experts. These technical
- 16 conferences provided an opportunity for fulsome discussion and enhanced understanding of Hydro's
- 17 RRA Study Review and Expansion Plans. As a result of these proceedings, Hydro and the Intervenors
- 18 gained consensus on a number of issues ("Settled Issues") which were enumerated in a Settlement
- 19 Agreement.³ The Settled Issues include agreement that the recommendation to build a new 150 MW
- 20 unit at Bay d'Espoir (Unit 8) and a 150 MW Combustion Turbine on the Avalon Peninsula is appropriate
- 21 as part of the first step in addressing the requirements for additional capacity for the Island
- 22 Interconnected System, and applications for these projects should be filed for evaluation. In line with
- the Settled Issues, Hydro filed its 2025 Build Application for both of these assets in March 2025; the
- 24 regulatory proceeding is ongoing.

³ "2025 Build Application – Bay d'Espoir Unit 8 and Avalon Combustion Turbine," Newfoundland and Labrador Hydro, March 21, 2025 ("2025 Build Application"), sch. 2.



¹ "Reliability and Resource Adequacy Study," Newfoundland and Labrador Hydro, rev. September 6, 2019 (originally filed November 16, 2018).

² "2024 Resource Adequacy Plan – An Update to the Reliability and Resource Adequacy Study," Newfoundland and Labrador Hydro, rev. August 26, 2024 (originally filed July 9, 2024).

- 1 The RRA Study Review has included numerous rounds of requests for information and technical
- 2 conferences, providing for ample discourse and exchange of information between Hydro, the Board, and
- 3 the parties.
- 4 In the coming years and decades, beginning with the recommended assets within its Minimum
- 5 Investment Required portfolio, Hydro will have to make significant investments to maintain its
- 6 legislative obligation of the provision of safe, least-cost, reliable electrical service in an environmentally
- 7 responsible manner to the province. ⁴ As such, through the RRA Study Review, Hydro is modelling its
- 8 system expansion in consideration of various forecast scenarios and within the context of continuously
- 9 evolving energy policy. The numerous studies that Hydro has completed and planned are all necessary
- 10 to validate and justify the information that Hydro inputs into its models, that produce critical
- information on which timely, prudent decisions are to be made.
- While the enclosed study provides valuable, necessary information, it cannot and should not be
- considered independent of the rest of the studies and analyses ongoing through the RRA Study
- 14 Review. Rather, the study is an input that will—along with other studies completed and ongoing—
- inform Hydro's broader system resource planning process now and into the future.

2.0 Background

16

- 17 Hydro has been working with its independent expert, TransGrid Solutions ("TransGrid"), since 2017 on a
- series of operational studies in support of each major phase of the asset integration process for the
- 19 Lower Churchill Project ("LCP"). The objective of these studies has been to provide guidance to Hydro in
- 20 ensuring the reliable operation of the Newfoundland and Labrador transmission system during each
- 21 phase of the LCP integration. The primary focus of the operational studies has been to determine the
- 22 Labrador-Island Link ("LIL") and Maritime Link transfer limits under various system conditions. The final
- 23 operational study ("Stage 4F Study") has established system operating limits for all LCP assets
- 24 subsequent to final commissioning. The purpose of this document is to summarize the results of the
- 25 Stage 4F Study, provided as Attachment 1,5 that would be relevant to the upcoming 2026 Resource
- 26 Adequacy Plan filing.

⁵ "LCP Operational Study: Final LCP Operational Study ("Stage 4F") Report," TransGrid Solutions Inc., June 26, 2025.



⁴ Electrical Power Control Act, 1994, SNL 1994, c E-5.1, s 3(b)(iii).

- 1 The 2026 Resource Adequacy Plan filing will include an update to the firm energy analysis, which is
- 2 heavily influenced by the updated LIL Bipole transfer limits developed as part of the Stage 4F Study. ⁶ To
- 3 increase power flow to the Island over the LIL, more under-frequency load shedding ("UFLS") would be
- 4 deemed acceptable following a LIL bipole trip. The increase in LIL transfer limits associated with the new
- 5 proposed UFLS scheme ("Final UFLS Scheme") provides an improvement to the LIL-Maritime Link
- 6 relationship and thereby will permit more energy from Labrador to be absorbed on the Island

available UFLS is directly proportional to the total Island load, as shown in Figure 1.

7 Interconnected System.

8

9

10

11

12

13

14

15

16

17

18

2.1 LIL-Maritime Link Relationship

The LIL and the Maritime Link are equipped to provide frequency regulation in the event of pole and bipole contingencies on either link. Consequently, flows on the LIL and the Maritime Link must be coordinated. Therefore, under normal system conditions, the amount of energy that can flow over the LIL to the Island is limited by the interdependencies with the Maritime Link. This interdependence exists because both high-voltage direct current ("HVdc") links must work together through the use of runbacks to suddenly reduce their power flows to transiently regulate system frequency in the event a contingency occurs on the other HVdc link. This LIL-Maritime Link relationship has a significant impact on the amount of power that can be absorbed on the Island (Net dc⁷), but is primarily dependent on the amount of UFLS that is available and would be triggered following a LIL bipole trip. The amount of




Figure 1: Illustrative Example of Current LIL-Maritime Link Relationship

⁷ Direct current ("dc"). This would be the difference between Maritime Link export levels and the LIL imports at Soldiers Pond.



⁶ The updated LIL bipole transfer limits are provided in Section 4.1 of the Stage 4F Study.

- 1 In the event of a LIL bipole trip and a subsequent Maritime Link runback, the Island system would
- 2 experience a loss of supply at a magnitude of the Net dc. The only mechanism to transiently offset this
- 3 loss of supply would be UFLS. Therefore, the higher the amount of armed UFLS, the more energy that
- 4 can be sunk on the Island Interconnected System. The Stage 4F Study provides the updated LIL bipole
- 5 transfer limits associated with the implementation of the Final UFLS Scheme, which in turn quantifies
- 6 the improvement of the LIL-Maritime Link relationship.

2.2 UFLS Schemes

7

- 8 A UFLS scheme⁸ is a form of system protection that involves shedding load in blocks to ensure a stable
- 9 system response following a contingency event. The UFLS scheme currently in place is referred to as the
- 10 "Existing UFLS Scheme." Table 1 provides a summary of the Existing and Final UFLS Schemes assuming
- peak demand levels of 1,800 MW and 2,000 MW, 9 respectively. The block size amounts scale
- 12 proportionally to the Island Demand level. 10 Therefore, it would be expected that the total amount of
- 13 UFLS for the Existing UFLS Scheme would be approximately 295 MW at an Island Demand of 900 MW.

Table 1: UFLS Schemes

| | UFLS Block Size (MW) ¹¹ | | |
|----------------------------------|------------------------------------|-------------------|--|
| Frequency Blocks (Hz) | Existing UFLS Scheme | Final UFLS Scheme | |
| 58.8 | 110 | 160 | |
| 58.6 | 110 | 170 | |
| 58.4 | 120 | 170 | |
| 58.2 | 115 | 168 | |
| 58.1 | 135 | 88 | |
| 58.0 ¹² | 165 | - | |
| 57.7 ¹³ | - | 105 | |
| Total (Excluding Back-up Blocks) | 590 | 756 | |
| Assumed System Peak | 1,800 MW | 2,000 MW | |
| Percentage of System Peak Shed | 33% | 38% | |

⁸ Hydro is responsible for UFLS design, while Newfoundland Power Inc. manages the scheme and ensures it fairly rotates amongst their customers.

¹³ Safety Block – not intended to shed as part of the future UFLS Scheme following a LIL bipole trip; therefore, it is not included in the total. The purpose of the back-up blocks are to protect the system in the rare event that the system does not respond as expected or if it turns into a cascading event, for example. The LIL limits determined in the Stage 4F Study were not designed to utilize the back-up block.



⁹ The Final UFLS Scheme was designed to support a peak demand of 2,000 MW. The Final UFLS Scheme can be applied above Island Demand levels of 2,000 MW, but the total UFLS amount must be limited to 756 MW. In this case, LIL transfer limits would have to be established for Island Demand beyond 2,000 MW, with total UFLS fixed at 756 MW.

¹⁰ Hydro anticipates potential Island loads at 2,000 MW or higher by 2036 in the Reference Case load forecast.

¹¹ The block sizes are approximate values obtained from the Power System Simulation for Engineering (PSS/E)model.

¹² Safety Block – not intended to shed as part of the existing UFLS Scheme following a LIL bipole trip; therefore, it is not included in the total. The purpose of the back-up blocks are to protect the system in the rare event that the system does not respond as expected or if it turns into a cascading event, for example. The LIL limits determined in the Stage 4F Study were not designed to utilize the back-up block.

- 1 There is a technical limitation to the total amount of allowable UFLS on the Island Interconnected
- 2 System. In the event that too much UFLS is triggered following a LIL bipole trip (and the subsequent
- 3 Maritime Link runback), there would be a surplus of power on the Island Interconnected System that
- 4 would result in system overfrequency. This is discussed in more detail in Sections 4.1.2 and 4.1.3 of the
- 5 Stage 4F Study. The increased amount of load shedding associated with the Final UFLS Scheme permits
- 6 more LIL power transfer and therefore allows more energy that can be absorbed on the Island
- 7 Interconnected System.

8

9

10

11

12

13

14

2.3 Existing LIL Bipole Transfer Limits

The LIL bipole transfer limits currently in place are based on the Existing UFLS Scheme outlined in Table 1. Chart 1 illustrates the existing LIL bipole transfer limits for various Maritime Link export levels under normal operating conditions. There are separate plots for various Maritime Link export levels due to the LIL-Maritime Link Relationship, while the slope of each plot is directly proportional to the amount of available UFLS that could be tripped following a LIL bipole trip. The intention is that the implementation of the Final UFLS scheme will increase these transfer limits as presented in Section 3.3.




Chart 1: Existing LIL Bipole Transfer Limits (Normal Operation)¹⁴

¹⁴ Measured at sending end, or Muskrat Falls.



Page 5

3.0 Summary of Stage 4F Study Results Relevant to the RRA

- 2 The purpose of this overview is to provide a high-level summary of the results of the Stage 4F Study that
- 3 are relevant to the ongoing RRA Study Review, specifically the update to the LIL bipole transfer limits
- 4 with the Final UFLS Scheme applied. The updated LIL bipole transfer limits were defined to meet Hydro's
- 5 Transmission Planning Criteria or avoid both an underfrequency and overfrequency event following a LIL
- 6 bipole trip.

1

7

8

9

10

11

- **Underfrequency Event:** Island Interconnected System frequency must not drop below 57.8 Hz following a LIL bipole trip and must recover to avoid the risk of system instability.
- Overfrequency Event: Island Interconnected System frequency must not exceed 63.0 Hz following a contingency event to avoid any negative impacts to Hydro's generation assets.¹⁵

3.1 Underfrequency Event

- 12 The sudden loss of generation (or supply) on the Island Interconnected System will result in a decrease
- in system frequency that, if severe enough, could potentially lead to system instability. A LIL bipole trip
- 14 would be an event that would result in a loss of supply with a Maritime Link runback, and UFLS being a
- means to mitigate the underfrequency.
- 16 Figure 2 shows the frequency response of the Island Interconnected System at 2,000 MW following a LIL
- 17 bipole trip while operating at capacity (900 MW) during peak load conditions in which a 150 MW
- 18 Maritime Link runback was activated. In this case, the system frequency drops to 57.8 Hz, triggering all
- 19 UFLS blocks except the 57.7 Hz back-up block and then successfully recovers.




Figure 2: Underfrequency Following LIL Bipole Trip (900 MW) with a 150 MW Maritime Link Runback (Peak Load Conditions)

¹⁵ Generating units, specifically thermal units, should not be exposed to excessive over-speeds.



3.2 Overfrequency Event

1

13

- 2 As summarized in Section 4.1.2 of the Stage 4F Study, unacceptable overfrequency events were
- 3 observed on the Island Interconnected System for certain scenarios following a Maritime Link runback
- 4 and UFLS after a LIL bipole trip. When the system recovers from an underfrequency event caused by a
- 5 LIL bipole trip, a large overfrequency occurs because of the resulting power imbalance on the Island
- 6 Interconnected System. At higher Island Interconnected System demand levels, there is inherently more
- 7 load that is shed by the UFLS Scheme, which corresponds to a higher system frequency and, in some
- 8 cases, will violate Hydro's Transmission Planning Criteria.
- 9 Figure 3 shows the frequency response of the Island Interconnected System following a LIL bipole trip
- 10 while operating at capacity (900 MW) at an Island Demand of 2,000 MW, in which a 250 MW Maritime
- 11 Link runback was activated. In this case, an overfrequency event occurs with the system increasing
- beyond 64 Hz, violating Hydro's Transmission Planning Criteria.




Figure 3: Underfrequency following LIL Bipole Trip (900 MW) with a 150 MW Maritime Link Runback (Future Peak Load Conditions – 2,000 MW)

3.3 Updated LIL Bipole Transfer Limits

- 14 The updated LIL bipole transfer limits under normal operating conditions are provided in Table 4-3 of
- 15 the Stage 4F Study. There were nine Island Demand level simulations for Maritime Link export levels of
- 16 150 MW, 250 MW, 300 MW, 400 MW, and 500 MW, equating to the establishment of 45 scenarios or
- 17 operating points. TransGrid adjusted LIL power flow and the amount of UFLS to ensure system
- 18 frequency response was acceptable and remained within 57.7 Hz and 63 Hz in order to establish the
- optimal LIL bipole transfer limits for each operating point or scenario.
- 20 Using linear regression on all the simulated operating points, a relationship was established between LIL
- 21 transfer limits and Island Demand for each Maritime Link export level and summarized in Table 2.



- 1 Charts 2 to 6 are graphs of the LIL bipole transfer limits for both the Existing and Final UFLS Schemes for
- 2 various Maritime Link export levels.
- 3 As illustrated in Charts 2 to 6, the LIL Bipole Transfer limits are equal for the Existing and Final UFLS
- 4 Schemes for any Island Demand levels less than approximately 700 MW. At Island Demand levels less
- 5 than or equal to 700 MW, the frequency response of the Island Interconnected System is not the most
- 6 limiting factor when defining LIL bipole transfer limits; the limiting factor becomes the minimum
- 7 generation requirement and ensuring a balance of supply and demand on the Island Interconnected
- 8 System. There must be a minimum amount of dispatched generation on the Island Interconnected
- 9 System that equates to about 400 MW, which is required for reliability and to provide station service
- 10 load to certain plants. In a 600 MW Island Demand scenario with 160 MW of Maritime Link exports, the
- minimum generation requirement of 400 MW would limit LIL delivery to Soldiers Pond to 360 MW. ¹⁶ If
- 12 LIL imports are higher, there would be a surplus of supply on the Island Interconnected System.
- 13 The LIL Bipole Transfer Limits with Maritime Link exports at 150 MW are shown in Chart 2. At an Island
- 14 Interconnected System load of in excess of approximately 700 MW, the final UFLS scheme allows for
- 15 greater LIL imports of up to 900 MW, depending on the magnitude of the Island Interconnected System
- 16 load.




Chart 2: LIL Bipole Transfer Limits (Maritime Link=150 MW) (Normal Operation)

¹⁶ Island Demand + Maritime Link Exports - Minimum Island Generation. 600 MW +160 MW - 400MW = 360 MW.



Page 8

- 1 The LIL Bipole Transfer Limits with Maritime Link exports at 250 MW are shown in Chart 3. At an Island
- 2 Interconnected System load of in excess of approximately 700 MW, the final UFLS scheme allows for greater
- 3 LIL imports of up to 900 MW, depending on the magnitude of the Island Interconnected System load.




Chart 3: LIL Bipole Transfer Limits (Maritime Link=250 MW) (Normal Operation)

- 4 The LIL Bipole Transfer Limits with Maritime Link exports at 300 MW are shown in Chart 4. At an Island
- 5 Interconnected System load of between approximately 700 MW and 1,900 MW, the final UFLS scheme
- 6 allows for greater LIL imports of up to 900 MW, depending on the magnitude of the Island
- 7 Interconnected System load.




Chart 4: LIL Bipole Transfer Limits (Maritime Link = 300 MW) (Normal Operation)



- 1 The LIL Bipole Transfer Limits with Maritime Link exports at 400 MW are shown in Chart 5. At an Island
- 2 Interconnected System load of between approximately 700 MW and 1,600 MW, the final UFLS scheme
- 3 allows for greater LIL imports of up to 900 MW, depending on the magnitude of the Island
- 4 Interconnected System load.




Chart 5: LIL Bipole Transfer Limits (Maritime Link=400 MW) (Normal Operation)

- 5 The LIL Bipole Transfer Limits with Maritime Link exports at 500 MW are shown in Chart 6. At an Island
- 6 Interconnected System load of between approximately 700 MW and 900 MW, the final UFLS scheme
- 7 allows for greater LIL imports of up to 900 MW, depending on the magnitude of the Island
- 8 Interconnected System load.




Chart 6: LIL Bipole Transfer Limits (Maritime Link=500 MW) (Normal Operation)



Table 2: LIL Bipole Transfer Limits (Final UFLS Scheme)

| Island Demand (MW) | Maritime Link =150 | Maritime Link =250 | Maritime Link =300 | Maritime Link =400 | Maritime Link =500 |
|-----------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| 400 | 153 | 257 | 310 | 417 | 526 |
| 450 | 204 | 310 | 363 | 471 | 581 |
| 500 | 257 | 363 | 417 | 526 | 637 |
| 550 | 310 | 417 | 471 | 581 | 693 |
| 600 | 363 | 471 | 526 | 637 | 750 |
| 650 | 417 | 526 | 581 | 693 | 808 |
| 700 | 449 | 581 | 637 | 750 | 866 |
| 750 | 466 | 588 | 655 | 774 | 900 |
| 800 | 483 | 607 | 677 | 798 | 900 |
| 850 | 501 | 626 | 698 | 823 | 900 |
| 900 | 518 | 645 | 720 | 848 | 900 |
| 950 | 535 | 664 | 742 | 873 | 900 |
| 1000 | 552 | 683 | 764 | 898 | 900 |
| 1050 | 569 | 702 | 785 | 900 | 900 |
| 1100 | 586 | 721 | 807 | 900 | 900 |
| 1150 | 603 | 740 | 829 | 900 | 900 |
| 1200 | 620 | 758 | 850 | 900 | 900 |
| 1250 | 637 | 777 | 872 | 900 | 900 |
| 1300 | 654 | 796 | 900 | 900 | 900 |
| 1350 | 671 | 815 | 900 | 900 | 900 |
| 1400 | 689 | 834 | 900 | 900 | 900 |
| 1450 | 706 | 853 | 900 | 900 | 900 |
| 1500 | 723 | 872 | 900 | 900 | 900 |
| 1550 | 740 | 900 | 900 | 900 | 900 |
| 1600 | 757 | 900 | 900 | 900 | 900 |
| 1650 | 774 | 900 | 900 | 900 | 900 |
| 1700 | 791 | 900 | 900 | 900 | 900 |
| 1750 | 808 | 900 | 900 | 900 | 900 |
| 1800 | 825 | 900 | 900 | 900 | 900 |
| 1850 | 842 | 900 | 900 | 900 | 900 |
| 1900 | 859 | 900 | 900 | 900 | 900 |
| 1950 | 877 | 900 | 900 | 900 | 900 |
| 2000 | 894 | 900 | 900 | 900 | 900 |
| 2050 | 900 | 900 | 900 | 900 | 900 |



3.4 Improvements to the LIL-Maritime Relationship

2 The LIL bipole transfer limits have increased with the Final UFLS Scheme applied as indicated in Charts 2

to 6. The increase in LIL bipole transfer limits for a given Island Demand level for each Maritime Link

export level translates into more LIL energy that can be absorbed on the Island Interconnected System

(or Net dc). Chart 7 illustrates the incremental increase in Net dc associated with the application of the

Final UFLS Scheme compared to the Existing UFLS Scheme for various Maritime Link export levels. The

LIL-Maritime Link relationship has significantly improved since LIL power transfer has less dependency

on the Maritime Link export levels, meaning a higher Net dc. In a peak scenario with Island Demand

approximately 1,800 MW, the incremental Net dc with the Final UFLS Scheme applied is 190 MW, which

means the LIL power transfer delivered at Soldiers Pond can be 190 MW more for the same Island

Demand and Maritime Link export level.

1

3

4

5

6

7

8

9

10

11

12

13

14 15 This incremental increase in Net dc using the Final UFLS Scheme will reduce the firm energy deficit analyzed in each Island Interconnected System load forecast scenario presented in the 2025 Build Application by approximately 450–500 GWh. ¹⁷ A full update to the firm energy analysis will be provided in the 2026 Resource Adequacy Plan.




Chart 7: LIL-Maritime Link Relationship Improvement (Final UFLS Scheme – Normal Operation)

¹⁷ "2025 Build Application – Bay d'Espoir Unit 8 and Avalon Combustion Turbine," Newfoundland and Labrador Hydro, March 21, 2025, sch. 3, sec. 4.0.



Page 12

4.0 Conclusion and Next Steps

1

- 2 The primary objective of the TransGrid Study, as it relates to the RRA Study Review, is to determine the
- 3 technical viability of increasing the amount of allowable UFLS with the purpose of increasing LIL bipole
- 4 transfer limits to improve the LIL-Maritime Link relationship. Analysis was performed as part of the
- 5 Stage 4F Study that quantified the improvement of the LIL-Maritime Link relationship. This improvement
- 6 in the LIL-Maritime Link relationship will facilitate more energy that can be absorbed on the Island
- 7 Interconnected System and potentially reduce or defer the requirement for future firm energy sources
- 8 on the Island Interconnected System. This incremental increase in Net dc using the Final UFLS Scheme
- 9 will reduce the firm energy deficit analyzed in each Island Interconnected System load forecast scenario
- that was presented in the 2025 Build Application by approximately 450–500 GWh. ¹⁸ This reduction
- 11 results in less firm energy resources required to meet the Island Interconnected System firm energy
- 12 criteria. As the least-cost resource option to meet the firm energy requirement was identified as wind, a
- 13 capacity credit was assigned to this resource in the recommended Minimum Investment Required
- 14 expansion plan. Therefore, the reduction of the amount of wind required will result in the reduction of
- the capacity contribution from wind as presented in the Minimum Investment Required expansion plan.
- 16 The Final UFLS Scheme does not have any impact on the capacity projects recommended in the 2025
- 17 Build Application: Bay d'Espoir Unit 8 and the Avalon Combustion Turbine. A full update to the firm
- 18 energy analysis will be provided in the 2026 Resource Adequacy Plan.
- 19 As a next step, through further power system studies, Hydro will quantify if further improvements to the
- 20 LIL-Maritime Link relationship are possible with the application of a Battery Energy Storage System
- 21 ("BESS") capable of providing additional frequency response following a LIL bipole trip. Any additional
- benefits from a BESS on the LIL-Maritime Link relationship and its effect on the firm energy analysis will
- 23 be incorporated into the analysis for the 2026 Resource Adequacy Plan.





Attachment 1

Final LCP Operational Study (Stage 4F) Report

TransGrid Solutions Inc.






LCP OPERATIONAL STUDY:

Final LCP Operational Study ("Stage 4F") Report

NEWFOUNDLAND & LABRADOR HYDRO



Attention: Matthew Carter Report no.: R1205.01.03 Date of issue: June 26, 2025 Prepared By: TransGrid Solutions Inc. 100-78 Innovation Dr. Winnipeg, MB R3T 6C2 CANADA



Disclaimer

This report was prepared by TransGrid Solutions Inc. ("TGS"), whose responsibility is limited to the scope of work as shown herein. TGS disclaims responsibility for the work of others incorporated or referenced herein. This report has been prepared exclusively for Newfoundland & Labrador Hydro ("Hydro") and the project identified herein and must not be reused or modified without the prior written authorization of TGS.

Revisions

| Project Name: | LCP Operational Study | | |
|-------------------|-------------------------------------------------|--|--|
| Document Title: | Final LCP Operational Study ("Stage 4F") Report | | |
| Document Type: | Final Report | | |
| Document No.: | R1205.01.03 | | |
| Last Action Date: | June 26, 2025 | | |

| Rev. No. | Status | Prepared By | Checked By | Date | Comments |
|----------|--------|-------------|------------|----------------|--------------------------------------------------------------------------------------------|
| 00 | DFC | R. Ostash | M. Carter | April 21, 2025 | Draft report issued for review by Hydro |
| 01 | DFC | R. Ostash | M. Carter | | Updated draft report issued for review by Hydro after addressing initial round of comments |
| 02 | DFC | R. Ostash | M. Carter | | Updated draft report after additional round of comments. |
| 03 | IFA | R. Ostash | M. Carter | | Updated report after additional round of comments. |
| | | | | | |

Legend of Document Status:

| Approved by Client | ABC |
|---------------------|-----|
| Draft for Comments | DFC |
| Issued for Comments | IFC |
| Issued for Approval | IFA |



Table of Contents

| Exec | cutive Summary | 1 |
|--------|------------------------------------------------------|----|
| 1. Int | ntroduction | 2 |
| 1.1 | Interconnected Island System | 2 |
| 1.2 | Labrador Interconnected System | 2 |
| 2. Su | ummary of Previous Studies | 4 |
| 3. St | tudy Assumptions, Criteria and Cases | 5 |
| 3.1 | Study Assumptions | 5 |
| 3.2 | Study Criteria | 5 |
| 3.3 | PSSE Base Cases | 6 |
| 4. LII | IL Limits | 7 |
| 4.1 | LIL Bipole Limits | 7 |
| 4.2 | LIL Monopole Limits | 24 |
| 5. ML | IL Export Limits | 28 |
| 5.1 | LIL Frequency Support Available | 28 |
| 5.2 | LIL Frequency Support Unavailable | 29 |
| 6. ML | IL Import Limits | 31 |
| 6.1 | LIL Frequency Support Available | 31 |
| 6.2 | LIL Frequency Support Unavailable | 31 |
| 7. Ot | Other Considerations | 34 |
| 7.1 | Minimum Avalon Generation | 34 |
| 7.2 | LIL Filter Feeder Impact | 38 |
| 7.3 | LIL Limits with Cable Issues | 40 |
| 7.4 | LIL Limits with 0 / 1 SOP SC | 41 |
| 7.5 | Stability Transfer Limits (Prior Outage TL201/TL217) | 41 |
| 7.6 | 315 kV Prior Outage Limits | 43 |
| 7.7 | Maximum Generator Unit Loading | 57 |

Executive Summary

TransGrid Solutions has performed a series of operational studies for Newfoundland and Labrador Hydro ("Hydro") for each major phase of the asset integration process for Lower Churchill Project ("LCP"). These major assets included the Labrador Island Link ("LIL"), Maritime Link ("ML"), Soldiers Pond ("SOP") Synchronous Condensers, Muskrat Falls ("MFA") generators and the 315 kV lines between MFA and Churchill Falls ("CHF").

The objective of these studies has been to provide guidance to Hydro in ensuring the reliable operation of the Newfoundland and Labrador ("NL") transmission system during each phase of LCP commissioning. The primary focus of the operational studies has been to determine the LIL and ML transfer limits under various system conditions.

The final operational study ("The Stage 4F Study") has established system operating limits for all LCP assets assuming they have been fully commissioned. This report provides a comprehensive overview of the Stage 4F Study, which provides the following deliverables:

- Updated LIL **Bipole** Transfer Limits (with and without LIL restarts):
 - Using the existing underfrequency load shedding ("UFLS") scheme
 - Using a final modified version of the UFLS scheme for the purpose of maximizing LIL power transfer
- Updated LIL **Monopole** Transfer Limits (with and without LIL restarts)
- Updated ML **Bipole** Import/Export Transfer Limits
- Updated ML Monopole Import/Export Transfer Limits
- The following are other topics that were also assessed as part of the Stage 4F study that relate to the operation/integration of LCP assets:
 - Minimum Avalon Generation
 - LIL Filter Feeder Contingency Impact
 - LIL Limits with Subsea Cable Issues
 - LIL Limits with 0 or 1 SOP synchronous condensers online
 - Stability Transfer Limits (Prior Outage to TL201/TL217)
 - Update of the 315 kV Limits (with and without LIL F/C)



1. Introduction

The purpose of the Stage 4F Study is to establish system operating limits for all LCP assets assuming they have been fully commissioned. The Interconnected Island System ("IIS") and Labrador Interconnected System("LIS") are the areas of focus for this study.

The Stage 4F Study provides updated LIL and ML transfer limits for both bipole and monopole modes of operation, and addresses a list of other factors affecting LIS and IIS operation including:

- Minimum Avalon Generation
- LIL Filter Feeder Contingency Impact
- LIL Limits with Subsea Cable Issues
- LIL Limits with 0 or 1 SOP synchronous condensers
- Stability Transfer Limits (Prior Outage to TL201/TL217)
- Update of the 315 kV Limits (with and without LIL F/C)

1.1 **Interconnected Island System**

The 230 kV network of the IIS is shown in Figure 1-1.




Figure 1-1. IIS - 230 kV Transmission System

Labrador Interconnected System 1.2

The LIS between Muskrat Falls and Churchill Falls is shown in Figure 1-2.



Analysis involving the 315 kV lines between MFA and CHF is addressed in this study (Section 7.6).




Figure 1-2. LIS between Happy Valley and Churchill Falls



2. Summary of Previous Studies

Operational studies related to the addition of the MFA generating units, the ML, the LIL and the SOP synchronous condensers to the IIS started in 2017 and have been underway since that time, leading up to this Stage 4F study. The main purpose of the operational studies has been to determine LIL transfer limits and ML import/export limits throughout the various stages of LCP asset commissioning. Previous reports determined these limits for:

- Initial scenario with only the ML in-service
- SOP synchronous condensers coming into service
- Phased approach for the LIL coming into service, first as a monopole at 225 MW maximum transfer, then as a bipole at reduced transfer and finally as a bipole at full power with full functionality (2 pu overload, frequency support); assuming Hydro's original UFLS scheme.

Addition of the LIL bipole to the IIS also required a re-design of the UFLS scheme that is currently in place to ensure the IIS can maintain stability and meet dynamic performance criteria under a LIL bipole trip. Coordination of the ML and LIL was also required, e.g. running back of ML exports following a LIL bipole trips.

Operational limits were defined for various operating conditions such as:

- 0, 1, 2 and 3 SOP SCs being on-line
- LIL operating as monopole
- ML operating as monopole
- LIL frequency support active / not active
- ML frequency support active / not active
- ML runbacks active / not active

Operation of the IIS under a LIL bipole outage has also been studied and is still under study, in which case the 230 kV transmission corridor between BDE and SOP becomes of utmost importance to transferring power from generation in the west of the IIS to the main load center on the Avalon Peninsula.

Finally, operational studies on the Labrador side were conducted to identify impacts on LIL limits¹ and transfer limits between CHF and MFA under various operating conditions including:

- 2, 3 or 4 MFA generating units on-line
- Prior outage of a 315 kV line between MFA and CHF
- Isolated operation of the LIL with vary number of MFA generating units online



¹ With and without the future 315 kV line reactors in-service.

3. Study Assumptions, Criteria and Cases

Study Assumptions 3.1

The following are the high-level assumptions made for this study:

- Thermal generation from Holyrood ("HRD") units (1,2,3) is decommissioned. HRD unit 3 is operating as a synchronous condenser.
- Bay d'Espoir ("BDE") unit 8 is in-service. When not required for MW, it is set to synchronous condenser mode.
- Two Soldiers Pond synchronous condensers are in-service.
- LIL frequency controller is in-service with control (PFC) set in SOP (with exception to Section 6.6.1).
- LIL 2 pu 10-minute overload is available.
- ML can operate between 320 MW import and 500 MW export, if not limited by operational restrictions.
- As long as import capacity is available, the ML frequency controller may be activated to provide up to 150 MW of frequency support if a LIL pole or the bipole is lost or for other underfrequency events on the IIS2. It is assumed that if a ML runback has taken place in response to loss of the LIL bipole or pole, that further action by the ML frequency controller will not occur in this situation.
- Under normal operation the ML frequency controller shall be active when ML flow is between -170MW (import) to 150 MW (export). Runbacks shall be enabled whenever the ML is exporting greater than 150 MW.
- The new 3x50 MW HRD CTs are assumed available but are only dispatched when required to serve IIS demand, ML export and / or for minimum Avalon generation requirements as discussed in this report.
- Happy Valley-Goose Bay ("HVY") load was assumed to range from 15 MW to 80 MW in the analysis involving the MFA-CHF 315 kV transfer limits in Labrador.
- Normal LIL filter switching schedule was assumed.
- Minimum on-Island Generation dispatched is assumed to be 400 MW.

3.2 **Study Criteria**

The applicable Transmission Planning Criteria for this study is summarized below:

Steady state voltage: 0.95 pu - 1.05 pu during n-0 conditions

Unless an ML runback just occurred, at which time the ML frequency controller is automatically disabled.



- Steady state voltage: 0.90 pu 1.1 pu during n-1 conditions
- Post fault recovery voltages on the ac system shall be as follows:
 - Transient undervoltages following fault clearing should not drop below 70%
 - The duration of the voltage below 80% following fault clearing should not exceed 20 cycles
- IIS frequency must stay within 59 Hz to 63 Hz following a single contingency event to avoid UFLS and overfrequencies that could have an adverse impact on generation assets.
- LIS Frequency must stay within 58 Hz to 63 Hz following a single contingency event to avoid tripping MFA units on under/over frequency, respectively. The tripping of the MFA units would likely have a cascading effect and trip the LIL bipole.
- For a permanent loss of the ML bipole, underfrequency load shedding shall be permitted, but controlled, and the system frequency shall not drop below 58 Hz.
- For a permanent loss of the LIL bipole, underfrequency load shedding is permitted, but controlled. In the final modified design of the UFLS scheme (to be implemented in the future), the system frequency is allowed to shed the final block (58.1 Hz) of load shed, as long as the system recovers in a stable manner3. The final UFLS is designed with a back-up block of load shed at 57.7 Hz which is never intended to shed.

3.3 **PSSE Base Cases**

The PSSE base cases used in this study represent the year 2033-34.

Table 3-1 lists the initial set base cases provided by Hydro. Base Cases reflect long term (ten year) load forecast conditions in accordance with Hydro's annual assessment process. For the purposes of operational analysis, additional cases were developed with various IIS demand levels ranging from extreme light to peak, with varying LIL transfer levels and ML transfer levels. Generation dispatches were adjusted to reflect worst-case conditions in terms of transmission line power flows, reactive support, and total system inertia.

Table 3-1. Initial set of 2033-34 base cases

| Load Condition | Island Demand (MW) | On-Island Generation (MW) | LIL Power Transfer (at MFA) (MW) | ML Power Transfer (at BBK) (MW) |
|----------------|--------------------------|---------------------------------|----------------------------------------|------------------------------------|
| Peak | 2017 | 1579 | 739 | 250 |
| Light | 812 | 682 | 400 | 500 |
| Extreme Light | 447 | 406 | 305 | 250 |

⁴ Island Demand includes load and losses. Variations in Island Demand for the same loading condition are attributed to incremental losses associated with variations in dispatch.



³ The study found that in all cases where the system recovered in a stable manner, the system frequency was back up to 59.5 Hz after a maximum of 35 seconds.

4. LIL Limits

4.1 **LIL Bipole Limits**

Loss of the LIL bipole is the contingency that defines the requirements of the UFLS scheme for the IIS. The UFLS scheme ensures that the system frequency remains stable following the loss of the LIL bipole.

4.1.1 Interim UFLS Scheme

During the preliminary Stage 4 operational studies, an "Interim" UFLS scheme was designed by modifying the previously existing UFLS scheme under the base assumption that the ML was exporting 158 MW, with the aim of being able to transfer rated power of 900 MW on the LIL over peak⁵. This reflects the worst-case shortfall for Island system where imports are maximized, and exports are limited to firm commitment values ("Emera Block"). During other ML transfer levels between 320 MW import and 500 MW export with varying IIS demand levels, LIL transfer limits were determined with the modified Interim ULFS scheme in place.

This Interim UFLS scheme is currently in operation at the time of this report, and it includes a total of 755 MW (blocks from 58.8 Hz to 58.0 Hz) based on the 2023-34 peak demand of around 1800 MW. Hydro has been setting the LIL transfer limits such that all blocks would shed with the exception of the 58 Hz block, which would be a total load shed of approximately 590 MW during peak conditions (1800 MW).

The Interim UFLS scheme is summarized in Table 4-1.

Table 4-1. Interim UFLS scheme

| Frequency Blo | UFLS (MW)* | | |
|-------------------------------|------------------|-----|--|
| | 58.8 | 110 | |
| | 58.6 | 110 | |
| | 58.4 | 120 | |
| Main UFLS | 58.2 | 115 | |
| | 58.1 | 135 | |
| | 58.0 | 165 | |
| TOTAL | 755 ⁶ | | |
| *Assumes peak load of 1800 MW | | | |

⁶ This includes the NLH feeders, but not NLH industrial customers with motors set to trip on underfrequency.



⁵ These preliminary studies were based on the present day 2023-24 base cases at the time where peak demand was around 1825 MW.

At the time of the earlier Stage 4 operational studies, an original "Final" UFLS scheme was also designed, which included approximately 840 MW of UFLS (based on the 2023-24 peak demand of approximately 1800 MW). The idea was to allow higher LIL transfer by shedding more load if the LIL bipole tripped. However, this UFLS was designed under the assumption that the ML frequency controller, although not able to provide additional underfrequency support after running back to 0 MW, could still support the IIS frequency by providing overfrequency support if needed after the system recovered from the LIL bipole trip and UFLS. It was since determined that the ML frequency controller is entirely disabled after an ML runback, therefore, the ML frequency controller is unable to support any overfrequency that may occur as the system recovers. In the Stage 4F studies, it was determined that overfrequency can be a limiting issue, and a re-design (reduction) of the "Final" UFLS was required. The Stage 4F "Final" UFLS scheme and overfrequency issue are further discussed and demonstrated in Section 3.1.2 (Figure 4-1).



⁷ At the request of Nova Scotia Power.

4.1.2 Final UFLS Scheme

The Stage 4F study is based on the set of 2033-34 PSSE base cases, in which the peak demand is approximately 2000 MW. Initially, when starting the Stage 4F study, the Interim UFLS scheme was first tested to simulate loss of the LIL bipole using these base cases. Significant overfrequencies were observed on the IIS for some scenarios involving an ML runback after the LIL bipole tripped. This is because at a higher peak demand levels (2000 MW vs. 1800 MW) the same UFLS scheme will shed more total load. The 2033-34 peak case sheds a total of approximately 840 MW when applying the Interim UFLS scheme compared to 750 MW in the 2023-24 peak case. This is further explained as follows:

Overfrequency Issue

When the LIL bipole trips, there is an approximate delay of 250 ms from the time that the LIL bipole trips to the runback of ML export. During this delay, frequency is dropping. Subsequent to the 250ms delay, the ML runs back exports to 0 MW, which is an automated process following a LIL bipole trip. In some scenarios, depending on the amount of load that is shed plus the amount of power that is runback on the ML, more load/exports are removed than was lost from the LIL infeed. Therefore, when the system recovers from the underfrequency, a large overfrequency occurs because of the resulting power imbalance on the IIS. Since the ML frequency controller becomes inactive following an ML runback, it is not available to support the IIS to reduce this overfrequency. The overfrequency issue was more severe for the Stage 4F study compared to the other preliminary Stage 4 studies because of the higher peak demand in the 2033-34 cases. As higher IIS demand grows there is inherently more load that is shed by the UFLS scheme, and the more load that is shed, the higher the overfrequency. This resulted in violations of Transmission Planning criteria (i.e. frequency > 63 Hz).

An example of such overfrequency is shown in Figure 4-1.

This example is a 2033-34 peak case (~2000 MW demand) with ML exporting 250 MW and LIL transferring 900 MW (at MFA). When the LIL bipole trips, the frequency dips to 58.15 Hz resulting in a total of 839 MW of UFLS, along with the ML runback of 250 MW, adding up to a total of 1089 MW of effective load removed from the system. Since the LIL was operating at 900 MW, 832 MW (after LIL losses) of infeed is lost to the IIS, the system ends up in a state with approximately 250 MW of excess generation, resulting in a frequency greater than 64 Hz.




Figure 4-1. Example: Overfrequency > 64 Hz after IIS recovers from LIL bipole trip



Design of Final UFLS Scheme

To eliminate overfrequency violations under high demand scenarios, the total amount of load included in the Final UFLS scheme was reduced from the original Final UFLS scheme first introduced in the Stage 4E Study. In addition to reducing the total amount of UFLS, it was found beneficial to keep more of the load shed at higher frequency blocks, as the frequency drop can be halted slightly faster, which results in slightly less frequency dip overall. The reduction in UFLS scheme was accomplished by removing all blocks of load shed from the 58 Hz block, and some blocks from the 58.1 Hz block. Additionally, a new design concept was introduced to add a back-up block of load shed by shifting approximately 100 MW of the load block that belonged to the 58 Hz block in the Interim scheme and setting it to trip at 57.7 Hz in the Final UFLS scheme. The purpose of the back-up block is to protect the system in the rare event that the system does not respond as expected or if it turns into a cascading event, for example. The LIL limits determined in this study were not designed to utilize the back-up block.

The total load shed in the Final UFLS (based on the 2033-34 peak case) is approximately 750 MW (set to trip between 58.8 Hz and 58.1 Hz). The Final UFLS also has a back-up block of approximately 100 MW set to trip at 57.7 Hz. A minimum of 750 MW of UFLS is the amount required to allow the LIL to operate at 900 MW over 2033-34 peak (2000 MW) with ML exporting 150 MW, while leaving a 0.1 Hz margin to the 57.7 Hz back-up UFLS block.

Please note that it is recommended that UFLS blocks be re-adjusted as load grows to ensure that the blocks sizes remain the same (i.e. do not increase as peak demand grows beyond 2033-34) since the LIL limits are based on this amount of loadshed. If the blocks are not adjusted as load grows, the amount of UFLS will inherently grow and this has the potential to create additional overfrequency issues, that are discussed in upcoming Section 4.1.3.1 (page 12). It is recommended that Hydro and NF Power should monitor these blocks and review on an annual basis.

The Final UFLS scheme is summarized in Table 4-2 with the detailed scheme provided in Appendix 1.

Table 4-2. Final UFLS scheme

| Table 4 El Tillal el Es collelle | | | | |
|----------------------------------|----------------------|-----|--|--|
| Frequency Blo | Frequency Block (Hz) | | | |
| Main UFLS | 58.8 | 160 | | |
| | 58.6 | 170 | | |
| | 58.4 | 170 | | |
| | 58.2 | 168 | | |
| | 58.1 | 88 | | |
| | TOTAL | 756 | | |
| Back-up UFLS | 57.7 | 105 | | |
| *Assumes peak load of 2,000 MW | | | | |



4.1.3 Final LIL Limits

4.1.3.1 Loss of the LIL Bipole

LIL transfer limits were determined by simulating loss of the LIL bipole using the Final UFLS scheme and allowing the worst-case frequency dip to reach 57.8 Hz (leaving a 0.1 Hz margin to the 57.7 Hz back-up block), while ensuring a good recovery or "bounce back" of the frequency after UFLS and ML runback (if applicable). Overfrequency after the system recovered must also not be greater than 63 Hz.

Loss of the LIL bipole was tested for IIS system conditions ranging from extreme light to peak demand for the following scenarios:

- a) ML runbacks active⁸ ML exporting between 150 MW⁹ and 500 MW
- b) ML runbacks not active 10 ML operating at 0 MW
 - a. With ML frequency controller active¹¹
 - b. Without ML frequency controller active

Note: each scenario was assessed with and without LIL restarts enabled

The following observations were made from the analysis:

- 1. Loss of the LIL bipole results in the following impacts to the IIS:
 - a) Underfrequency following a LIL bipole trip and subsequent UFLS. LIL limits were set such that frequency did not dip lower than 57.8 Hz in a worst-case scenario, and such that the frequency recovered in a reasonable timeframe. The 900 MW LIL over peak scenario with ML exporting 150 MW is shown in Figure 4-2 as an example where the frequency dips to 57.8 Hz and then recovers.

¹¹ If ML imports are greater than 170 MW, the full 150 MW capacity of the ML frequency controller is not available due to the maximum 320 MW import limit.



⁸ ML exports levels that result in ML runback to 0 MW following a LIL bipole trip range from 150 MW to 500 MW. ML frequency controller status has no impact on LIL limits when ML is exporting at these levels because an ML runback automatically disables ML frequency controller action.

⁹ Hydro's SCADA system is setup to enable ML runbacks at 145 MW. There difference of 5 MW has no material impact on the analysis.

¹⁰ ML runbacks are not active when ML is importing or when ML is exporting less than 150 MW. The LIL limits when ML runbacks are not active were calculated using ML=0 MW as a base assumption but these limits are also applicable to scenarios when ML is importing.




Figure 4-2. Example 12 – Worst underfrequency after Loss of LIL Bipole - 2000 MW demand, LIL 900 MW, ML 150 MW

b) Overfrequency occurs after UFLS and the ML runback when the system is recovering. The severity of the overfrequency depends on island demand and ML transfer levels at the time of the LIL bipole trip. The overfrequency was not a concern for scenarios that do not involve ML runbacks. With the Final UFLS scheme applied, only one scenario was observed to have frequency slightly greater than 63 Hz. The worst case overfrequency of 63.2 Hz was observed in the 1750 MW demand scenario, with LIL at 900 MW and ML exporting 400 MW, as shown in Figure 4-3. Since the overfrequency violation (>63 Hz) only occurs at a specific demand and ML export scenario and is only slightly above 63 Hz, it was deemed acceptable.

¹² A slight violation of transient undervoltage occurs. Voltage should not dip below 0.7 pu and should not dip below 0.8 pu for more than 20 cycles. In this simulation, voltage at SSD was below 0.8pu for approximately 22-23 cycles.




Figure 4-3. Example – Worst overfrequency after recovering from loss of LIL bipole

c) Voltage collapse near the mid-point of the BDE-SOP 230 kV corridor (around Sunnyside (SSD)) during high IIS demand conditions. When the LIL infeed on the Avalon is lost, a large amount of power suddenly flows from the western part of the IIS over the 230 kV BDE-SOP corridor towards the Avalon load causing a transient voltage drop along this corridor. The voltage issues were also observed in the preliminary Stage 4 studies where it was mitigated by ensuring a minimum amount of Avalon thermal generation is in-service under specified high levels of IIS demand, which is the same approach taken in the Stage 4F study. The issue is discussed further in Section 7.1 of this report. Alternative mitigation options, such as the addition of reactive power support near SSD and a Remedial Action Scheme (RAS) are being investigated in future studies. The issue is demonstrated in Figure 4-4 by plotting the 230 kV voltage at SSD (following a LIL bipole trip) for varying levels of pre-contingency Avalon thermal generation.




Figure 4-4. Voltage response at SSD after LIL bipole trip – as Avalon generation is reduced *Blue*: Pre-contingency Avalon generation 3x47.2 MW - meets transient voltage criteria *Green*: Pre-contingency Avalon generation 2x47.2 MW – violates transient voltage criteria *Red*: Pre-contingency Avalon generation 2x30 MW – unstable

2. <u>Impact of LIL Restarts</u>: Enabling one restart on the LIL did not de-rate the LIL transfer limits. The main impact of enabling one restart is the additional delay time between the LIL bipole going to 0 MW from the



DC faults and the ML running back all exports. This scenario is simulating a very low probability event of having two DC pole faults at the same time and then neither pole is successful at reclosing and both poles trip. The timing for this event simulates a 560ms delay from LIL pole faults to ML runback, explained as follows:

The sequence for one restart attempt is demonstrated in Figure 4-5 by adding up the DC line fault detection time plus A and E.

Fault detection time of approximately 60 ms + 150 ms (force retard 1 "A") + 100 ms (deblock attempt "E") $= 310 \, ms.$

With one restart enabled, the pole(s) would then trip if the reclose attempt was not successful, and the additional delay of 250 ms to ML runback would occur. Therefore, the entire time delay from LIL bipole going to 0 MW (i.e. simultaneous DC fault on both poles) to ML runback is:

310 ms + 250 ms = 560 ms




Figure 4-5. Timing of LIL restart attempts

The impacts of enabling one restart on the LIL are as follows:

a) When LIL not operating at a transfer limit: The impact of enabling one restart was observed in the frequency response in scenarios where the LIL is not operating at a limit (e.g. where it can transfer 900 MW without resulting in all blocks of UFLS being shed in the "no restart" scenario). In these scenarios, additional UFLS occurs in the "one restart" scenario because of the additional delay to runback the ML exports, however, the LIL transfer limits were not impacted since both



frequency responses for "no restart" and "one restart attempt" were acceptable. An example is shown in Figure 4-6 where the green plots represent the "no restart" scenario and the blue plots represent the "one restart attempt" scenario.




Figure 4-6. Impact of Enabling One Restart Attempt – in scenarios where LIL can operate at 900 MW without shedding all blocks of UFLS in the "no restart" scenario

b) When LIL operating at a transfer limit: In cases where all UFLS blocks are shed in the "no restart" scenario, i.e. when LIL is operating at a transfer limit, there was minimal impact observed on the frequency response by adding the additional delay to runback the ML for the "one restart attempt" scenario. A typical example is demonstrated in Figure 4-7, where it is observed that the frequency response is nearly identical between the "one restart" (blue curve) and the "no restart" (green curve) scenarios. Therefore, there was no impact to LIL transfer limits.






Figure 4-7. Minimal Impact of One LIL restart – 1500 MW IIS demand, ML = 150 MW, LIL at limit of 780 MW

c) When ML runbacks are not active: In cases where ML runbacks are not active, there is no impact from enabling one restart attempt because there are no ML runbacks, therefore, the increased time delay to runback the ML is not applicable.

Although the analysis has shown no impact of restarts on LIL transfer limits, for extra pre-caution it is desirable to avoid additional delay between ML runbacks and loss of the LIL bipole when possible. Therefore, it could be recommended that, when LIL restarts are enabled, operating the LIL to its limit should be avoided, if possible, unless adverse weather conditions (wind/lightning) advise otherwise.

- 3. Loss of LIL bipole slower system response during low demand scenarios:
 - a) **Slower Recovery of Frequency**. It was observed in low demand cases that because there are fewer generators on-line, the frequency recovers much slower than higher demand cases and the system takes longer to get back to 60 Hz, sometimes up to 30 or 40 seconds¹³,

¹³ All frequency responses recovered to 59.5 Hz within 35 seconds. Time for frequency to recover after loss of the LIL bipole for each LIL transfer limit / demand scenario is provided in Table 4-3.

whereas the high demand cases can recover as quickly as 5 seconds. A typical example of slower frequency recovery for a 750 MW demand scenario is plotted in Figure 4-8. However, despite the slower frequency recovery, the system does recover.

If the 57.7 Hz back-up block were to be hit under this scenario, the frequency would recover quicker, however, more customer load would be shed. The LIL limits were not designed to use this block of UFLS.




Figure 4-8. Example of slower frequency recovery in low demand scenarios.

b) Minimum Island Generation¹⁴ becomes more restrictive than stability. For scenarios where IIS demand is below 700 MW, the minimum island generation becomes more restrictive than maintaining system stability following the loss of the LIL bipole. For example, at IIS demand of around 400 MW and ML exporting 150 MW, the maximum that the LIL can transfer is 240 MW, as this results in the extreme minimum allowable IIS generation of around 315 MW. Loss of the LIL bipole under this particular scenario results in a frequency dip to 58.6 Hz, which is not at a stability / UFLS limit.

In these low demand cases (<700 MW), the maximum LIL transfer due to minimum IIS generation can be calculated as:

4.1.3.2 Loss of a LIL Pole (when operating as a Bipole)

The Transmission Planning Criteria for loss of a LIL pole are specified such that this event should not result in UFLS, therefore, it should not cause the IIS frequency to drop below 59.1 Hz (leaving some margin to the 58.8 Hz UFLS block).

The LIL is designed with a 10-minute 2 pu overload rating. If one of the LIL poles is lost, the remaining pole is rated to transmit 2 pu at the sending end for 10 minutes, after which the continuous monopole rating drops down to 1.5 pu. The purpose of the 10-minute 2.0 pu overload rating is to allow operators time to quickly dispatch other resources to make up for the loss of infeed from the LIL pole that was lost.

¹⁴ Minimum Island Generation is defined in Section 2.1. At lower demand scenarios, the IIS can only accept a certain amount of LIL infeed, otherwise the IIS generation must be dispatch below the Minimum Island Generation.



When the LIL is operating in 2.0 pu overload, however, losses on the LIL are higher, therefore, the infeed at SOP becomes less than it was prior to the loss of the pole. To account for this and keep frequency above 59.1 Hz:

- In scenarios where ML runbacks are active, a small pre-calculated ML runback takes place to cover the loss of infeed at SOP in scenarios where ML runbacks are active.
- In scenarios where ML runbacks are not active, the small ML runback mentioned above cannot be used to cover the loss of infeed due to increased losses. In this case, the ML frequency controller will cover the loss of infeed. However, if the ML frequency controller is also not active, the study determined that at high demand loss of a LIL pole is more limiting than loss of the LIL bipole, and requires a small reduction in LIL transfer limit at or near peak demand if the ML frequency controller is not active in order to ensure the IIS frequency does not dip below 59.1 Hz. This is noted in upcoming Table 4-4.

4.1.3.3 Final LIL Transfer Limits

Final LIL transfer limits with the re-designed Final UFLS scheme are provided in the following tables. Plots for simulations of loss of LIL bipole at these transfer limits are provided in Appendix 2.

- Table 4-3 ML runbacks active with and without one LIL restart enabled
- Table 4-4 ML runbacks not active¹⁵ with and without ML Frequency Controller active
- Table 4-5 Minimum IIS demand required for LIL to operate at 900 MW

¹⁵ When ML runbacks are not active, there is no impact from enabling LIL restart attempts because there are no ML runbacks, therefore, the increased time delay to runback the ML is not applicable and therefore LIL limits are not impacted.

Table 4-3. LIL Limits - ML Runbacks Active - No restarts & One restart scenarios

| ШLLin | nits - Fina | al Stage 4F Study | , | | FINALUFLS (N | - 750 MW o Restarts | | oack-up | Time to | recover ec) | _ | | IW+100 M\ tart Enabled | | Time to rec | cover (sec) |
|-----------------------|---------------------------|-------------------------|---------------------------------|------------|----------------------------|--------------------------|--------------------------|----------------------|---------------------|-------------------|---------------------------|--------------------------|---------------------------|-------------------|---------------------|-------------------|
| IIS Demand (MW) | IIS Generation (MW) | Avalon generation | Gross Avalon load (MW) | ML (MW) | LIL Transfer Limit (MW) | Min Frequency (Hz) | Max Frequency (Hz) | Load Shed (MW) | to 59.5 Hz (sec) | to 60 Hz (sec) | LILTransfer Limit (MW) | Min Frequency (Hz) | Max Frequency (Hz) | Load shed (MW) | to 59.5 Hz (sec) | to 60 Hz (sec) |
| 2056 | 1729 | 3x47.2MW* +170MW** | 1090 | 500 | 900 | 58.49 | 60.43 | 333 | 8.9 | 12.9 | 900 | 58.32 | 61.85 | 457 | 4.6 | 5.5 |
| 2034 | 1607 | 3 x 47.2 MW* + 100 MW** | 1088 | 400 | 900 | 58.29 | 61.33 | 496 | 6.6 | 8.4 | 900 | 58.22 | 61.18 | 496 | 6.6 | 8.4 |
| 2020 | 1493 | 3x47.2 MW* | 1086 | 300 | 900 | 58.10 | 62.20 | 663 | 5.6 | 6.6 | 900 | 58.07 | 63.02 | 738 | 4.5 | 5.2 |
| 2016 | 1439 | 3x47.2MW* | 1086 | 250 | 900 | 58.00 | 62.70 | 751 | 5.1 | 5.9 | 900 | 57.98 | 62.48 | 737 | 5.1 | 5.9 |
| 2012 | 1334 | 3x47.2MW* | 1086 | 150 | 900 | 57.80 | 61.50 | 752 | 7.7 | 9.4 | 900 | 57.83 | 61.35 | 752 | 7.7 | 9.4 |
| 1938 | 1611 | 3x47.2MW* +70MW** | 1025 | 500 | 900 | 58.44 | 60.29 | 326 | 10.5 | 15.1 | 900 | 58.29 | 62.40 | 459 | 4.6 | 5.6 |
| 1919 | 1492 | 3x47.2MW** | 1023 | 400 | 900 | 58.16 | 62.40 | 564 | 5.4 | 6.3 | 900 | 58.14 | 62.37 | 564 | 5 | 6 |
| 1907 | 1380 | 2x47.2MW* | 1022 | 300 | 900 | 58.03 | 62.84 | 702 | 5 | 5.8 | 900 | 58.01 | 62.63 | 690 | 5 | 5.8 |
| 1904 | 1413 | 2x47.2MW* | 1022 | 250 | 900 | 57.92 | 62.36 | 702 | 5.7 | 6.7 | 900 | 57.92 | 62.30 | 702 | 5.6 | 6.7 |
| 1901 | 1223 | 2x30 MW* | 1022 | 150 | 875 | 57.75 | 60.94 | 702 | 8.3 | 10.4 | 875 | 57.82 | 60.92 | 702 | 8.3 | 10.4 |
| 1785 | 1428 | 2x47.2MW** | 940 | 500 | 900 | 58.31 | 61.80 | 422 | 5.8 | 7.1 | 900 | 58.24 | 61.76 | 422 | 5.6 | 6.8 |
| 1768 | 1341 | 1x47.2MW* | 938 | 400 | 900 | 58.09 | 63.19 | 627 | 4.6 | 5.3 | 900 | 58.10 | 62.91 | 599 | 4.6 | 5.4 |
| 1761 | 1234 | 1x30 MW* | 938 | 300 | 900 900 | 57.96 | 62.21 61.17 | 639 638 | 5.8 | 6.9 | 900 900 | 57.99 | 62.14 61.11 | 639 | 5.5 7 | 6.7 |
| 1759 1750 | 1181 1073 | 1x20MW* 0 | 938 938 | 250 150 | 900 850 | 57.88 57.79 | 60.34 | 638 | 7.2 10.9 | 8.7 15 | 900 850 | 57.94 57.84 | 60.30 | 638 722 | 10.9 | 8.7 15 |
| 1535 | 1207 | 0 | 801 | 500 | 900 | 58.36 | 60.95 | 356 | 7.4 | 9.5 | 900 | 58.22 | 60.96 | 364 | 7 | 9.1 |
| 1524 | 1096 | 0 | 801 | 400 | 900 | 58.36 58.16 | 61.08 | 300 464 | 7.4 | 9.5 | 900 | 58.22 58.07 | 62.28 | 364 464 | 5.1 | 6.2 |
| 1513 | 985 | 0 | 801 | 300 | 900 | 57.99 | 60.57 | 538 | 9.5 | 13.2 | 900 | 57.97 | 60.50 | 538 | 9.2 | 12.3 |
| 1513 | 934 | 0 | 801 | 250 | 875 | 58.00 | 60.20 | 538 | 10.8 | 15.6 | 875 | 57.98 | 60.14 | 538 | 11.2 | 16.6 |
| 1502 | 825 | 0 | 801 | 150 | 780 | 57.94 | | 538 | 13.5 | 20 | 780 | 57.95 | 00.14 | 538 | 13.5 | 20 |
| 1296 | 969 | 0 | 659 | 500 | 900 | 58.34 | 60.12 | 287 | 11.1 | 16.7 | 900 | 58.15 | 60.94 | 350 | 6.3 | 8.2 |
| 1280 | 853 | 0 | 659 | 400 | 900 | 58.16 | - 00.12 | 385 | 13.4 | 20.3 | 900 | 58.05 | 60.62 | 428 | 7.9 | 10.7 |
| 1261 | 734 | 0 | 659 | 300 | 870 | 58.00 | _ | 435 | 17 | 27 | 870 | 57.98 | - | 435 | 17 | 21 |
| 1253 | 744 | 0 | 657 | 250 | 800 | 57.99 | _ | 435 | 17.5 | 28 | 800 | 57.98 | - | 435 | 17.5 | 28 |
| 1248 | 613 | 0 | 658 | 150 | 680 | 57.96 | - | 435 | 17.7 | 30 | 680 | 57.98 | - | 435 | 17.7 | 30 |
| 1067 | 740 | 0 | 526 | 500 | 900 | 58.29 | - | 220 | 21.5 | 37 | 900 | 58.14 | - | 267 | 11.2 | 18.1 |
| 1046 | 619 | 0 | 526 | 400 | 900 | 58.05 | _ | 333 | 20 | 24.6 | 900 | 58.00 | - | 333 | 21.6 | 37.5 |
| 1023 | 609 | 0 | 521 | 300 | 785 | 57.97 | - | 332 | 26.9 | 37 | 785 | 57.95 | - | 333 | 20.9 | >40 |
| 1015 | 598 | 0 | 520 | 250 | 720 | 57.99 | - | 332 | 23.9 | 29.1 | 720 | 57.98 | - | 332 | 28.3 | >40 |
| 1003 | 598 | 0 | 518 | 150 | 590 | 57.97 | - | 332 | 19.1 | 23.9 | 590 | 57.98 | - | 332 | 22.1 | >40 |
| 811 | 483 | 0 | 383 | 500 | 900 | 58.06 | - | 223 | 18 | 32 | 900 | 57.88 | - | 223 | 18 | 23 |
| 781 | 476 | 0 | 377 | 400 | 800 | 57.99 | - | 222 | 17.7 | 20.9 | 800 | 57.93 | - | 223 | 21.8 | 27.4 |
| 760 | 461 | 0 | 373 | 300 | 660 | 57.99 | - | 223 | 27.3 | >40 | 660 | 57.96 | - | 223 | 27.3 | 36.3 |
| 752 | 457 | 0 | 371 | 250 | 600 | 58.02 | - | 222 | 20 | 28.3 | 600 | 57.99 | - | 222 | 28.2 | >40 |
| 741 | 447 | 0 | 369 | 150 | 480 | 58.02 | - | 222 | 19.2 | 22.7 | 480 | 58.01 | - | 222 | 28.2 | >40 |
| 742 | 415 | 0 | 329 | 500 | 900 | 58.05 | - | 183 | 31.9 | >40 | 900 | 58.00 | - | 183 | 24.1 | 30 |
| 714 | 417 | 0 | 322 | 400 | 750 | 58.05 | - | 183 | 21.5 | 30.3 | 750 | 58.03 | - | 192 | 27.9 | 34.4 |
| 712 | 417 | 0 | 336 | 300 | 635 | 58.01 | - | 196 | 33.4 | >40 | 635 | 57.97 | - | 201 | 24.1 | 33 |
| 713 | 418 | 0 | 331 | 250 | 570 | 58.02 | - | 193 | 29.9 | 34.4 | 570 | 57.99 | - | 202 | 31.2 | 37.1 |
| 704 | 418 | 0 | 329 | 150 | 460 | 57.98 | - | 194 | 34.4 | >40 | 460 | 57.94 | - | 206 | 34.4 | >40 |
| 468 | 324 | 0 | 182 | 500 | 690 | 58.59 | - | 34 | 28.2 | >40 | 690 | 58.35 | - | 51 | 20 | 40 |
| 435 | 317 | 0 | 175 | 400 | 550 | 58.59 | - | 34 | 29.9 | >40 | 550 | 58.55 | - | 34 | 26.4 | 28.4 |
| 412 | 323 | 0 | 170 | 300 | 410 | 58.60 | - | 34 | 24.4 | >40 | 410 | 58.60 | - | 34 | 24.4 | >40 |
| 404 | 321 | 0 | 169 | 250 | 350 | 58.59 | - | 34 | 25 | >40 | 350 | 58.59 | - | 34 | 21.8 | 26.7 |
| 394 | 315 415 MW min | 0 | 167 | 150 | 240 | 58.60 | - | 34 | 25.8 | 30 | 240 | 58.60 | - | 34 | 24.5 | 33.1 |

ULlimit at 415 MW min generation
330 MW extreme min gen - max UL (not at a transfer limit)

*to meet transient UV criteria at SSD

**to meet ML export



Table 4-4. LIL Limits - ML Runbacks Not Active

| ULI | Bipole Limi | ts(MLRunl | backs Not | Active) - I | VILF/CAC | tive (150 N | VIVV) |
|----------------|-------------------|-----------------|----------------|--------------------------|------------------|-------------------|--------------------------------------------|
| Demand (MW) | LIL (MW) @ MFA | LIL(MW)@ SOP | Net DC (MW) | Min Frequency (Hz) | Max Freq (Hz) | Load Shed (MW) | Loss of Pole - Min Frequency (Hz) |
| 2012 | 900 | 834 | 834 | 57.85 | - | 757 | 59.02* |
| 1889 | 875 | 813 | 813 | 57.83 | - | 702 | 59.11 |
| 1738 | 850 | 791 | 791 | 57.85 | - | 637 | 59.21 |
| 1492 | 780 | 730 | 730 | 57.93 | - | 541 | 59.36 |
| 1235 | 680 | 642 | 642 | 57.97 | - | 435 | 59.42 |
| 995 | 580 | 552 | 552 | 57.98 | - | 332 | 59.48 |
| 741 | 470 | 452 | 452 | 58.05 | - | 222 | 59.58 |
| 594 | 410 | 396 | 396 | 58.05 | - | 159 | 59.62 |
| 463 | 350 | 340 | 340 | 58.05 | - | 96 | 59.67 |
| 400 | 320 | 311 | 311 | 58.02 | - | 76 | 59.67 |

^{*}Aslight reduction in LIL transfer limit would be needed to keep frequency ≥59.1 Hz, however 59.02 Hz is still above the 58.8 Hz UFLS block

| | ШLВір | ole Limits | (MLRunba | acks Not A | Active) - N | LF/C Not | Active | |
|----------------|-------------------|-----------------|----------------|--------------------------|------------------|-------------------|--------------------------------------------|----------------------------------------------------------------------|
| Demand (MW) | LIL (MW) @ MFA | LIL(MW)@ SOP | Net DC (MW) | Min Frequency (Hz) | Max Freq (Hz) | Load Shed (MW) | Loss of Pole - Min Frequency (Hz) | Reduced LIL Transfer for Loss of LIL Pole (MW) (59.1 Hz) |
| 2018 | 780 | 730 | 730 | 57.80 | 60.75 | 757 | 58.77 | 720 |
| 1898 | 715 | 673 | 673 | 57.80 | 60.82 | 702 | 58.95 | 705 |
| 1747 | 690 | 644 | 644 | 57.80 | - | 637 | 59.23 | - |
| 1497 | 620 | 588 | 588 | 57.90 | - | 541 | 59.38 | - |
| 1238 | 520 | 498 | 498 | 57.94 | - | 435 | 59.51 | - |
| 996 | 420 | 398 | 398 | 57.97 | - | 332 | 59.61 | - |
| 735 | 310 | 302 | 302 | 58.04 | - | 222 | 59.69 | - |
| 586 | 245 | 240 | 240 | 58.02 | - | 159 | 59.78 | - |
| 438 | 180 | 177 | 177 | 58.05 | - | 96 | 59.92 | - |
| 390 | 160 | 150 | 150 | 57.97 | - | 76 | 59.94 | - |

Table 4-5. Minimum IIS Demand to Operate LIL at 900 MW

| | Minimum I | sland Dema | and for ∐L | 900 MW | |
|----------------|---------------------------|--------------------------|------------|--------------------------|-------------------|
| Demand (MW) | IIS Generation (MW) | ⊔LTransfer Limit (MW) | ML(MW) | Min Frequency (Hz) | Load Shed (MW) |
| 742 | 415 | 900 | 500 | 58.05 | 183 |
| 1005 | 577 | 900 | 400 | 57.99 | 314 |
| 1308 | 781 | 900 | 300 | 57.93 | 454 |
| 1551 | 974 | 900 | 250 | 57.97 | 557 |
| 2012 | 1334 | 900 | 150 | 57.8 | 752 |

*at min gen



4.1.4 UFLS: 57.7 Hz Back-up Block

The final UFLS scheme was designed with a 57.7 Hz back-up block of approximately 100 MW over peak. The final LIL transfer limits provided in Section 4.1.3 provide at least 0.1 Hz margin to the 57.7 Hz backup block of UFLS.

The purpose of the back-up block is to provide an additional layer of protection to maintain IIS stability above and beyond the LIL transfer limits. Therefore, the following are recommendations for further protection to minimize the risk of instability after a LIL bipole trip:

- Hydro should set all under-frequency protection for their generation assets as low as possible, preferably less than 57.5 Hz, to ensure no additional loss of supply.
- Hydro should further investigate if setting the ML under-frequency protection to 57.7 Hz as a back-up is a feasible option in the event a ML runback is not triggered.

To test the back-up block's ability to maintain stability and to see how far the system can be pushed beyond the LIL transfer limit (i.e. to see how much additional power can be lost while maintaining system stability), additional simulations were performed as follows:

- Trip a generator along with the LIL bipole (LIL operating at its transfer limit) to see how much additional power can be lost.
- Trip the LIL bipole when it is operating beyond the transfer limit to see how much additional power can be lost.

The amount of power being supplied by the generator that was tripped or the amount of power on the LIL above the transfer limit was recorded when it caused the 57.7 Hz back-up block to trip. In all cases, system stability was maintained at these higher power loss scenarios when the 57.7 Hz back-up block tripped.

Table 4-6 summarizes the additional loss of power (beyond the LIL transfer limit) that the system can withstand while maintaining system stability if the 57.7 Hz back-up block is in place and avoiding overfrequency during system recovery.

Table 4-6. Approximate additional MW loss the system can handle with the 57.7 Hz UFLS block

| IIS Demand (MW) | Additional MW beyond LIL Limit* | Amount of load shed by 57.7 Hz back-up block (MW) |
|--------------------|------------------------------------|---------------------------------------------------------|
| 2000 | 100 | 98 |
| 1900 | 100 | 92 |
| 1750 | 100 | 79-84 |
| 1500 | 75-100 | 71 |
| 1250 | 75-100 | 57-58 |



| 1000 | 40-75 | 44-45 |
|------|-------|-------|
| 800 | 20-40 | 29-30 |
| 700 | <35 | 23-26 |

^{*}exact amounts depend on ML exports, please refer to Table 4-7

Full results for the testing of the back-up UFLS are provided in Table 4-7. The table is explained as follows:

- The blue shaded portion represents the normal LIL limits (from Section 4.1.3) that do not invoke the 57.7 Hz back up UFLS block.
- The orange shaded portion represents the tripping of a generator along with the LIL bipole operating at the LIL transfer limit.
- The yellow shaded portion represents the tripping of the LIL bipole when operating the LIL beyond the LIL transfer limit.
- Purple shaded cells show scenarios when the 57.7 Hz back-up block operated and how much additional load was shed by the back-up block.



| Part Common Com | | ML(MW) 500 500 500 250 750 760 760 760 760 760 760 760 760 760 76 | (No Rest UL Transfer Limit (MW) 900 900 900 | arts Eng | abled) | • | | | | | | | | | | | | | | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|-------------------------------------------------------------------|---------------------------------------------|-------------|--------------------------|--------------------------|----------------------|------|------------------------------------------------------|------------------------------|------------------------------|-----------------------------|--------------|----------------|---------|---------------------------------------------------------------------------|--------------|--------------|------------------------|---------------------------------------------------------------|
| Marie Mari | | | | | | | | | | Tripp | ingAddi | tional G | enerato | * | | | Addition | nal MM | on the | ULbeyond limit |
| Seed Grid | | 500 400 300 250 500 400 300 250 150 | 0 0 0 | | Min Frequency (Hz) | Max Frequency (Hz) | Max quency Hz) | | +Gentrip (in addition to LL bipole) (MM) | + Gentrip Minfreq (Hz) | +Gentrip Max freq (Hz) | Total Load shed (MMV) | | | | +additional LIL MW beyond limit to just hit back-up UFLS (MW) | | | Backup UFLS (MW) | +additional LL MW beyond limit to just maint an stability* |
| 28.20 60.64 61.23 64.53 64.53 64.53 64.53 64.53 64.54 64.53 64.53 64.54 64.53 64.53 64.54 64.53 64.53 64.54 64.53 64.53 64.54 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 64.53 <th< td=""><td></td><td>400 300 250 150 400 300 250 150</td><td>8 8</td><td>832</td><td>58.49</td><td>60.43</td><td>60.43</td><td>333</td><td>100</td><td>28.30</td><td>61.19</td><td>497</td><td></td><td>332</td><td>266</td><td></td><td></td><td></td><td></td><td></td></th<> | | 400 300 250 150 400 300 250 150 | 8 8 | 832 | 58.49 | 60.43 | 60.43 | 333 | 100 | 28.30 | 61.19 | 497 | | 332 | 266 | | | | | |
| Section Control Cont | | 300 250 250 500 400 300 250 500 500 | 000 | 832 | 58.29 | 60.64 | 61.33 | 496 | 100 | 58.12 | 62.31 | 643 | | 335 | 1043 | | | | | |
| 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, | | 250 150 500 400 300 250 150 | | 832 | 58.10 | 60.81 | 6220 | 963 | 9 | 57.95 | 62.27 | 72 | | 335 | 1021 | | | | | |
| 5.8.4 (1) 6.04 (1) 7.2 (1) 6.04 (1) 7.2 (1) 6.04 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) 7.2 (1) | | 500 400 300 250 150 500 | 88 | 88 88 | 28.00 | 8.94 | 6270 | 751 | 9 9 | 27.82 | 61.47 | 75 | 8 | 88 88 | 1001 | | | | | |
| 8 844 | | 250 250 500 500 | 006 | 835 | 57.80 | 50.04 | 61.50 | 727 | 001 | 57.67 | 61.73 | 0 8 8 | 25 25 | 335 | 000 | | | | | |
| 8 8 8 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 | | 300 250 150 500 | 8 8 | 3 8 | 4 5 | 50 27 27 28 | 60.29 | 320 | 90,6 | 85.58 | 70.09 | \$ 8 | | 3 8 | 4 6 | | | | | |
| 57.70 60.31 72.2 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 60.70 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 77.8 <td></td> <td>250 250 500</td> <td></td> <td>3 8</td> <td>00.00</td> <td>3.8</td> <td>0240</td> <td>\$ 8</td> <td>8 6</td> <td>8.6</td> <td>02.94</td> <td>28 68</td> <td></td> <td>3 8</td> <td>200</td> <td></td> <td></td> <td></td> <td></td> <td></td> | | 250 250 500 | | 3 8 | 00.00 | 3.8 | 0240 | \$ 8 | 8 6 | 8.6 | 02.94 | 28 68 | | 3 8 | 200 | | | | | |
| 97.76 60.00 67.47 61.07 74.4 62.0 63.2 64.0 64.0 74.4 62.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 65.0 | | 150 | | 3 8 | 20.03 | 90.9 | 92.09 | 707 | 8 6 | 27.08 | 40.10 | 20 6 | | 3 8 | 7007 | | | | | |
| Section Color Co | \perp | 200 | 8 % | 8 8 23 K | 57.75 | 9.00 | 60 94 | 20.2 | 8 5 | 57.73 | 61.02 | 70 70 | 8 | 928 | 202 | | | | | |
| 53.75 60.74 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 60.75 70.75 60.75 70.75 60.75 70.75 60.75 70.75 60.75 70.75 80.75 70.75 80.75 70.75 80.75 <th< td=""><td></td><td>3</td><td>050</td><td>200</td><td>50.04</td><td>8.00</td><td>64.00</td><td>5</td><td>100</td><td>00.00</td><td>61.00</td><td>501</td><td>1</td><td>200</td><td>900</td><td></td><td></td><td></td><td></td><td></td></th<> | | 3 | 050 | 200 | 50.04 | 8.00 | 64.00 | 5 | 100 | 00.00 | 61.00 | 501 | 1 | 200 | 900 | | | | | |
| 57.56 60.77 60.27 60.80 70.00 57.00 60.83 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.93 60.9 | | 007 | 8 8 | 3 8 | 200.01 | 8 6 | 01.00 | 424 | 3 5 | 38.20 58.05 | 20.102 | 38 | | 32 25 | 000 | | | | | |
| 5778 60.54 61.17 628 60.15 777 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 77 | 1 | 200 | 3 6 | 3 8 | 57.96 | 6 6 | 62.21 | 639 | 6 | 27.83 | 6063 | 88 | | 330 | 030 | | | | | |
| 1, 12, 12, 13, 13, 13, 14, 14, 14, 15, 14, 14, 15, 14, 14, 15, 14, 14, 14, 14, 14, 14, 14, 14, 14, 14 | | 520 | 8 | 83 | 57.88 | 60.64 | 61.17 | 638 | 100 | 57.69 | 61.13 | 717 | 6/ | 33 | 296 | These cases | were only te | sted as los | sofULbip | oleat transfer limit + loss of additional |
| 83.8 60.58 36.6 60.0 50.16 60.34 440 62.2 940 Reservation in manuscrate in man | | 150 | 098 | 797 | 57.79 | 60.34 | 60.34 | 638 | 9 | 27.62 | 60.25 | 222 | 8 | 891 | 872 | | | | generato | 10 |
| SSS (1) FASA (1) (1) CASA (1) (1) CASA (1) (1) CASA (1) <td>L</td> <td>200</td> <td>006</td> <td>832</td> <td>58.36</td> <td>60.39</td> <td>60.95</td> <td>326</td> <td>100</td> <td>58.16</td> <td>60.94</td> <td>440</td> <td></td> <td>335</td> <td>940</td> <td></td> <td></td> <td></td> <td></td> <td></td> | L | 200 | 006 | 832 | 58.36 | 60.39 | 60.95 | 326 | 100 | 58.16 | 60.94 | 440 | | 335 | 940 | | | | | |
| 2 50.00 60.00 77.0 60.00 77.0 60.00 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 88.9 77.0 88.9 88.9 77.0 88.9 88.9 77.0 88.9 88.9 77.0 88.9 88.9 77.0 88.9 88.9 77.0 88.9 88.9 77.0 88.9 88.9 77.0 88.9 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 77.0 88.9 <t< td=""><td></td><td>400</td><td>006</td><td>832</td><td>58.16</td><td>60.64</td><td>61.08</td><td>464</td><td>100</td><td>27.98</td><td>98.09</td><td>540</td><td></td><td>335</td><td>940</td><td></td><td></td><td></td><td></td><td></td></t<> | | 400 | 006 | 832 | 58.16 | 60.64 | 61.08 | 464 | 100 | 27.98 | 98.09 | 540 | | 335 | 940 | | | | | |
| 3 5 7 7 6 0.03 71 888 889 7 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 889 <t< td=""><td></td><td>300</td><td>006</td><td>832</td><td>66.79</td><td>60.53</td><td>60.57</td><td>238</td><td>100</td><td>57.65</td><td>00:09</td><td>609</td><td>7</td><td>335</td><td>606</td><td></td><td></td><td></td><td></td><td></td></t<> | | 300 | 006 | 832 | 66.79 | 60.53 | 60.57 | 238 | 100 | 57.65 | 00:09 | 609 | 7 | 335 | 606 | | | | | |
| 57.94 | | 220 | 875 | 813 | 28.00 | 60.20 | 60.20 | 238 | 75 | 27.68 | 90.35 | 60 60 | 7 | 88 | 826 | | | | | |
| 84.06 | | 150 | 08/2 | 730 | 57.94 | - 0 | - 00 | 538 | 75 | 57.66 | - 00 | 600 | 74 | 802 | 759 | | | | | |
| 58.00 - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - <td></td> <td>200</td> <td>3 8</td> <td>3 8</td> <td>20.00</td> <td>50. IZ</td> <td>50.TZ</td> <td>787</td> <td>3 4</td> <td>= 8 2 8</td> <td>80.18</td> <td>8 8</td> <td></td> <td>3 68</td> <td>000</td> <td></td> <td></td> <td></td> <td></td> <td></td> | | 200 | 3 8 | 3 8 | 20.00 | 50. IZ | 50.TZ | 787 | 3 4 | = 8 2 8 | 80.18 | 8 8 | | 3 68 | 000 | | | | | |
| 5 57.59 - 435 75 57.64 - 482 57 747 642 57 743 445 57.64 - 482 57 747 642 57 747 642 57 747 642 57 747 642 57 747 642 57 744 822 777 642 45 774 642 777 642 777 642 777 642 777 642 777 642 777 642 777 642 777 642 777 642 777 642 777 642 777 642 777 642 777 45 777 45 777 45 777 45 777 45 777 45 777 45 777 45 777 45 777 45 777 45 777 45 777 478 477 477 478 477 477 477 | | 300 | 028 | 9 8 | 2800 | | | 435 | 22 | 27.55 | | 493 | 229 | 8 8 | 283 | | | | | |
| 2 57.56 - 435 75 57.63 - 482 57 717 642 57.68 - 482 57 714 642 57.68 - 482 57.78 45 784 784 784 784 784 784 784 784 784 784 785 77.78 45 785 77.78 45 785 77.78 45 785 77.78 45 45 786 77.78 45 786 77.78 45 786 77.78 45 786 77.78 45 786 77.78 45 786 77.78 45 786 77.78 45 786 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 | + | 250 | 8 8 | 748 | 57.99 | | | 435 | 2 52 | 57.64 | | 493 | 8 88 | 828 | 743 | | | | | |
| 58.20 - 220 75 38.11 - 234 44 892 777 44 862 777 45 778 45 778 45 778 45 778 45 778 47 45 778 677 45 778 45 778 45 778 45 778 45 778 45 778 47 45 778 677 45 778 677 45 778 677 45 778 677 45 778 677 45 778 677 45 778 677 45 778 677 45 778 677 45 778 677 45 778 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 47 <th< td=""><td></td><td>150</td><td>080</td><td>642</td><td>96.79</td><td></td><td></td><td>435</td><td>75</td><td>57.63</td><td></td><td>492</td><td>22</td><td>717</td><td>642</td><td></td><td></td><td></td><td></td><td></td></th<> | | 150 | 080 | 642 | 96.79 | | | 435 | 75 | 57.63 | | 492 | 22 | 717 | 642 | | | | | |
| 5 58.05 - - 333 60 57.67 - 377 44 892 777 45 778 677 45 778 677 45 778 677 45 778 677 40 778 676 45 778 677 40 778 676 45 778 677 40 778 676 45 778 677 40 778 676 45 778 677 40 778 676 45 778 678 778 678 778 678 778 678 778 678 778 678 778 678 778 678 778 678 778 778 678 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 778 77 | | 200 | 006 | 832 | 58.29 | | | 220 | 75 | 58.11 | | 284 | | 206 | 794 | | | | | |
| 5 57.97 - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - </td <td></td> <td>90</td> <td>08</td> <td>832</td> <td>58.05</td> <td></td> <td></td> <td>333</td> <td>8</td> <td>27.67</td> <td></td> <td>377</td> <td>4 :</td> <td>865</td> <td>111</td> <td></td> <td>1</td> <td>1</td> <td></td> <td></td> | | 90 | 08 | 832 | 58.05 | | | 333 | 8 | 27.67 | | 377 | 4 : | 865 | 111 | | 1 | 1 | | |
| 5.57.99 - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - - </td <td>_</td> <td>900</td> <td>£ 6</td> <td>ક ફ</td> <td>57.97</td> <td></td> <td></td> <td>332</td> <td>2 (</td> <td>2,69</td> <td></td> <td>3//</td> <td>ֆ ք</td> <td>8 8</td> <td>1/9</td> <td>S &</td> <td>8 8</td> <td>5/.69</td> <td></td> <td>/5 MW - 57.64 Hz, stable but slow recove</td> | _ | 900 | £ 6 | ક ફ | 57.97 | | | 332 | 2 (| 2,69 | | 3// | ֆ ք | 8 8 | 1/9 | S & | 8 8 | 5/.69 | | /5 MW - 57.64 Hz, stable but slow recove |
| 8.67.99 - 252.2 50.0 57.68 - 252.2 30.0 778.9 669.2 752.2 778.9 778.9 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 778.0 </td <td></td> <td>150</td> <td>2 6</td> <td>25.00</td> <td>57.97</td> <td></td> <td>. </td> <td>333</td> <td>8 6</td> <td>8 6</td> <td></td> <td>376</td> <td>3 4</td> <td>611</td> <td>526</td> <td>} 4</td> <td>£ £</td> <td>69 14</td> <td></td> <td>SOMW-97.33 PZ, stable but slow recow</td> | | 150 | 2 6 | 25.00 | 57.97 | | . | 333 | 8 6 | 8 6 | | 376 | 3 4 | 611 | 526 | } 4 | £ £ | 69 14 | | SOMW-97.33 PZ, stable but slow recow |
| 5 (7.99) | _ | 200 | 006 | 832 | 58.06 | | | 223 | 20 | 27.66 | | 252 | 29 | 882 | 752 | ! | | | | |
| 4 57.99 - 223 35 57.69 - 229 659 552 20 644 57.69 30 58.02 - - 222 35 57.69 - 251 29 665 501 20 644 57.69 30 28.02 - - 27.69 - 271 20 665 501 20 481 57.69 30 58.05 - - 183 35 57.69 - 22 759 606 57.71 30 58.01 - 183 35 57.69 - 22 56 652 522 469 77.71 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 10 | H | 400 | 800 | 748 | 66.79 | | | 222 | 20 | 57.69 | | 252 | 8 | 738 | 662 | 35 | 783 | 27.69 | Г | 40 MW - 57.65 Hz, stable but slow recove |
| 580.2 - 222 35 5769 - 251 29 665 501 580.2 - - 222 35 5769 - 251 29 665 401 580.5 - - 183 35 5769 - 207 24 667 401 580.6 - - 183 35 5769 - 206 23 739 606 580.1 - 196 30 5767 - 222 26 57 469 580.2 - 194 30 5767 - 220 26 477 499 585.9 - 194 30 5768 - 220 26 477 370 586.0 - 34 30 5768 - 220 26 477 370 586.0 - 34 30 5768 - 220 26 472 370 586.0 - 34 34 36 36 36 37 370 37 588.0 - - 34 34 36 37 37 37 37 | | 300 | 099 | 624 | 57.99 | | | 223 | 35 | 57.69 | | 222 | 83 | 629 | 292 | 20 | \$ | 57.69 | | 40 MW - 57.67 Hz, stable but slow recove |
| 1 58.02 - - 222 35 57.69 - 271 224 456 401 2 58.05 - - 183 35 57.66 - 237 224 667 707 2 58.01 - 183 35 57.69 - 222 26 622 52 3 58.02 - 194 30 57.67 - 229 26 57 469 5 58.59 - 194 30 57.68 - 220 26 472 370 5 58.59 - 34 5 58.60 - 34 7 58.60 - 34 These cases are already at minimum general ready g | | 220 | 000 | 270 | 28.02 | | | 222 | 32 | 57.69 | | <u>1</u> 2 | ଷ | 909 | 8 | 8 | <u>6</u> | 27.69 | | 30MW-57.69Hz |
| 2 58.05 - - 183 35 57.66 - 24 867 707 4 58.05 - - 183 35 57.69 - 226 22 73 606 3 58.01 - - 194 30 57.52 - 229 26 622 622 3 58.02 - 194 30 57.67 - 219 26 573 469 5 58.59 - - 194 30 57.68 - 220 26 472 370 5 58.59 - - 34 - - 34 - 5 58.60 - - 34 - - - - 5 58.60 - - 34 - - - - 5 58.60 - - 34 - - - - 5 58.60 - - 34 - - - 5 58.60 - - 34 - - - | | 150 | 480 | 461 | 58.02 | | | 222 | 35 | 69.75 | | 251 | 29 | 496 | 401 | 20 | 481 | 27.7 | | 30MW-57.69Hz |
| 4 58.05 - 185 35 57.69 - 23 739 606 3 58.07 - - 196 30 57.52 - 222 26 673 469 2 57.38 - 194 30 57.67 - 219 26 673 469 2 57.38 - 194 30 57.68 - 220 26 472 370 5 58.69 - - 34 5 58.69 - - 34 5 58.60 - - 34 These cases are already at minimum general mini | | 200 | 08 | 832 | 58.05 | | | 8 | 32 | 27.66 | | 202 | 77 | 867 | 707 | | | | | |
| 2. 88.00 - - 196 30 57.68 - 220 26 472 30 2. 88.00 - - 194 30 57.68 - 220 26 472 370 4. 88.00 - - 194 30 57.68 - 220 26 472 370 5. 88.59 - - 34 34 34 34 34 5. 88.60 - - 34 34 34 34 5. 88.60 - - 34 34 34 | | 90 6 | 220 | \$ 8 | 58.05 | | | 8 8 | 35 | 27.69 | | 8 8 | 8 8 | 85 68 86 68 | 900 | ı | - | | | : |
| 3 53,000 - - 1194 30 57,68 - 219 5 58,59 - - 34 34 57,68 - 220 5 58,59 - - 34 34 57,68 - 220 5 58,59 - - 34 34 34 5 58,59 - - 34 5 58,60 - - 34 | | 93 8 | £ 1 | Z 5 | 58.01 | | | 95 9 | S 8 | 57.52 | | 3 8 | 8 8 | 7 (8 | 77 | These ca | ses are alre | ady at minir | num gener | ation so cannot increase LLfurther. |
| 58.56 - 34 5.00 5.00 5.00 5.00 5.00 5.00 5.00 5.0 | | 22.5 | 2/0 | X 5 | 28.02 | | | 193 | 9 8 | 27.57 | | 617 | 8 8 | 5 5 | 9 66 | | | | | |
| 5 58.50 34 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 | | 2002 | P 00 | A54 | 58.50 | . | . | ± % | 8 | 90: 30 | - | 8 | 23 | 7/1 | 200 | | | | | |
| 5 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 58.60 - 34 34 | | 400 | 98 | 525 | 58.59 | | | 8 | | | | | | | | | | | | |
| 5 5860 | | 300 | 410 | 336 | 58.60 | | | 怒 | | | | Ē | ese cases at | e already at | minimum | generation so c | cannot incre | ase ULfurth | er. | |
| 28.60 | | 250 | 320 | 340 | 58.59 | | | 怒 | | | | | | | | | | | | |
| La Lilling at Mark Minn general and market market and market mark | 315 | 150 | 240 | 235 | 58.60 | | | 怒 | | | | | | | | | | | | |
| | imit at 415 MWmin gr | eneration | t at a tranefar | imit | | | | | | | | | | | | | | | | |

23 | ©TransGrid Solutions Inc., 2025 | Report: R1205.01.03, June 26, 2025

4.2 **LIL Monopole Limits**

If the LIL is operating as a monopole and it trips, UFLS should not occur and, therefore, IIS frequency should not dip below 58.8 Hz¹⁶. LIL monopole limits were set to keep the IIS frequency at 59.1 Hz, to provide a 0.3 Hz margin to 58.8 Hz. These LIL monopole limits are summarized in the following tables:

- Table 4-8 ML runbacks active with and without one LIL restart enabled
- Table 4-9 ML runbacks not active with and without ML Frequency Controller active

Please note the following:

- Unlike in bipole mode, restarts do have a marginal impact on transfer limits as per Table 4-8.
- There are some scenarios listed in Table 4-8 where the allowable LIL transfer (measured at SOP) is less than ML exports (i.e. when ML is exporting in the range of 400 MW to 500 MW). Enabling LIL restarts in these scenarios should be avoided.
- In Table 4-9, when ML runbacks are not active and the ML frequency controller is not available, the LIL monopole was set to operate at its minimum of 45 MW. Although the 58.8 Hz UFLS is not reached when the monopole trips, the goal of maintaining some margin and ensuring frequency does not dip below 59.1 Hz is not achievable.
- There is an interesting trend to note in the LIL MP limits; starting at peak demand the LIL MP limits initially decrease as demand decreases, however, once IIS demand reaches around 1500 MW, the LIL MP limits begin to increase as demand decreases. An example of this trend is shown in Figure 4-9. It is theorized that the lower demand cases have more inertia in-service if normalized against the demand, and this ratio of inertia to demand starts increasing around the 1250 MW demand cases and continues increasing as demand decreases, thereby allowing the LIL MP limits to increase while still maintaining frequency above 59 Hz.

¹⁶ Hydro does have "LIL Monopole Protocols" in which LIL monopole transfers can be increased for economic or low Island supply scenarios at the expense of risking UFLS for loss of LIL monopole.






Figure 4-9. LIL MP Limit – trend over IIS demand range.

If it is deemed acceptable to allow UFLS to occur if the LIL monopole were to trip, then the same LIL bipole limits provided in Table 4-3 can be used, as long as it results in the same LIL power <u>at SOP</u>, i.e. that the LIL limits at MFA take into account the additional losses on the LIL when operating in monopole mode compare to bipole mode.



Table 4-8. LIL Monopole Limits - No UFLS - ML runbacks active

| | Limits - No | | _ | Restarts Enal | oled | | Restart Enabl ns delay ML ru | |
|--------------------|------------------------|---------|------------------------------------------|-------------------------------------|-----------------------|------------------------------------------|-------------------------------------|-----------------------|
| IIS Demand (MW) | IIS Generation (MW) | ML (MW) | LIL Transfer Limit (MW) @ MFA (GR) | LIL Transfer Limit (MW) @ SOP | Min Frequency (Hz) | LIL Transfer Limit (MW) @ MFA (GR) | LIL Transfer Limit (MW) @ SOP | Min Frequency (Hz) |
| 1939 | 1898 | 500 | 665 | 548 | 59.1 | 615 | 513 | 59.1 |
| 1751 | 1714 | 500 | 655 | 543 | 59.11 | 595 | 501 | 59.1 |
| 1537 | 1523 | 500 | 626 | 521 | 59.1 | 565 | 480 | 59.1 |
| 1283 | 1250 | 500 | 650 | 540 | 59.1 | 560 | 476 | 59.1 |
| 1044 | 993 | 500 | 681 | 558 | 59.1 | 540 | 462 | 59.1 |
| 790 | 720 | 500 | 710 | 578 | 59.1 | 534 | 459 | 59.1 |
| 642 | 571 | 500 | 715 | 581 | 59.1 | 519 | 448 | 59.1 |
| 490 | 429 | 500 | 696 | 569 | 59.11 | 489 | 425 | 59.1 |
| 2130 | 2082 | 400 | 528 | 455 | 59.1 | 514 | 444 | 59.1 |
| 1920 | 1886 | 400 | 510 | 441 | 59.1 | 500 | 434 | 59.11 |
| 1751 | 1757 | 400 | 500 | 434 | 59.1 | 488 | 425 | 59.1 |
| 1527 | 1523 | 400 | 471 | 412 | 59.1 | 486 | 423 | 59.1 |
| 1269 | 1241 | 400 | 502 | 435 | 59.1 | 484 | 422 | 59.1 |
| 1025 | 986 | 400 | 516 | 446 | 59.11 | 484 | 422 | 59.1 |
| 768 | 720 | 400 | 528 | 455 | 59.11 | 454 | 399 | 59.1 |
| 634 | 592 | 400 | 520 | 449 | 59.1 | 444 | 391 | 59.1 |
| 466 | 424 | 400 | 514 | 444 | 59.1 | 429 | 380 | 59.1 |
| 2115 | 2082 | 300 | 377 | 339 | 59.1 | 373 | 336 | 59.11 |
| | | | - | | | | | |
| 1911 | 1887 | 300 | 367 | 331 | 59.1 | 363 | 328 | 59.11 |
| 1761 | 1729 | 300 | 376 | 339 | 59.1 | 372 | 336 | 59.1 |
| 1525 | 1522 | 300 | 342 | 310 | 59.1 | 337 | 306 | 59.11 |
| 1255 | 1233 | 300 | 364 | 329 | 59.1 | 356 | 323 | 59.11 |
| 1012 | 992 | 300 | 362 | 328 | 59.1 | 354 | 321 | 59.1 |
| 748 | 715 | 300 | 377 | 340 | 59.1 | 370 | 334 | 59.1 |
| 642 | 606 | 300 | 380 | 343 | 59.1 | 374 | 337 | 59.1 |
| 448 | 416 | 300 | 376 | 339 | 59.1 | 362 | 328 | 59.1 |
| 2110 | 2083 | 225 | 280 | 259 | 59.1 | 278 | 257 | 59.1 |
| 1906 | 1876 | 225 | 282 | 261 | 59.1 | 278 | 258 | 59.11 |
| 1761 | 1743 | 225 | 269 | 250 | 59.1 | 267 | 248 | 59.1 |
| 1511 | 1473 | 225 | 292 | 270 | 59.1 | 288 | 266 | 59.11 |
| 1259 | 1244 | 225 | 266 | 247 | 59.1 | 263 | 244 | 59.1 |
| 1012 | 988 | 225 | 276 | 256 | 59.11 | 273 | 254 | 59.11 |
| 744 | 714 | 225 | 283 | 262 | 59.1 | 279 | 259 | 59.1 |
| 439 | 415 | 225 | 277 | 256 | 59.11 | 275 | 255 | 59.1 |
| 2016 | 1990 | 150 | 193 | 183 | 59.1 | 192 | 182 | 59.11 |
| 1910 | 1886 | 150 | 190 | 181 | 59.1 | 190 | 191 | 50.09 |
| 1763 | 1744 | 150 | 185 | 176 | 59.11 | 184 | 175 | 59.11 |
| 1517 | 1492 | 150 | 192 | 182 | 59.1 | 191 | 181 | 59.1 |
| 1259 | 1246 | 150 | 178 | 170 | 59.11 | 177 | 169 | 59.11 |
| 1005 | 976 | 150 | 196 | 186 | 59.1 | 195 | 185 | 59.1 |
| 744 | 721 | 150 | 189 | 179 | 59.11 | 188 | 178 | 59.11 |
| 434 | 413 | 150 | 187 | 178 | 59.1 | 185 | 176 | 59.12 |



Table 4-9. LIL Monopole Limits – No UFLS – ML runbacks not active

| LIL MP Lim | its (no UFLS, N | 1L Runbacks | Not Active) - | ML Active F/ | C (150 MW) |
|--------------------|------------------------|-------------|------------------------------------------|-------------------------------------|-----------------------|
| IIS Demand (MW) | IIS Generation (MW) | ML (MW) | LIL Transfer Limit (MW) @ MFA (GR) | LIL Transfer Limit (MW) @ SOP | Min Frequency (Hz) |
| 2130 | 1977 | 0 | 167 | 160 | 59.1 |
| 1914 | 1762 | 0 | 166 | 159 | 59.1 |
| 1769 | 1614 | 0 | 169 | 162 | 59.1 |
| 1532 | 1386 | 0 | 159 | 152 | 59.1 |
| 1275 | 1139 | 0 | 149 | 143 | 59.1 |
| 1013 | 877 | 0 | 149 | 143 | 59.11 |
| 742 | 672 | 0 | 155 | 149 | 59.11 |
| 598 | 603 | 0 | 169 | 162 | 59.1 |
| 461 | 543 | 0 | 172 | 164 | 59.1 |

| LIL MP Limit | s (no UFLS, M | L Runbacks | Not Active) - I | ML Not Active | e F/C (0 MW) |
|--------------------|------------------------|------------|------------------------------------------|-------------------------------------|-----------------------|
| IIS Demand (MW) | IIS Generation (MW) | ML (MW) | LIL Transfer Limit (MW) @ MFA (GR) | LIL Transfer Limit (MW) @ SOP | Min Frequency (Hz) |
| 2124 | 2086 | 0 | 45 | 44 | 58.94 |
| 1922 | 1884 | 0 | 45 | 44 | 58.96 |
| 1772 | 1734 | 0 | 45 | 44 | 59.08 |
| 1557 | 1520 | 0 | 45 | 44 | 58.83 |
| 1275 | 1238 | 0 | 45 | 44 | 59.02 |
| 1029 | 991 | 0 | 45 | 44 | 58.86 |
| 750 | 785 | 0 | 45 | 44 | 58.89 |
| 603 | 725 | 0 | 45 | 44 | 59 |
| 462 | 665 | 0 | 45 | 44 | 58.95 |



5. ML Export Limits

Loss of the ML bipole while exporting is the contingency that defines the ML export limits. If the ML bipole (or monopole) is lost while exporting, the Island frequency will increase. Transmission Planning Criteria state that this overfrequency should not go above 63 Hz.

ML Export limits can be defined in terms of Island Generation rather than Island Demand, since they are more of a function of inertia and not UFLS.

5.1 LIL Frequency Support Available

The LIL is equipped with runback/runup functionality ¹⁷ and frequency controller functionality to regulate IIS frequency if the ML bipole or pole trips. This study determined that if LIL frequency support is available (in the form of the frequency controller or runbacks), there are no restrictions on ML exports if the ML bipole trips. Analysis confirmed that the frequency response when relying on the LIL frequency controller versus LIL runbacks is the same. Please note that this is assuming the LIL is dispatched in such a way that the required frequency support can be provided. For example; if LIL is at 90 MW, there will not be any frequency support available.

ML export of 500 MW was simulated with the LIL frequency support in-service (in the form of the frequency controller or runbacks). The resulting maximum IIS frequency excursion following loss of the ML bipole is around 61.1 Hz as summarized in Table 5-1.

It is concluded that if the LIL bipole is in-service and can provide its full range of frequency support, the ML can export its full rating of 500 MW without violating Transmission Planning Criteria at any Island Generation level.

Table 5-1. Frequency Excursions due to loss of ML bipole (LIL frequency support available)

| | | | Loss of | ML Bipole |
|----------|----------------|-----------------|-------------------|--------------------------|
| LIL (MW) | Demand (MW) | Generation (MW) | ML Export (MW) | Max Frequency (Hz) |
| 900 | 2057 | 1730 | | 61.1 |
| 900 | 1939 | 1611 | | 61.1 |
| 900 | 1785 | 1457 | | 61.1 |
| 900 | 1542 | 1214 | | 61.1 |
| 900 | 1291 | 963 | 500 | 61.1 |
| 900 | 1067 | 739 | | 61.1 |
| 900 | 811 | 483 | | 61.13 |
| 875 | 724 | 418 | | 61.13 |
| 690 | 468 | 324 | | 61.15 |

¹⁷ PDO_X Active --> PFC at SOP Disabled --> Bipole Power Regulating Active --> Bipole Power Regulating Not Active --> PDO X Not Active --> PFC at SOP Enable



5.2 LIL Frequency Support Unavailable

ML export must be limited to meet Transmission Planning Criteria if frequency support from the LIL is unavailable (frequency controller or runbacks). ML export limits were determined for two frequency criteria scenarios:

- 1. Ensuring system frequency does not exceed 62.5 Hz (HRD Unit Online)¹⁸
- 2. Ensuring system frequency does not exceed 63 Hz (HRD Unit Offline)

One option to increase ML export limits is to cross-trip Cat Arm generation to help reduce the frequency and keep it within criteria. ML export limits were determined for the following scenarios without frequency support from the LIL:

- No cross-tripping of Cat Arm generation
- Cross-tripping of varying amounts of Cat Arm generation to aid in reducing overfrequency if frequency exceeds:
 - o 61 Hz
 - 61.5 Hz
 - 62 Hz¹⁹

The ML export limits without frequency support from the LIL are provided in:

- Table 5-2 to keep IIS frequency below 62.5 Hz
- Table 5-3 to keep IIS frequency below 63 Hz

Table 5-2 MI Export Limit - IIS Frequency Criteria 62 5 Hz (HRD Online)

| I able | 5-Z. IVIL D | Export Lii | 111t — 11 | o rieq | uency | Criter | 1a 62.5 | 112 (11 | ווט טוו | iiiie) | | | | |
|--------|-------------|------------|-----------|-----------|----------|----------|---------|----------------|-----------|-------------|----------|--------|---------|-------|
| | | | N | /IL Expor | t Limits | s (MW) - | No UL | F/C -IIS | S Freque | ency Cri | teria 62 | 2.5 Hz | | |
| Demand | Generation | No CATARM | | | | Trip | CATARM | n Overfre | quency of | 61, 61.5, 6 | 62 Hz | | | |
| (MW) | (MW) | X-trip | | 35 MW | | | 67 MW | | | 90 MW | | | 134 MW | |
| | | X-tiip | 61 Hz | 61.5 Hz | 62 Hz | 61 Hz | 61.5 Hz | 62 Hz | 61 Hz | 61.5 Hz | 62 Hz | 61 Hz | 61.5 Hz | 62 Hz |
| 1900 | 1355 | 136 | 165 | 163 | 160 | 195 | 190 | 185 | 216 | 211 | 205 | 245 | 240 | 230 |
| 1750 | 1265 | 132 | 153 | 151 | 148 | 182 | 176 | 170 | 213 | 209 | 203 | 232 | 228 | 218 |
| 1500 | 1034 | 124 | 144 | 142 | 138 | 173 | 170 | 164 | 202 | 198 | 192 | 226 | 221 | 212 |
| 1250 | 832 | 110 | 138 | 136 | 132 | 170 | 166 | 160 | 199 | 196 | 191 | 222 | 218 | 210 |
| 1000 | 551 | 106 | 128 | 126 | 123 | 160 | 158 | 154 | 185 | 183 | 180 | 212 | 208 | 204 |
| 750 | 400 | 76 | 108 | 107 | 105 | 138 | 136 | 132 | 170 | 168 | 165 | 190 | 187 | 183 |
| 450 | 415 | 90 | 111 | 110 | 109 | 142 | 140 | 138 | 182 | 180 | 177 | 205 | 204 | 201 |



¹⁸ It is preferred that the HRD Thermal Units not experience frequency greater than 62.5 Hz as per direction from the asset owner. This criterion only applies in the interim and these limits will not be applicable once HRD is relegated to a backup role only (or decommissioned)

¹⁹ Hydro currently applies these limits.

Table 5-3. ML Export Limits – IIS Frequency Criteria 63 Hz (HRD Offline)

| | <u> </u> | | | | 9 4 5 6 | , | | · ·- /· ·· | | | | | | |
|------|----------|-----------|-------|---------|----------|--------|---------|------------|-----------|-------------|-----------|-------|---------|-------|
| | | | | ML Expo | rt Limit | s (MW) | -No∐L | .F/C -II | S Frequ | iency C | riteria 6 | 3 Hz | | |
| | | No CATARM | | | | Trip | CATARM | on Overfre | quency of | 61, 61.5, 6 | 62 Hz | | | |
| (MW) | (MW) | X-trip | | 35 MW | | | 67 MW | | | 90 MW | | | 134 MW | |
| | | X-tiip | 61 Hz | 61.5 Hz | 62 Hz | 61 Hz | 61.5 Hz | 62 Hz | 61 Hz | 61.5 Hz | 62 Hz | 61 Hz | 61.5 Hz | 62 Hz |
| 1900 | 1372 | 178 | 198 | 196 | 194 | 230 | 226 | 222 | 240 | 237 | 232 | 280 | 276 | 270 |
| 1750 | 1310 | 176 | 196 | 194 | 192 | 228 | 225 | 220 | 238 | 236 | 230 | 279 | 275 | 268 |
| 1500 | 1074 | 162 | 182 | 180 | 178 | 214 | 211 | 206 | 230 | 227 | 222 | 266 | 262 | 255 |
| 1250 | 882 | 158 | 178 | 176 | 174 | 210 | 207 | 202 | 222 | 218 | 215 | 262 | 258 | 252 |
| 1000 | 577 | 131 | 158 | 157 | 155 | 190 | 188 | 185 | 204 | 202 | 200 | 244 | 242 | 238 |
| 750 | 440 | 115 | 133 | 132 | 131 | 164 | 163 | 161 | 188 | 186 | 184 | 228 | 227 | 224 |
| 450 | 453 | 127 | 148 | 147 | 146 | 178 | 177 | 175 | 200 | 198 | 197 | 241 | 239 | 236 |

ML Import Limits 6.

Loss of the ML bipole is the contingency that defines the ML import limits. If the ML bipole is lost while importing, the Island frequency will decrease. Transmission Planning Criteria state that for loss of the bipole UFLS is acceptable, as long as the system recovers. Similar to how the LIL bipole limits are determined, the frequency should stay above 57.8 Hz to give some margin to the 57.7 Hz UFLS back-up block.

For loss of a pole, the frequency should remain above 59.1 Hz. Following an ML pole trip (while the ML is operating as a bipole), it is assumed that the healthy ML pole will pick up the transfer that was lost on the other ML pole, up to its rating of 250 MW at the rectifier end.

LIL Frequency Support Available 6.1

The LIL is equipped with runback/runup functionality and frequency controller functionality to assist IIS frequency if the ML bipole or pole trips. This study determined that if the LIL is in-service and can provide its full range of frequency support, there are no restrictions on ML imports if the ML bipole trips.

Maximum ML import of 320 MW was simulated with LIL frequency support available and the Final UFLS in-service. The resulting worst-case IIS frequency excursions are summarized in Table 6-1 for loss of the ML bipole.

It is concluded that, if LIL frequency support is available, the ML can import the full 320 MW transfer limit without violating the underfrequency criteria the ML bipole trips.

| | | | Los | s of ML Bipole | |
|----------|----------------|--------------------|---------------------|--------------------------|--------------|
| LIL (MW) | Demand (MW) | Generation (MW) | ML Transfer (MW) | Min Frequency (Hz) | UFLS (MW) |
| 780 | 1998 | 954 | | 58.59 | 316 |
| 690 | 1743 | 779 | | 58.77 | 136 |
| 620 | 1495 | 594 | -320 | 58.75 | 116 |
| 500 | 1240 | 448 | | 59.16 | - |
| 170 | 1001 | 430 | | 59.23 | - |

LIL Frequency Support Unavailable 6.2

6.2.1 ML operating as bipole

A maximum ML import level of 320 MW was tested without LIL frequency support and with the Final UFLS scheme in place. The results are summarized in Table 6-2, with conclusions summarized below:

For loss of the ML bipole, the ML can transfer the full 320 MW over all IIS demand scenarios, except for the 723 MW demand case at minimum IIS generation, which has an ML import limit of 300 MW. UFLS occurs as summarized in the table.



• Loss of an ML pole is more limiting than loss of the ML bipole when LIL frequency support is not available. When operating a 320 MW import, each pole is at 160 MW. If a pole is lost, the healthy pole will increase to 250 MW, resulting in a loss of approximately 70 MW to the IIS, which is too high to maintain the 59.1 Hz criteria when the LIL frequency support is not available. The ML import limits are therefore defined by loss of a pole and range from 280 MW to 287 MW import as listed in Table 6-2. Since the limits do not vary widely, it is recommended to use an ML bipole import limit of 280 MW under all IIS conditions when LIL frequency support is not available.

Table 6-2. ML Bipole – Import Limits – No LIL frequency support available

| | | Loss of ML | Bipole (Impor | t) - No LIL free | quency sup | port | |
|-------------|----------------|--------------------|-----------------------------------------|-------------------|--------------|------------------------------------|-------------------|
| LIL (MW) | Demand (MW) | Generation (MW) | ML limit – Loss of bipole (MW) | Frequency (Hz) | UFLS (MW) | ML limit – Loss of Pole (MW) | Frequency (Hz) |
| 780 | 1998 | 954 | -320 | 58.51 | 333 | -284 | 59.1 |
| 690 | 1743 | 779 | -320 | 58.44 | 283 | -287 | 59.1 |
| 620 | 1495 | 594 | -320 | 58.38 | 358 | -285 | 59.1 |
| 500 | 1240 | 448 | -320 | 58.33 | 287 | -280 | 59.1 |
| 170 | 1001 | 430 | -320 | 58.19 | 294 | -287 | 59.1 |
| 45* | 723 | 385 | -300 | 58.01 | 210 | -286 | 59.12 |

^{*}to meet minimum IIS generation



6.2.2 ML operating as monopole

If the ML is operating as a monopole when it trips, UFLS should not occur, and IIS frequency should not drop below 58.8 Hz. ML import limits were set to keep the IIS frequency above 59.1 Hz, to provide a 0.3 Hz margin to 58.8 Hz.

The ML monopole import limits range from 24 MW to 33 MW when LIL frequency support is not available in the form of the frequency controller or LIL runbacks and are summarized in Table 6-3. Since the limits do not vary widely, it is recommended to use an ML monopole import limit of 24 MW under all IIS conditions when LIL frequency support is not available.

Table 6-3. ML Monopole – Import Limits – LIL frequency support available

| Loss of M | L Monopole (| Import) - No L | IL Frequency | Support |
|-----------|----------------|--------------------|------------------|-------------------|
| LIL (MW) | Demand (MW) | Generation (MW) | ML limit (MW) | Frequency (Hz) |
| 900 | 2004 | 1144 | -30 | 59.11 |
| 850 | 1738 | 920 | -33 | 59.12 |
| 780 | 1491 | 734 | -33 | 59.1 |
| 680 | 1234 | 570 | -29 | 59.12 |
| 580 | 995 | 425 | -24 | 59.1 |
| 300 | 735 | 420 | -28 | 59.11 |



7. Other Considerations

7.1 Minimum Avalon Generation

As discussed in Section 4.1.3, voltage collapse can occur near the mid-point of the BDE-SOP 230 kV corridor (around SSD) during high IIS demand conditions when the LIL bipole trips. When the LIL infeed on the Avalon is lost, a large amount of power suddenly flows from the western part of the IIS over the 230 kV BDE-SOP corridor towards the Avalon load causing a transient voltage drop along this corridor. The voltage issues were also observed in the preliminary Stage 4 studies where it was mitigated by ensuring a minimum amount of Avalon generation is in-service under specified high levels of IIS demand to offload BDE-SOP flow, which is the same approach taken in the Stage 4F study. A previous study²⁰ assessing the 230 kV transmission corridor between BDE and SOP also identified the possibility of shedding more load on the Avalon following a LIL bipole trip to reduce or eliminate the need for a minimum amount Avalon generation to be in-service.

The voltage collapse issue was demonstrated in Section 4.1.3 and shown again here in Figure 7-1 by plotting the 230 kV voltage at SSD (following a LIL bipole trip) for varying levels of pre-contingency Avalon generation. Please note that HRD3 was assumed to be in-service as a synchronous condenser for this analysis.




Figure 7-1. Voltage response at SSD after LIL bipole trip – as Avalon generation is reduced *Blue*: Pre-contingency Avalon generation 3x47.2 MW - meets transient voltage criteria *Green*: Pre-contingency Avalon generation 2x47.2 MW – violates transient voltage criteria *Red*: Pre-contingency Avalon generation 2x30 MW – unstable

²⁰ Section 2.3.2 of TGS report TN1817.01.05 "Assessment of the BDE/SOP Transmission Constraints ", dated October 25, 2023.

The minimum Avalon generation requirements were calculated for the set of 2023-2421 cases and the 2033-34 cases for varying LIL and ML transfer levels with two SOP synchronous condensers in-service²², as summarized in Table 7-1. The following observations are made:

- The need for a minimum amount of Avalon generation to be in-service to prevent voltage collapse following the loss of the LIL bipole starts at an IIS demand of approximately 1650 MW.
- At higher levels of ML export and IIS demand, Avalon generation amounts in grey-shaded cells marked with ** indicate that the Avalon generation required to be in-service to serve demand/ML exports is higher than the Avalon generation required to prevent the voltage collapse issue, therefore voltage collapse is inherently not the limiting factor in these scenarios.
- The minimum Avalon generation requirements vary based on LIL and ML transfer levels. Yellowshaded cells indicate the Avalon generation requirement for a particular demand level that would cover all LIL / ML transfer level scenarios. Using this single yellow-shaded number would avoid a large look-up table, however, it means that more Avalon generation may be on-line than needed in some scenarios.

Alternative mitigation options, such as the addition of reactive power support near SSD, are being investigated in future studies. A previous study¹⁶ also evaluated various transmission upgrades to the 230 kV BDE-SOP corridor, including the possibility of adding a 3rd 230 kV line between WAV and SOP.



²¹ 2023-24 cases differ from the 2033-34 cases in that BDE unit 8 and the three new 50 MW HRD CTs are not inservice.

²² HRD3 was assumed to be online as a synchronous condenser.

Table 7-1. Minimum Avalon Generation required to prevent voltage collapse after LIL bipole trip

| | <i>s</i> eneratio | on Require | ements | | 2 SOPSCs | |
|------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------|----------------------------------------|
| | (M | W) | | | 2033-34 Case | s |
| Demand (MW) | Generation (MW) | Gross Avalon load (MW) | ML(MW) | ⊔L=900 MW | ⊔L=700 MW | ⊔L=600 MW |
| 2056 | 1729 | 1090 | 500 | 310 ** | ** | ** |
| 2034 | 1607 | 1088 | 400 | 240** | ** | ** |
| 2020 | 1493 | 1086 | 300 | 180 | ** | ** |
| 2016 | 1439 | 1086 | | 145 | ** | ** |
| 2012 | 1334 | 1086 | 150 | 140 | 180 | ** |
| | | | 0 | 120 | 140 | 160 |
| 1938 | 1611 | 1025 | 500 | 210** | ** | ** |
| 1919 | 1492 | 1023 | 400 | 140** | ** | ** |
| 1907 | 1380 | 1022 | 300 | 95 | ** | ** |
| 1904 | 1413 | 1022 | 250 | 80 | 115 | ** |
| 1901 | 1223 | 1022 | 150 | 60 | 95 | 115 |
| | | | 0 | 30 | 60 | 80 |
| 1785 | 1428 | 940 | 500 | 95** | ** | ** |
| 1768 | 1341 | 938 | 400 | 30 | ** | ** |
| 1761 | 1234 | 938 | | 0 | 40 | ** |
| 1759 | 1181 | 938 | | 0 | 20 | ** |
| 1750 | 1073 | 938 | | 0 | 10 | 30 |
| | | | 0 | 0 | 0 | 0 |
| 1535 | 1207 | 801 | 500 | 0 | | ** |
| 1524 | 1096 | | 400 | 0 | | 0 |
| 1513 | 985 | 801 | 300 | 0 | | 0 |
| 1511 | 934 | 801 | 250 | 0 | | 0 |
| 1502 | 825 | 801 | 150 | 0 | | 0 |
| | | | | - | 2023-24 Case: | |
| | | Gross | I | | | |
| Demand (MW) | Generation (MW) | Avalon load | ML(MW) | ∐L=900 MW | ⊔L=700 MW | ⊔L=600 MW |
| | (, | (10/10.00) | III(IIIIV) | DL - 300 IVIVV | | |
| 1023 | ` ' | (MW) | | | ** | ** |
| 1923 1895 | 1587 | 1019 | 500 | 443** | | ** |
| 1895 | 1587 1459 | 1019 1014 | 500 400 | 443 * * 310 * * | ** | |
| 1895 1877 | 1587 1459 1342 | 1019 1014 1010 | 500 400 300 | 443 ** 310 ** 180 ** | ** ** ** | ** |
| 1895 1877 1872 | 1587 1459 1342 1286 | 1019 1014 1010 1009 | 500 400 300 250 | 443 ** 310 ** 180 ** 140 | ** ** ** 233** | ** |
| 1895 1877 1872 1865 | 1587 1459 1342 1286 1189 | 1019 1014 1010 1009 1009 | 500 400 300 250 150 | 443** 310 ** 180** 140 115 | ** ** ** | ** ** ** |
| 1895 1877 1872 1865 1864 | 1587 1459 1342 1286 1189 1528 | 1019 1014 1010 1009 1009 987 | 500 400 300 250 150 | 443 ** 310 ** 180 ** 140 115 363.5** | ** ** ** 233** 140 | ** ** ** |
| 1895 1877 1872 1865 1864 1839 | 1587 1459 1342 1286 1189 1528 1404 | 1019 1014 1010 1009 1009 987 983 | 500 400 300 250 150 500 | 443 ** 310 ** 180 ** 140 115 363.5** 250** | ** ** 233 ** 140 ** | ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 | 1587 1459 1342 1286 1189 1528 1404 1288 | 1019 1014 1010 1009 1009 987 983 981 | 500 400 300 250 150 500 400 300 | 443 ** 310 ** 180 ** 140 115 363.5** 250** | ** ** 233** 140 ** | ** ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 | 1019 1014 1010 1009 1009 987 983 981 980 | 500 400 300 250 150 500 400 300 250 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** | ** ** 233** 140 ** ** | ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 | 1019 1014 1010 1009 1009 987 983 981 980 979 | 500 400 300 250 150 500 400 300 250 150 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** | ** ** 233 ** 140 ** ** ** ** | ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1812 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 1127 972 | 1019 1014 1010 1009 1009 987 983 981 980 979 | 500 400 300 250 150 500 400 300 250 150 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** 100 60 40 | ** ** 233 ** 140 ** ** ** | ** ** ** ** ** ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1812 1808 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 1127 972 | 1019 1014 1010 1009 1009 987 983 981 980 979 979 | 500 400 300 250 150 500 400 300 250 150 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** 100 60 40 330 ** | ** ** 233 ** 140 ** ** ** ** 100 | ** ** ** ** ** ** ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1812 1808 1804 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 1127 972 1468 1344 | 1019 1014 1010 1009 1009 987 983 981 980 979 979 | 500 400 300 250 150 500 400 300 250 150 0 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** 100 60 40 330 ** 190 ** | ** ** 233 ** 140 ** ** ** ** 100 ** | ** ** ** ** ** ** ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1812 1808 1804 1779 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 1127 972 1468 1344 | 1019 1014 1010 1009 1009 987 983 981 980 979 979 954 | 500 400 300 250 150 500 400 300 250 150 0 500 400 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** 100 60 40 330 ** 190 ** 90 ** | ** ** 233 ** 140 ** ** ** ** 100 ** | ** ** ** ** ** ** ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1812 1808 1804 1779 1765 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 1127 972 1468 1344 1229 | 1019 1014 1010 1009 1009 987 983 981 980 979 979 954 950 | 500 400 300 250 150 500 400 300 250 150 60 400 300 250 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** 100 60 40 330 ** 190 ** 90 ** | ** ** 233 ** 140 ** ** ** 100 ** ** ** ** ** | ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1812 1808 1779 1765 1760 1755 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 1127 972 1468 1344 1229 1174 | 1019 1014 1010 1009 1009 987 983 981 980 979 979 954 950 948 | 500 400 300 250 150 500 400 300 250 150 400 300 250 150 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** 100 60 40 330 ** 190 ** 90 ** 70 40 | ** ** 233 ** 140 ** ** ** 100 ** ** ** ** ** | ** ** ** ** ** ** ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1812 1808 1779 1765 1760 1755 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 1127 972 1468 1344 1229 1174 1069 | 1019 1014 1010 1009 1009 987 983 981 980 979 979 954 950 948 947 | 500 400 300 250 150 500 400 300 250 500 400 300 250 150 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** 100 60 40 330 ** 190 ** 90 ** 70 40 223 ** | ** ** 233** 140 ** ** ** 100 ** ** ** 60 (LIL=800) | ** ** ** ** ** ** ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1812 1808 1779 1765 1760 1755 1693 1671 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 1127 972 1468 1344 1229 1174 1069 | 1019 1014 1010 1009 1009 987 983 981 980 979 979 954 950 948 947 | 500 400 300 250 150 500 400 300 250 500 400 300 250 150 500 400 | 443 ** 310 ** 180 ** 140 115 363.5 ** 250 ** 150 ** 100 60 40 330 ** 190 ** 70 40 223 ** 100 ** | ** ** 233 ** 140 ** ** ** 100 ** ** ** 60 (LIL=800) ** ** | ** ** ** ** ** ** ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1808 1804 1779 1765 1760 1755 1693 1671 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 11127 972 1468 1344 1229 1174 1069 1357 | 1019 1014 1010 1009 1009 987 983 981 980 979 979 954 950 948 947 947 | 500 400 300 250 150 500 400 300 250 150 400 300 250 150 400 300 | 443 ** 310 ** 180 ** 140 115 363.5** 250** 150** 100 60 40 330 ** 190 ** 70 40 223 ** 100 ** 0 (on verge) | ** ** 233 ** 140 ** ** ** 100 ** ** ** 60 (LIL=800) ** ** | ** ** ** ** ** ** ** ** ** ** |
| 1895 1877 1872 1865 1864 1839 1824 1816 1812 1808 1779 1765 1760 1755 1693 1671 | 1587 1459 1342 1286 1189 1528 1404 1288 1206 1127 972 1468 1344 1229 1174 1069 | 1019 1014 1010 1009 1009 987 983 981 980 979 979 954 950 948 947 947 893 890 888 | 500 400 300 250 150 500 400 300 250 500 400 300 250 500 400 300 250 | 443 ** 310 ** 180 ** 140 115 363.5 ** 250 ** 150 ** 100 60 40 330 ** 190 ** 70 40 223 ** 100 ** | ** ** 233 ** 140 ** ** ** 100 ** ** ** 60 (LIL=800) ** ** | ** |

0 MW **Needed for MW



7.1.1 Impact of Synchronous Condensers

Please note that the status of the SOP SCs and the HRD3 SC will impact the minimum Avalon generation requirements. Fewer SCs in-service will require more Avalon generation to be in-service, and additional SCs in-service will require less Avalon generation to be in-service. Table 7-2 provides an example of the impact of adding the 3rd SOP SC to the minimum Avalon generation requirements for the 2023-24 cases.

Table 7-2. Minimum Avalon Generation Requirements with 2 and 3 SOP SCs in-service

| 2023-24 | Min Avalor | Gen (MW) |
|------------|------------|-----------|
| IIS demand | 2SOPSCs | 3 SOP SCs |
| 1870 | 140 | 60 |
| 1815 | 100 | 50 |
| 1760 | 70 | 0 |
| 1650 | 20 | 0 |

A previous study²³ performed a more thorough evaluation of the impact of HRD3 and SOP SCs on the need for Avalon generation at high demand. Conclusions from that study were as follows:

Sensitivity analysis was performed to check the equivalency of an SOP SC being in-service to the HRD 3 SC being in-service. It was found that an SOP SC provides slightly better system response than the HRD 3 SC. For example, the system response is slightly better (or Avalon generation requirements are slightly reduced, or have more margin) if 3 SOP SCs are in-service compared to 2 SOP SCs and the HRD 3 SC. Therefore, it would be safe to use the requirement for "2 SOP SC+HRD 3 SC" if there were 3 SOP SCs in-service and HRD 3 was out-of-service.

Additional future analysis will identify the updated full set of Avalon generation requirements for all combinations of SCs in/out-of-service, as well as the alternative solutions to reduce or eliminate these requirements, such as the addition of dynamic reactive power support near SSD.

²³ TGS report TN1817.01.05, "Assessment of the BDE/SOP Transmission Constraints", dated October 25, 2023.

7.2 LIL Filter Feeder Impact

There is an additional contingency that requires evaluation to determine the impact to the LIL transfer limits. The contingency involves the loss of a LIL filter feeder, in which up to three filters can trip at once, resulting in a fast reduction in LIL power transfer. In contrast to a LIL trip, this contingency is not setup to trigger a runback of ML exports. Therefore, the expectation is that under certain scenarios, LIL transfer limits could be further restricted when considering this specific contingency and the inability to perform an ML runback.

A previous study²⁴ assessed the impact of this contingency on LIL transfer limits. This study evaluated loss of LIL filter feeder B311 at Muskrat Falls ("MFA"). In a worst-case scenario, loss of this filter feeder will cause the LIL to quickly reduce power transfer to 271 MW²⁵.

The Stage 4F study repeated the analysis of the LIL filter feeder contingency using the Final UFLS scheme and the 2033-34 set of PSSE base cases with the LIL operating at the Final LIL transfer limit. The results are summarized in the following tables:

- Table 7-3

 LIL limits with ML runbacks active with and without ML Frequency Controller active
- Table 7-4 LIL limits with ML runbacks not active with and without ML Frequency Controller active

Red text in Table 7-3 indicates scenarios where loss of the filter feeder requires a reduction in the LIL transfer limit. The majority of these scenarios are at lower IIS demand levels with higher ML exports, and mostly when the ML frequency controller is not in-service. These scenarios would be unlikely operating states.

When ML runbacks are not active (Table 7-4) no reduction in LIL transfer limits is needed due to the filter feeder contingency.

²⁴ TGS report TN1205.87.07, "Revised LIL Transfer Limits – Consideration for Loss of a LIL Filter Feeder", dated January 10, 2022.

²⁵ The contingency was modeled by reducing LIL power to 271 MW and setting MFA filters to 2x72 MVAR. The filters at SOP were left as is, leaving the LIL's reactive power controller to adjust SOP filters as required for the new LIL operating point.

Table 7-3. LIL limits for loss of filter feeder – ML runbacks active

| ШLLimit | s | | | | | RFEED LF/Cin) | | | | | TERFEE VILF/Co | | |
|--------------------|---------------------------|------------|----------------------------|---------------------------|--------------------------|----------------------|-------------------------------------------------|--------------------------|---------------------------------------|--------------------------|----------------------|---------------------------------------------|--------------------------|
| IIS Demand (MW) | IIS Generation (MW) | ML(MW) | LIL Transfer Limit (MW) | LILTransfer Limit (MW) | Min Frequency (Hz) | Load shed (MW) | LIL Limit using Back- up block (MW) | Min Frequency (Hz) | ЦL Transfer Limit (M W) | Min Frequency (Hz) | Load shed (MW) | LIL Limit using Back-up block (MW) | Min Frequency (Hz) |
| 2056 | 1729 | 500 | 900 | 900 | 58.39 | 482 | | | 900 | 58.22 | 666 | | |
| 2034 | 1607 | 400 | 900 | 900 | 58.38 | 490 | | | 900 | 58.19 | 652 | | |
| 2020 | 1493 | 300 | 900 | 900 | 58.35 | 496 | | | 900 | 58.18 | 664 | | |
| 2016 | 1439 | 250 | 900 900 | 900 900 | 58.35 | 495 | | | 900 | 58.18 | 663 | | |
| 2012 | 1334 | 150 | | | 58.33 | 496 | | | 900 | 58.16 | 665 | | |
| 1938 1919 | 1611 1492 | 500 400 | 900 900 | 900 900 | 58.38 58.34 | 458 464 | | | 900 900 | 58.18 | 622 621 | | |
| 1919 | 1380 | 300 | 900 | 900 | 58.34 58.31 | 464 | | | 900 | 58.17 58.15 | 621 | | |
| 1907 | 1413 | 250 | 900 | 900 | 58.29 | 463 | | | 900 | 58.14 | 620 | | |
| 1904 | 1223 | 150 | 900 875 | 900 875 | 58.37 | 463 | | | 875 | 58.16 | 620 | | |
| 1785 | 1428 | 500 | 900 | 900 | 58.37 | 422 | | | 900 | 58.15 | 565 | | |
| 1768 | 1341 | 400 | 900 | 900 | 58.31 | 421 | | | 900 | 58.08 | 638 | | |
| 1761 | 1234 | 300 | 900 | 900 | 58.29 | 422 | | | 900 | 58.09 | 627 | | |
| 1759 | 1181 | 250 | 900 | 900 | 58.31 | 421 | | | 900 | 58.09 | 638 | | |
| 1750 | 1073 | 150 | 850 | 850 | 58.37 | 421 | | | 850 | 58.17 | 564 | | |
| 1535 | 1207 | 500 | 900 | 900 | 58.19 | 437 | | | 900 | 58.01 | 539 | | |
| 1524 | 1096 | 400 | 900 | 900 | 58.17 | 477 | | | 900 | 57.94 | 540 | | |
| 1513 | 985 | 300 | 900 | 900 | 58.18 | 476 | | | 900 | 57.94 | 538 | | |
| 1511 | 934 | 250 | 875 | 875 | 58.26 | 356 | | | 875 | 58.07 | 538 | | |
| 1502 | 825 | 150 | 780 | 780 | 58.37 | | | | 780 | 58.15 | | | |
| 1296 | 969 | 500 | 900 | 900 | 58.11 | 385 | | | 830 | 57.92 | 434 | 900 | 57.68 |
| 1280 | 853 | 400 | 900 | 900 | 58.15 | 385 | | | 820 | 57.92 | 434 | 880 | 57.67 |
| 1261 | 734 | 300 | 870 | 870 | 58.17 | 385 | | | 810 | 57.97 | 434 | 870 | 57.69 |
| 1253 | 744 | 250 | 800 | 800 | 58.3 | 287 | | | 800 | 57.98 | 435 | | |
| 1248 | 613 | 150 | 680 | 680 | 58.49 | 193 | | | 680 | 58.15 | 381 | | |
| 1067 | 740 | 500 | 900 | 900 | 58.03 | 333 | | | 740 | 57.85 | 332 | 790 | 57.67 |
| 1046 | 619 | 400 | 900 | 900 | 58.02 | 333 | | | 725 | 57.89 | 332 | 775 | 57.67 |
| 1023 | 609 | 300 | 785 | 785 | 58.21 | 263 | | | 720 | 57.95 | 332 | 760 | 57.69 |
| 1015 | 598 | 250 | 720 | 720 | 58.38 | 220 | | | 720 | 57.95 | 332 | | |
| 1003 | 598 | 150 | 590 | 590 | 58.61 | 147 | 650 | F7 00 | 590 | 58.22 | 219 | | F7.00 |
| 811 | 483 | 500 | 900 | 820 | 57.94 | 222 | 850 | 57.69 | 620 | 58.00 | 222 | 675 | 57.68 |
| 781 | 476 461 | 400 300 | 800 660 | 800 | 57.9 | 223 | | | 610 | 57.98 57.07 | 222 222 | 650 640 | 57.67 57.67 |
| 760 752 | 461 457 | 300 250 | 600 | 660 600 | 58.39 58.58 | 147 98 | | | 610 600 | 57.97 57.99 | 222 | 640 | 57.67 |
| 752 | 457 | 250 150 | 480 | 480 | 58.85 | 98 | | | 480 | 57.99 58.38 | 147 | | |
| 741 | 415 | 500 | 900 | 750 | 57.98 | 189 | 780 | 57.70 | 580 | 57.98 | 189 | 610 | 57.69 |
| 742 | 417 | 400 | 900 750 | 750 750 | 57.96 57.99 | 192 | 700 | 51.10 | 580 | 57.96 57.95 | 189 | 610 | 57.68 57.68 |
| 714 | 417 | 300 | 635 | 635 | 58.39 | 133 | | | 580 | 57.95 57.97 | 201 | 600 | 57.69 |
| 712 | 418 | 250 | 570 | 570 | 58.58 | 89 | | | 570 | 58.01 | 202 | 000 | 01.00 |
| 704 | 418 | 150 | 460 | 460 | 59.07 | 0 | | | 460 | 58.39 | 137 | | |
| 468 | 324 | 500 | 690 | 655 | 57.94 | 96 | 675 | 57.70 | 470 | 57.99 | 96 | 480 | 57.68 |
| 435 | 317 | 400 | 550 | 550 | 58.54 | 34 | | | 470 | 57.96 | 96 | 480 | 57.73 |
| 412 | 323 | 300 | 410 | 410 | 59.18 | 0 | | | 410 | 58.17 | 68 | | |
| 404 | 321 | 250 | 350 | 350 | 59.33 | 0 | | | 350 | 58.60 | 34 | | |
| 394 | 315 | 150 | 240 | 240 | n/a | n/a | | | 240 | n/a | n/a | | |

LLImit at 415 MW min generation

330 MW extreme min gen - max LL (not at a transfer limit)



Table 7-4. LIL limits for loss of filter feeder - ML runbacks not active

| | | Loss of | Filter Feede | er | | |
|--------|-----|-----------------|--------------|-----|-----------------|------|
| Demand | MI | F/C Active (150 | MW) | | ML F/C Not Acti | ve |
| Demand | LIL | Freq Hz | UFLS | LIL | Freq Hz | UFLS |
| 2012 | 900 | 58.30 | 499 | 900 | 58.15 | 669 |
| 1892 | 900 | 58.26 | 464 | 900 | 58.13 | 626 |
| 1739 | 900 | 58.26 | 421 | 900 | 58.07 | 627 |
| 1492 | 900 | 58.19 | 479 | 900 | 58.03 | 541 |
| 1242 | 900 | 58.15 | 385 | 800 | 58.00 | 434 |
| 1021 | 880 | 58.01 | 333 | 700 | 58.00 | 332 |
| 782 | 770 | 58.04 | 223 | 580 | 58.06 | 222 |
| 640 | 710 | 58.07 | 160 | 520 | 58.05 | 159 |
| 504 | 640 | 58.07 | 96 | 450 | 58.07 | 96 |

LIL Limits with Cable Issues 7.3

In a scenario where a LIL cable fails to switch 5 minutes after a pole trip, the LIL power order will suddenly drop to 450 MW on the healthy pole. The system should not experience UFLS when the LIL drops its transfer down to 450 MW.

These LIL limits are provided in Table 7-5 for scenarios with the ML frequency controller active and not active to ensure the frequency stays above 59.1 Hz to provide a 0.3 Hz margin to the 58.8 Hz block of UFLS. Hydro's operators have only 5 minutes to re-enable the ML frequency controller after a ML runback, and therefore Hydro should take caution when operating to the limits in Table 6-5 assuming the ML frequency controller can be reactivated.

Given the relatively small range (~10-20 MW) of LIL limits over the large range of IIS demand and ML transfer, it is recommended for simplicity to use a fixed LIL limit for the cable failure scenario as follows:

- ML Frequency controller in-service: 667 MW LIL limit
- ML Frequency control out-of-service: 486 MW LIL limit



Table 7-5. LIL Limits for the Cable Switching Failure Contingency

| | J. LIL LIIII | | | | gFailur | | | |
|----------------|--------------------|----------------------|------------------------------------------|-----------------------------------|-------------------------|--------------------------------------|-------------------------------|----------------------------------|
| Demand (MW) | Generation (MW) | ML before runback | LILBP Transfer before pole trip | Infeed @ SOP before (MW) | LILIosses in MP (GR) | ML runback due to pole trip | MLafter initial Runback | Min Freq after UL-> 450 MW |
| | | | MLF/ | C Active (1 | 50 MW) | | | |
| 1904 | 1570 | 300 | 670 | 629.5 | 114.4 | 73.9 | 226.1 | 59.10 |
| 1758 | 1438 | 300 | 670 | 629.5 | 114.4 | 73.9 | 226.1 | 59.10 |
| 1509 | 1191 | 300 | 670 | 629.5 | 114.4 | 73.9 | 226.1 | 59.10 |
| 1247 | 926 | 300 | 675 | 633.9 | 115.9 | 74.9 | 225.1 | 59.10 |
| 1008 | 680 | 300 | 685 | 642.8 | 119.1 | 76.8 | 223.2 | 59.10 |
| 753 | 424 | 300 | 685 | 642.8 | 119.1 | 76.8 | 223.2 | 59.10 |
| 1899 | 1432 | 150 | 667 | 626.8 | 113.5 | 73.3 | 76.7 | 59.10 |
| 1752 | 1285 | 150 | 667 | 626.8 | 113.5 | 73.3 | 76.7 | 59.10 |
| 1502 | 1032 | 150 | 670 | 629.5 | 114.4 | 73.9 | 76.1 | 59.10 |
| 1240 | 764 | 150 | 680 | 638.4 | 117.5 | 75.8 | 74.2 | 59.10 |
| 998 | 522 | 150 | 680 | 638.4 | 117.5 | 75.8 | 74.2 | 59.10 |
| 739 | 418 | 150 | 500 | 476.7 | 67.8 | 44.5 | 105.5 | 59.43 |
| | | | MLF/0 | C not Active | (0 MW) | | | |
| 1907 | 1742 | 300 | 491 | 468.5 | 65.7 | 43.2 | 256.8 | 59.10 |
| 1760 | 1595 | 300 | 491 | 468.5 | 65.7 | 43.2 | 256.8 | 59.10 |
| 1522 | 1355 | 300 | 493 | 470.3 | 66.1 | 43.5 | 256.5 | 59.10 |
| 1258 | 1091 | 300 | 494 | 471.2 | 66.4 | 43.6 | 256.4 | 59.10 |
| 1011 | 842 | 300 | 497 | 474.0 | 67.1 | 44.1 | 255.9 | 59.10 |
| 750 | 583 | 300 | 493 | 470.3 | 66.1 | 43.5 | 256.5 | 59.10 |
| 1909 | 1594 | 150 | 491 | 468.5 | 65.7 | 43.2 | 106.8 | 59.10 |
| 1754 | 1449 | 150 | 491 | 468.5 | 65.7 | 43.2 | 106.8 | 59.10 |
| 1514 | 1199 | 150 | 491 | 468.5 | 65.7 | 43.2 | 106.8 | 59.10 |
| 1245 | 926 | 150 | 497 | 474.0 | 67.1 | 44.1 | 105.9 | 59.10 |
| 999 | 683 | 150 | 493 | 470.3 | 66.1 | 43.5 | 106.5 | 59.10 |
| 739 | 427 | 150 | 486 | 463.9 | 64.5 | 42.4 | 107.6 | 59.10 |

Min gen, not at a LILlimit

7.4 LIL Limits with 0 / 1 SOP SC

Previous Stage 4 operational studies have been performed to identify LIL operating restrictions when there is only one (1) or no (0) SOP synchronous condensers in-service.

Please refer to the previous study report for details - "Updated LIL Restrictions with 0 and 1 SOP Synchronous Condensers", TN1205.97.03, dated June 2, 2023.

7.5 **Stability Transfer Limits (Prior Outage TL201/TL217)**

Previous Stage 4 operational studies found that there is a stability limit on the TL201/TL217 corridor between WAV and SOP if there is a prior outage of either TL201 or TL217. During this prior outage, if the other line trips, the power flow is forced to flow via the underlying 138 kV transmission, which results in both thermal and stability limitations. The stability limit is a transient voltage violation, as shown in Figure 7-2.






Figure 7-2. Transient Voltage Criteria defines the stability limit – prior outage TL217, loss of TL201



The stability limits were revisited in the Stage 4F and were found to remain unchanged as listed in Table 7-6.

Table 7-6. Prior outage Stability Transfer Limits on TL201/TL217

| Demand (MW) | Stability / Transient voltage limit |
|-------------|----------------------------------------|
| | TL201/TL217 Flow (MW) |
| 1900** | 150 |
| 1750*** | 150 |
| 1500 | 155 |
| 1250 | 160 |
| 1000 | 165 |
| 750 | 133 |

^{*}not a stability limit (LIL at min)

7.6 315 kV Prior Outage Limits

Previous Stage 4 operational studies²⁶ determined LIL operating restrictions based on the Labrador end of the link. The 315 kV prior outage limits were revisited in the Stage 4F studies in order to test the frequency response at MFA and on the IIS to confirm the deadband settings for the LIL frequency controller for PFC and FLC modes of operation.

There are two parallel 315 kV lines connecting MFA to CHF. A prior outage of one of these 315 kV lines requires transfer limits on the remaining in-service 315 kV line in case it trips. These transfer limits depend on whether the LIL frequency controller is in-service or not, and which direction the power on the 315 kV line is flowing; MFA to CHF, or CHF to MFA. If the LIL frequency controller is in-service when there is a 315 kV prior outage, it is operating in "PFC" mode at MFA and the SOP end is operating in "FLC" mode.

If the remaining 315 kV line trips, the LIL becomes isolated with the MFA generators and the Happy Valley load area, and the following issues arise:

- Overfrequency if the 315 kV power transfer was in the direction from MFA to CHF
- Underfrequency if the 315 kV power transfer was in the direction from CHF to MFA
- The frequency at which the systems settle is not necessarily 60 Hz (observable in the upcoming Figures 7-3 through 7-6). This is because the LIL frequency controller at the MFA end (PFC) and at the SOP end (FLC) are giving opposing inputs which are summed and passed to the LIL frequency controller to add to the LIL power order. If for example, there is an underfrequency at MFA and the MFA units are already operating at maximum power output, the PFC (at MFA) will

²⁶ TGS report TN1205.79.02, "Stage 4C: Updates for Labrador Transfer Analysis", dated October 1, 2020. TGS report TN1205.66.09, "Stage 4C: Labrador Transfer Analysis", dated November 6, 2020.



^{**}HRD CT in-service @ 70 MW for minimum Avalon generation

^{***}HRD CT in- service @ 40 MW for minimum Avalon generation

ask the LIL to reduce transfer, however, reduced transfer will cause an underfrequency at SOP, which will cause the FLC (at SOP) to ask the LIL to increase transfer. Hence, with nothing set to control the frequency to 60 Hz, the system can settle out at off-nominal frequency. Hydro is currently investigating options to resolve this steady state frequency issue that may require further studies.

The 315 kV transfer limits are needed to ensure the frequency response at MFA is stable and remains between 57.5 Hz and 62.5 Hz²⁷ when LIL becomes isolated with HVY load to prevent MFA units from tripping on frequency protection. Additionally, when the LIL frequency controller at MFA (PFC mode) responds to changes in frequency at MFA, this will also affect the LIL power infeed at SOP, which then affect the IIS frequency, which can in turn causes the LIL frequency controller at SOP (FLC mode) to respond and oppose the modulation to the power order being requested by the MFA end. Therefore, the 315 kV transfer limits are also needed to ensure that the IIS frequency remains within the Transmission Planning criteria and that no UFLS occurs (i.e. frequency remains above 59.1 Hz).

7.6.1 LIL Frequency Controller in-service

When the LIL frequency controller is in-service and the LIL becomes isolated at the MFA end, the LIL frequency controller at MFA (PFC mode) will respond to the frequency changes at MFA, which modifies the LIL infeed at SOP and affects the IIS frequency, which in turn can result in the operation of the LIL frequency controller at SOP (FLC mode) as well. Therefore, the analysis for determining the 315 kV prior outage transfer limits involves ensuring that no UFLS occurs on the IIS, and therefore, the limits are also dependent on whether the ML frequency controller is in-service or not and IIS demand levels.

The 315 kV prior outage limits with the LIL frequency controller in-service are summarized in the following tables. Limits are provided for scenarios with 2, 3 and 4 MFA generators in-service:

- Table 7-7 LIL frequency controller in-service, 315 kV MFA-CHF direction
- Table 7-8- LIL frequency controller in-service, 315 kV CHF-MFA direction

Each table provides the following:

- 315 kV prior outage transfer limit for the given scenario
- LIL bipole steady state operating point (MW)
- LIL bipole maximum transient real power (MW) (includes impact of power order modulation from the frequency controller)
- LIL bipole steady state post-contingency real power (MW) (includes impact of power order modulation from the frequency controller)
- the limiting factor that determined the 315 kV transfer limit.

This information will help define the necessary LIL frequency controller settings.

²⁷ MFA generating unit protection is set to 57 Hz ad 63 Hz (with a delay). This study used criteria of maintaining isolated system frequency between 57.5 Hz and 62.5 Hz to ensure some margin to the protection settings.



7.6.1.1 315 kV MFA -> CHF Direction

When the power direction is from MFA to CHF, MFA experiences an overfrequency if the remaining 315 kV line trips, which results in the LIL frequency controller increasing the LIL power order in an attempt to reduce the overfrequency, which also causes an overfrequency on the IIS.

With the ML frequency controller in-service, the limiting factor that determined the 315 kV limits in the MFA to CHF direction is keeping the MFA frequency below 62.5 Hz. An example is shown in Figure 7-3, where there are 3 MFA units on-line @ 206 MW each, IIS demand is 1900 MW and the remaining 315 kV line is transferring 305 MW from MFA to CHF when it trips. Note that the 315 kV limits are marginally dependent on IIS demand when the ML frequency controller is in-service due to frequency impacts on the IIS. A similar trend in 315 kV limits vs IIS demand was observed as was discussed in Section 3.2 Figure 4-9.

With the ML frequency controller out-of-service, some of the scenarios were limited due to frequency decreasing below 59.1 Hz on the IIS. The same example used in Figure 7-3 is shown again in Figure 7-4, this time with the ML frequency controller out-of-service. Initially MFA experiences an overfrequency, which causes the LIL frequency controller to increase LIL transfer, which then results in an overfrequency on the IIS. The overfrequency on the IIS causes the LIL frequency controller at SOP to reduce the LIL transfer, which then results in an underfrequency as the frequency swings up/down as the system settles over time. Without the ML frequency controller active, the frequency swings on the IIS are larger and take longer to settle.



Table 7-7. 315 kV prior outage limits MFA->CHF – LIL Frequency controller in-service 315 kV Prior Outage - Transfer Limits (MFA-> CHF) - LIL FIC with PFC@MFA

| Number of | MEALoading | SII | ≅ | | | MLF/C in-service | service | | SI | | | MLF/C | MLF/C out-of-service | |
|----------------------|---------------------|--------------------------|--------------------|--------------------------|------------------------------|--------------------------|--------------------------------|--------------------------|--------------------|--------------|----------------------------|-----------------------------|----------------------|----------------------------------------|
| MFAunits on- line | | Demand (MM) | Generation (MM) | 315 kV limit | LIL Bipole (MW) steady state | LIL Bipole (MW)* maximum | LLEipole (MW)* Steady state | | Generation (MM) | 315 kV limit | LLBipole (MW) steady state | LIL Bipole (MW)* maximum | LIL Bipole (MW)* | |
| | | | | (MW) | pre-contingency | transient | post-contingency | Limitingfactor | | (MM) | pre-contingency | transient | post-contingency | Limitingfactor |
| | 506 | | 1461 | 273 | 465 | 821 | 669 | 62.5 Hz MFA | 1254 | 61 | 229 | 843 | 229 | dOS 7H 0.69 |
| | 150 | 1900 | 1823 | 415 | 100 | 838 | 378 | 62.5 Hz MFA | 1685 | 586 | 225 | 603 | 371 | 62.5 Hz MFA |
| | 103 | | 1834 | 386 | 06 | 602 | 374 | 62.5 Hz MFA | 1834 | 262 | 06 | 444 | 244 | 62.5 Hz MFA, 62.2 Hz SOP |
| | 506 | | 524 | 240 | 498 | 908 | 869 | 62.5 Hz MFA | 299 | 930 | 200 | 748 | 718 | 59.46 Hz SOP |
| 4 | 150 | 1000 | 827 | 322 | 192 | 610 | 382 | 62.5 Hz MFA | 989 | 186 | 328 | 9/9 | 408 | 62.5 Hz MFA |
| | 103 | | 940 | 230 | 06 | 474 | 286 | 62.5 Hz MFA | 861 | 166 | 161 | 387 | 249 | 62.5 Hz MFA |
| | 206 | | 464 | 258 | 480 | 810 | 869 | 62.5 Hz MFA | 420 | ষ্ঠ | 704 | 758 | 714 | dOS 7H E'69 |
| | 150 | 200 | 704 | 324 | 190 | 809 | 382 | 62.5 Hz MFA | 518 | 123 | 391 | 292 | 443 | dOS 7H 80'69 |
| | 103 | | 802 | 294 | 06 | 478 | 290 | 62.5 Hz MFA | 713 | 144 | 183 | 380 | 281 | 62.5 Hz MFA, 59.05 Hz SOP |
| | 506 | | 1700 | 305 | 220 | 999 | 504 | 62.5 Hz MFA, 62.1 Hz SOP | 1516 | 112 | 420 | 280 | 256 | 62.1 Hz MFA, 59 Hz SOP |
| | 150 | 1900 | 1836 | 383 | 06 | 929 | 370 | 62.5 Hz MFA, 62.1 Hz SOP | 1824 | 265 | 100 | 460 | 256 | 62.5 Hz MFA, 62.3 Hz SOP, 59.5 Hz SOP |
| | 103 | | 1836 | 361 | 06 | 614 | 376 | 62.5 Hz MFA, 62.1 Hz SOP | 1836 | 240 | 06 | 434 | 248 | 62.5 Hz MFA, 62.2 Hz SOP |
| | 206 | | 720 | 238 | 294 | 632 | 504 | 62.5 Hz MFA, 62.2 Hz SOP | 526 | 72 | 460 | 564 | 518 | 62.2 Hz MFA, SOP / 59.2 Hz SOP |
| e | 150 | 1000 | 937 | 291 | 06 | 504 | 280 | 62.5 Hz MFA, 62.1 Hz SOP | 828 | 175 | 190 | 440 | 276 | 62.5 Hz MFA, 62.4 Hz SOP / 59.2 Hz SOF |
| | 103 | | 937 | 272 | 06 | 486 | 288 | 62.5 Hz MFA, 62.1 Hz SOP | 937 | 158 | 06 | 314 | 178 | 62.5 Hz MFA, 62.3 Hz SOP |
| | 506 | | 427 | 242 | 290 | 089 | 205 | 62.5 Hz MFA | 431 | 38 | 492 | 265 | 514 | dOS 7H 0.65 |
| | 150 | 200 | 426 | 279 | 06 | 486 | 264 | 62.5 Hz MFA, 62.1 Hz SOP | 435 | 140 | 226 | 426 | 998 | 405 74 6'85 / 405 YJW 74 5'7 |
| | 103 | | 426 | 258 | 06 | 464 | 268 | 62.5 Hz MFA, 62.2 Hz SOP | 426 | 134 | 06 | 290 | 170 | 62.55 Hz MFA/59.5 Hz SOP |
| | 506 | | 1836 | 334 | 06 | 879 | 406 | 62.5 Hz MFA, 62.1 Hz SOP | 1813 | 217 | 110 | 474 | 906 | 408 4H Z 729 YHM 4H S 729 |
| | 150 | 1900 | 1836 | 361 | 06 | 089 | 384 | 62.5 Hz MFA, 62.1 Hz SOP | 1836 | 240 | 06 | 470 | 827 | 92.5 Hz MFA, 62.3 Hz SOP |
| | 103 | | 1836 | 348 | 06 | 682 | 386 | 62.5 Hz MFA, 62.1 Hz SOP | 1836 | 225 | 06 | 452 | 260 | 62.5 Hz MFA, 62.2 Hz SOP |
| | 206 | | 937 | 247 | 06 | 488 | 316 | 62.5 Hz MFA, 62.1 Hz SOP | 817 | 126 | 200 | 400 | 320 | 62.5 Hz MFA, SOP/ 59.1 Hz SOP |
| 2 | 150 | 1000 | 937 | 264 | 06 | 514 | 286 | 62.5 Hz MFA, 62.0 Hz SOP | 937 | 156 | 06 | 338 | 184 | 62.5 Hz MFA, 62.3 Hz SOP |
| | 103 | | 937 | 253 | 06 | 205 | 290 | 62.5 Hz MFA, 62.0 Hz SOP | 837 | 143 | 06 | 324 | 181 | 45.59 PAIN 44.5.29 |
| | 506 | | 418 | 229 | 86 | 468 | 306 | 62.5 Hz MFA | 434 | 99 | 260 | 392 | 310 | dOS 7H 0.65 |
| | 150 | 200 | 426 | 258 | 90 | 504 | 276 | 62.5 Hz MFA, 62.1 Hz SOP | 426 | 128 | 06 | 294 | 234 | 62.5 Hz MFA, 62.4 Hz SOP |
| | 103 | | 426 | 244 | 06 | 488 | 278 | 62.5 Hz MFA, 62.1 Hz SOP | 426 | 114 | 06 | 278 | 210 | 62.5 Hz MFA, 62.4 Hz SOP |
| * Included the | and the position of | and the last of the last | Illoday daniel | facous sounds as a sound | at the last | | | | | | | | | |




Figure 7-3. 3 MF units (206 MW), IIS demand 1900 MW, ML F/C in, Loss of L3101 @ 305 MW






Figure 7-4. 3 MF units (206 MW), IIS demand 1900 MW, ML F/C out, Loss of L3101 @ 112 MW



7.6.1.2 315 kV CHF -> MFA Direction

When the power direction is from CHF to MFA, MFA experiences an underfrequency if the remaining 315 kV line trips, which results in the LIL frequency controller decreasing the LIL power order in an attempt to mitigate the underfrequency, which also causes an underfrequency on the IIS.

Whether the ML frequency controller is in-service or out-of-service, the limiting factor that determined the 315 kV limits in the CHF to MFA direction is keeping the SOP frequency above 59 Hz to avoid UFLS. However, the 315 kV transfer limits are significantly less if the ML frequency controller is not in-service. An example is shown in Figure 7-528, in which 2 MFA units are in-service at 206 MW each, IIS demand is 1000 MW, ML frequency controller is in-service, and the remaining 315 kV line is transferring 190 MW before it trips. The same scenario with the ML frequency controller out-of-service is shown in Figure 7-6, in which case the remaining 315 kV line was only transferring 45 MW before it trips.

Please also note that when the ML frequency controller is in-service, the 315 kV limits are marginally dependent on IIS demand due to frequency impacts in the IIS. A similar trend in 315 kV limits vs IIS demand was observed as was discussed in Section 3.2 Figure 4-9.

²⁸ As noted in Section 7.6, the frequency at which the systems settle in Figure 7-5 is necessarily 60 Hz. This is because the LIL frequency controller at the MFA end (PFC) and at the SOP end (FLC) are giving opposing inputs which are summed and passed to the LIL frequency controller to add to the LIL power order. If for example, there is an underfrequency at MFA and the MFA units are already operating at maximum power output, the PFC (at MFA) will ask the LIL to reduce transfer, however, reduced transfer will cause an underfrequency at SOP, which will cause the FLC (at SOP) to ask the LIL to increase transfer. Hence, with nothing set to control the frequency to 60 Hz, the system can settle out at off-nominal frequency. Hydro is currently investigating options to resolve this steady state frequency issue that may require further studies.



Table 7-8. 315 kV prior outage limits CHF->MFA – LIL Frequency controller in-service 315 kV Prior Outage - Transfer Limits (CHF-> MFA) - LIFIC with PFC@MFA

| | | | | | | 211111 | ا حمدها - المال | SIS VATIO CALAGE - II aliste Dilling (Ali + III A - PEI/O WILLI CAMPA | , h | | | | | |
|----------------------|-----------------------------------------------------|----------------|--------------------|----------------------|--------------------|----------------------------|-------------------------------|-----------------------------------------------------------------------|--------------------|--------------|---------------------------------|----------------------------|-------------------------------|----------------|
| Number of | MEAL SOCIES | SI | S | | | MLF/Cin-service | service | | S | | | MLF/C | MLF/C out-of-service | |
| MFAunits on- line | | Demand (MW) | Generation (MW) | 315 kV limit | | UL Bipole (MW)* maximum | ULBpole (MW)* Steady state | | Generation (MW) | 315 KV limit | LIL Bipole (MW) steady state | LILBipole (MW)* maximum | LIL Bipole (MW)* Steady state | |
| | | | | (MW) | pre-contingency | transient | post-contingency | Limitingfactor | | (MM) | pre-contingency | transient | post-contingency | Limitingfactor |
| | 206 | | 1055 | 183 | 206 | 208 | 728 | 58.7 Hz MFA, 59.0 Hz SOP | 1172 | 35 | 773 | 67.2 | 749 | 408 4H 0.69 |
| | 150 | 1900 | 1205 | 221 | 736 | 482 | 929 | G9.0 Hz SOP | 1350 | 73 | 282 | 523 | 285 | 59.0 Hz SOP |
| | 103 | | 1388 | 211 | 238 | 280 | 410 | 59.0 Hz SOP | 1527 | 73 | 400 | 332 | 400 | 59.0 Hz SOP |
| | 506 | | 914 | 199 | 305 | 989 | 710 | 58.7 Hz MFA, 59.0 Hz SOP | 1022 | 40 | 8// | 728 | 748 | 59.0 Hz SOP |
| | 150 | 1500 | 955 | 218 | 733 | 489 | 627 | 59.0 Hz SOP | 1184 | 82 | 286 | 540 | 296 | G9.0 Hz SOP |
| , | 103 | | 1134 | 208 | 535 | 317 | 413 | 59.0 Hz SOP | 1368 | 78 | 405 | 333 | 403 | G9.0 Hz SOP |
| 4 | 206 | L | 437 | 204 | 305 | 682 | 902 | 58.7 Hz MFA, 59.0 Hz SOP | 540 | 35 | 773 | 67.2 | 749 | 59.0 Hz SOP |
| | 150 | 1000 | 454 | 232 | 747 | 479 | 631 | GS 2H 0.65 | 989 | 8 | 268 | 542 | 298 | 59.0 Hz SOP |
| | 103 | | 625 | 220 | 547 | 279 | 413 | 59.0 Hz SOP | 864 | 78 | 405 | 343 | 401 | 59.0 Hz SOP |
| | 506 | | | Lat max, p | owerflow still MFA | >CHF | | | | | | | | |
| | 150 | 200 | 309 | 251 | 992 | 468 | 628 | 58.75 Hz MFA, 59.03 Hz SOP | 451 | 09 | 575 | 215 | 275 | 59.0 Hz SOP |
| | 103 | | 429 | 526 | 223 | 277 | 413 | dOS 7H 0.69 | 603 | 99 | 333 | 342 | 393 | dOS 2H 0.69 |
| | 506 | | 1249 | 149 | 681 | 203 | 535 | dOS 7H 0.69 | 1355 | 38 | 220 | ZZS | 236 | 95.0 H2 SOP |
| | 150 | 1900 | 551 | 218 | 283 | 323 | 451 | 408 7H 0.69 | 1496 | 99 | 430 | 998 | 430 | 59.0 Hz SOP |
| | 103 | | 069 | 207 | 431 | 195 | 291 | dOS 7H 0.69 | 1654 | 26 | 283 | 572 | 281 | 95.0 Hz SOP |
| | 506 | | 926 | 185 | 718 | 205 | 542 | dOS 7H 0.69 | 1071 | 33 | 2002 | 272 | 539 | 95.0 Hz SOP |
| | 150 | 1500 | 1065 | 205 | 220 | 302 | 450 | dOS 7H 0.69 | 1198 | 62 | 427 | 696 | 427 | 95.0 HS SOP |
| r | 103 | | 1223 | 191 | 415 | 197 | 287 | dOS 7H 0.69 | 1349 | 22 | 281 | 522 | 277 | dOS 2H 0.69 |
| n | 206 | | 428 | 193 | 724 | 474 | 530 | 59.0 Hz SOP | 461 | 35 | 999 | 920 | 536 | G9.0 Hz SOP |
| | 150 | 1000 | 449 | 216 | 280 | 288 | 450 | dOS 7H 0.69 | 585 | 89 | 432 | 998 | 432 | 95.0 Hz SOP |
| | 103 | | 587 | 207 | 430 | 170 | 290 | 59.0 Hz SOP | 725 | 99 | 230 | 240 | 290 | 40S ZH 0.69 |
| | 206 | | 319 | 219 | 752 | 468 | 534 | 59.7 Hz MFA, 59.0 Hz SOP | 440 | 26 | 228 | 225 | 536 | 90.0 Hz SOP |
| | 150 | 200 | 430 | 236 | 009 | 292 | 452 | dOS 7H 0.69 | 443 | 22 | 420 | 896 | 420 | 4OS 7H 0.65 |
| | 103 | | 437 | 216 | 440 | 156 | 290 | 40S7H0765 | 443 | 20 | 274 | 242 | 274 | G9.0 Hz SOP |
| | 206 | | 1424 | 173 | 200 | 256 | 330 | dOS 7H 0.69 | 1556 | 46 | 372 | 318 | 330 | 4OS 7H 0.69 |
| | 150 | 1900 | 1517 | 194 | 409 | 159 | 275 | dOS 7H 0.69 | 1624 | 28 | 273 | 212 | 569 | 36.0 Hz SOP |
| | 103 | | 1632 | 181 | 305 | 98 | 166 | dOS 7H 0.69 | 1641 | 53 | 174 | 122 | 160 | 4OS 7H 0.69 |
| | 206 | | 1041 | 165 | 492 | 264 | 324 | dOS 7H 0.69 | 1162 | 37 | 363 | 319 | 327 | 4OS 7H 0.65 |
| | 150 | 1500 | 1131 | 189 | 404 | 164 | 272 | dOS 7H 0.69 | 1258 | 28 | 273 | 219 | 265 | 36.0 Hz SOP |
| · | 103 | | 1221 | 185 | 306 | 98 | 162 | 99.0 Hz SOP | 1365 | 22 | 178 | 122 | 160 | 59.0 Hz SOP |
| ٧ | 206 | | 202 | 190 | 516 | 278 | 328 | dOS 7H 0.69 | 645 | 45 | 370 | 320 | 330 | 36.0 Hz SOP |
| | 150 | 1000 | 009 | 202 | 416 | 148 | 276 | 59.0 Hz SOP | 735 | 65 | 280 | 218 | 280 | 59.0 Hz SOP |
| | 103 | | 697 | 196 | 317 | 66 | 167 | 59.0 Hz SOP | 839 | 26 | 180 | 124 | 180 | 59.0 Hz SOP |
| | 206 | | 452 | 195 | 520 | 220 | 320 | 59.0 Hz SOP | 437 | 27 | 352 | 324 | 332 | 59.0 Hz SOP |
| | 150 | 200 | 441 | 215 | 430 | 128 | 280 | 59.0 Hz SOP | 432 | 47 | 262 | 222 | 262 | 59.0 Hz SOP |
| | 103 | _ | 431 | 200 | 320 | 20 | 168 | 40S 7H 0.69 | 420 | 43 | 164 | 124 | 164 | 59.0 Hz SOP |
| * Includes im | Includes impact of power order modulation by the UI | rder modu | lation by the I II | frequency controller | wtmler | | | | | | | | | |




Figure 7-5. 2 MFA units (206 MW), IIS demand 1000 MW, ML F/C in, Loss of L3101 @ 190 MW




Figure 7-6. 2 MFA units (206 MW), IIS demand 1000 MW, ML F/C out, Loss of L3101 @ 45 MW

7.6.2 LIL Frequency Controller out-of-service

When the LIL frequency controller is not in-service and the LIL becomes isolated at MFA, the IIS system no longer impacts the 315 kV limits, and the MFA generators are the only factor affecting the frequency response at MFA. The limiting factors are overfrequency at MFA if prior outage 315 kV power flow direction is from MFA to CHF, and underfrequency at MFA if prior outage 315 kV power flow direction is from CHF to MFA. The MFA unit frequency protection defines the allowable frequency levels, since tripping all MFA units will have a negative impact on both the Island and Labrador systems; given the LIL would also trip.

The 315 kV prior outage limits without the LIL frequency controller are summarized in the following tables. Limits are provided for scenarios with 2, 3 and 4 MFA generators in-service, at low and high HVY load scenarios and with the power system stabilizers (PSSes) on the MF units in and out-of-service:

- Table 7-9 LIL frequency controller out-of-service, 315 kV MFA-CHF direction
- Table 7-10 LIL frequency controller out-of-service, 315 kV CHF-MFA direction

The following observations were made:

- When operating in isolated mode, the PSSes on the MF units made the response of the MFA generators significantly less stable compared to the cases with the PSSes out-of-service. Examples are shown in Figure 7-7 (MFA->CHF) and Figure 7-8 (CHF->MFA) to overlay the responses with the PSS in (blue plots) and PSS out (green plots). Based on these results it is recommended to disable the PSSes if the LIL and MFA units are isolated together when the LIL frequency controller is not in-service. Alternatively, the PSSes should be better tuned for this isolated mode of operation. It is therefore recommended to perform a PSS tuning study.
- The 315 kV transfer limit is 0 MW (or very small in some cases) if the MFA units are operated at full power rating of 206 MW. Therefore, some amount of room is needed on the MFA units to be able to respond to frequency changes at MFA if the remaining 315 kV line trips. This study tested MF units loaded at 103 MW (minimum generation), 150 MW and 206 MW (maximum generation).
- The 315 kV transfer limits are slightly lower with lower HVY load (e.g. 15 MW vs 80 MW load).



Table 7-9. 315 kV prior outage limits MFA->CHF – LIL Frequency controller out-of-service

| 31 | 315 kV Prior Outage - Transfer Limits (MFA -> CHF) - LIL F/C out-of-service | | | | | | | | | |
|--------------------|-----------------------------------------------------------------------------|------------------|-------------------|----------------|-------------------|----------------|--|--|--|--|
| Number of MFAunits | MFA Loading (MW) | HVY Load (MW) | PSS | Sin | PSS | out | | | | |
| on-line | () | () | 315 kV limit (MW) | Limitingfactor | 315 kV limit (MW) | Limitingfactor | | | | |
| | 206 | | 6 | 62.5 Hz MFA | 4 | 62.5 Hz MFA | | | | |
| | 150 | 80 | 50 | 57.5 Hz MFA | 60 | 62.5 Hz MFA | | | | |
| 4 | 103 | | 40 | 62.5 Hz MFA | 51 | 62.5 Hz MFA | | | | |
| 4 | 206 | | 9 | instability | 9 | instability | | | | |
| | 150 | 15 | 41 | 57.5 Hz MFA | 58 | 62.5 Hz MFA | | | | |
| | 103 | | 36 | 62.5 Hz MFA | 49 | 62.5 Hz MFA | | | | |
| | 206 | | ~2 | 62.5 Hz MFA | ~2 | 62.5 Hz MFA | | | | |
| | 150 | 00 | 24 | 57.5 Hz MFA | 47 | 62.5 Hz MFA | | | | |
| | 76.5 | 80 | 51 | 62.5 Hz MFA | 55 | 62.5 Hz MFA | | | | |
| 3 | 103 | | 31 | 62.5 Hz MFA | 35 | 62.5 Hz MFA | | | | |
| | 206 | | ~4 | 62.5 Hz MFA | ~4 | 62.5 Hz MFA | | | | |
| | 150 | 15 | 27 | 57.5 Hz MFA | 46 | 62.5 Hz MFA | | | | |
| | 103 | | 25 | 57.5 Hz MFA | 37 | 62.5 Hz MFA | | | | |
| | 206 | | ~4 | 62.5 Hz MFA | ~4 | 62.5 Hz MFA | | | | |
| | 150 | 80 | 22 | 57.5 Hz MFA | 31 | 62.5 Hz MFA | | | | |
| 2 | 103 | | 23 | 62.5 Hz MFA | 25 | 62.5 Hz MFA | | | | |
| | 206 | | ~3 | 57.5 Hz MFA | ~3 | 62.5 Hz MFA | | | | |
| | 150 | 15 | 20 | 57.5 Hz MFA | 30 | 62.5 Hz MFA | | | | |
| | 103 | | 19 | 62.5 Hz MFA | 24 | 62.5 Hz MFA | | | | |

Table 7-10. 315 kV prior outage limits CHF->MFA - LIL Frequency controller out-of-service

| 31 | 315 kV Prior Outage - Transfer Limits (CHF -> MFA) - LIL F/C out-of-service | | | | | | | | |
|--------------------|-----------------------------------------------------------------------------|------------------|-------------------|----------------|-------------------|----------------|--|--|--|
| Number of MFAunits | MFA Loading (MW) | HVY Load (MW) | PSS | Bin | PSS out | | | | |
| on-line | ` ' | , , | 315 kV limit (MW) | Limitingfactor | 315 kV limit (MW) | Limitingfactor | | | |
| | 206 | | 0 | instability | 0 | instability | | | |
| | 150 | 80 | 65 | 57.5 Hz MFA | 57 | 57.5 Hz MFA | | | |
| 4 | 103 | | 73 | 57.5 Hz MFA | 54 | 57.5 Hz MFA | | | |
| 4 | 206 | | 0 | instability | 0 | instability | | | |
| | 150 | 15 | 55 | 57.5 Hz MFA | 51 | 57.5 Hz MFA | | | |
| | 103 | | 66 | 57.5 Hz MFA | 53 | 57.5 Hz MFA | | | |
| | 206 | | 9 | instability | 0 | instability | | | |
| | 150 | 80 | 57 | 57.5 Hz MFA | 45 | 57.5 Hz MFA | | | |
| 3 | 103 | | 53 | 57.5 Hz MFA | 41 | 57.5 Hz MFA | | | |
| 5 | 206 | | 0 | instability | 0 | instability | | | |
| | 150 | 15 | 56 | 57.5 Hz MFA | 43 | 57.5 Hz MFA | | | |
| | 103 | | 54 | 57.5 Hz MFA | 39 | 57.5 Hz MFA | | | |
| | 206 | | 0 | instability | 0 | instability | | | |
| | 150 | 80 | 46 | 57.5 Hz MFA | 31 | 57.5 Hz MFA | | | |
| 2 | 103 | | 37 | 57.5 Hz MFA | 29 | 57.5 Hz MFA | | | |
| - | 206 | | 0 | instability | 0 | instability | | | |
| | 150 | 15 | 43 | 62.5 Hz MFA | 30 | 57.5 Hz MFA | | | |
| | 103 | | 36 | 57.5 Hz MFA | 29 | 57.5 Hz MFA | | | |




Figure 7-7. MFA->CHF, LIL F/C out, 3 MFA units (150 MW): PSS in: Blue, PSS out: Green






Figure 7-8. MFA->CHF, LIL F/C out, 3 MFA units (150 MW): PSS in: Blue, PSS out: Green



7.7 Maximum Generator Unit Loading

Loss of a generator should not result in UFLS, therefore, the maximum generator unit loading was determined such that the IIS frequency does not drop below 59.1 Hz, leaving a 0.3 Hz margin to UFLS (58.8 Hz).

Maximum generator unit loading was determined for the following scenarios, with IIS demand ranging from peak to extreme light conditions:

- LIL frequency controller out-of-service
 - o ML frequency controller in-service
 - ML frequency control out-of-service
- · LIL frequency controller in- service
 - ML frequency controller in-service
 - ML frequency control out-of-service

7.7.1 LIL Frequency controller out-of-service

With the LIL frequency controller out-of-service, the maximum generator unit loading is determined mainly by the status of the ML frequency controller. The IIS demand level has a much smaller impact.

- With the ML frequency controller in-service, the maximum generator unit loading ranges from 157 MW to 165 MW.
- With the ML frequency controller out-of-service, the maximum generator unit loading ranges from 25 to 36 MW.

The maximum generator unit loading with the LIL frequency controller is out-of-service is summarized in Table 7-11. These tables should be used to define the limitations around the amount of frequency response that can be provided to Nova Scotia by the ML frequency controller.



Table 7-11. Maximum generator unit loading - LIL F/C out of service

| LILF/C Out-of-Service | | | | | | | | | |
|--------------------------------|------------|---------------|---------------|--|--|--|--|--|--|
| Maximum Generator Unit Loading | | | | | | | | | |
| Demand | Generation | Max Gen | Min frequency | | | | | | |
| (MW) | (MW) | loading (MW) | ` , | | | | | | |
| MLF/C Active (150 MW) | | | | | | | | | |
| 2014 | 1336 | 165 | 59.1 | | | | | | |
| 1900 | 1244 | 165 | 59.1 | | | | | | |
| 1749 | 1115 | 165 | 59.1 | | | | | | |
| 1502 | 929 | 165 | 59.1 | | | | | | |
| 1243 | 758 | 165 | 59.1 | | | | | | |
| 1002 | 597 | 159 | 59.1 | | | | | | |
| 740 | 586 | 158 | 59.1 | | | | | | |
| 435 | 548 | 157 | 59.1 | | | | | | |
| | MLF/Cir | nactive (0 MV | (> | | | | | | |
| 2014 | 1336 | 28 | 59.1 | | | | | | |
| 1900 | 1244 | 30 | 59.1 | | | | | | |
| 1749 | 1115 | 29 | 59.1 | | | | | | |
| 1502 | 929 | 36 | 59.1 | | | | | | |
| 1243 | 758 | 30 | 59.1 | | | | | | |
| 1002 | 597 | 25 | 59.1 | | | | | | |
| 742 | 438 | 28 | 59.1 | | | | | | |
| 423 | 434 | 31 | 59.1 | | | | | | |

7.7.2 LIL Frequency controller in-service

With the LIL frequency controller in-service, the maximum generator unit loading is determined mainly by:

- the status of the ML frequency controller
- LIL reserve²⁹

The IIS demand level has a small impact, with the maximum generator unit loading being slightly less at lower demand than higher demand.

The maximum generator unit loading with the LIL frequency controller is in-service is summarized in Table 7-12 for LIL reserve starting from 100 MW up to 350 MW (450 MW for lighter demand cases) in steps of 50 MW.

²⁹ The amount the LIL can increase up to its capacity (or limit) when providing frequency support.

Table 7-12. Maximum generator unit loading - LIL F/C in service

| Table 7- | | | ∐LF/Cli | n-Service | | |
|--------------------------------------------------------------------|---------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|--------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------|
| | MI | _F/CInac | tive | V | LF/CActi | ve |
| LIL Reserve (MW) | Max Gen loading (MW) | Min frequency (Hz) | Additional MW Beyond LIL reserve (MW) | Max Gen loading (MW) | Min frequency (Hz) | Additional MW Beyond LIL reserve (MW) |
| | 2000 MV | V Demand | | 20 | 000 MW Dema | and |
| 100 | 122 | 59.1 | 22 | 255 | 59.1 | 155 |
| 150 | 170 | 59.1 | 20 | 296 | 59.1 | 146 |
| 200 | 215 | 59.1 | 15 | 331 | 59.1 | 131 |
| 250 | 250 | 59.1 | 0 | 371 | 59.1 | 121 |
| 300 | 280 | 59.1 | -20 | 411 | 59.1 | 111 |
| 350 | 319 | 59.1 | -31 | 434 | 59.1 | 84 |
| | | V Demand | | | 750 MW Dema | |
| 100 | 120 | 59.1 | 20 | 250 | 59.1 | 150 |
| 150 | 166 | 59.1 | 16 | 290 | 59.1 | 140 |
| 200 | 210 | 59.1 | 10 | 333 | 59.1 | 133 |
| 250 | 240 | 59.1 | -10 | 374 | 59.1 | 124 |
| 300 | 277 | 59.1 | -23 | 414 | 59.1 | 114 |
| 350 | 323 | 59.1 | -27 | 436 | 59.1 | 86 |
| | 1500 MV | V Demand | | 1: | 500 MW Dema | and |
| 100 | 113 | 59.1 | 13 | 245 | 59.1 | 145 |
| 120 | 136 | 59.1 | 16 | 260 | 59.1 | 140 |
| 150 | 158 | 59.1 | 8 | 285 | 59.1 | 135 |
| 200 | 201 | 59.1 | 1 | 320 | 59.1 | 120 |
| 250 | 235 | 59.1 | -15 | 365 | 59.1 | 115 |
| 300 | 277 | 59.1 | -23 | 404 | 59.1 | 104 |
| 350 | 315 | 59.1 | -35 | 430 | 59.1 | 80 |
| | 1250 MV | V Demand | | 1: | 250 MW Dema | |
| 100 | 103 | 59.1 | 3 | 225 | 59.1 | 125 |
| 150 | 145 | 59.1 | -5 | 263 | 59.1 | 113 |
| 200 | 189 | 59.1 | -11 | 310 | 59.1 | 110 |
| 250 | 222 | 59.1 | -28 | 345 | 59.1 | 95 |
| 300 | 266 | 59.1 | -34 | 385 | 59.1 | 85 |
| 350 | 310 | 59.1 | -40 | 415 | 59.1 | 65 |
| 100 | | V Demand | | | 000 MW Dema | |
| 100 | 102 | 59.1 | 2 | 210 | 59.1 | 110 |
| 150 | 142 | 59.1 | -8 -34 | 244 | 59.1 | 94 |
| 200 250 | 166 220 | 59.1 59.1 | -34 -30 | 280 330 | 59.1 59.1 | 80 80 |
| 300 | 248 | 59.1 | -50 -52 | | 59.1 59.1 | 63 |
| | 240 | υσ. i | | 303 | JJ. I | ω |
| 350 | 287 | 50.1 | | 363 385 | 50.1 | 35 |
| 350 400 | 287 311 | 59.1 59.1 | -63 | 385 | 59.1 59.1 | 35 0 |
| 400 | 311 | 59.1 | -63 -89 | 385 400 | 59.1 | 0 |
| | 311 348 | 59.1 59.1 | -63 | 385 400 440 | 59.1 59.1 | 0 -10 |
| 400 | 311 348 | 59.1 59.1 / Demand | -63 -89 | 385 400 440 7 | 59.1 | 0 -10 |
| 400 450 | 311 348 750 MW | 59.1 59.1 | -63 -89 -102 | 385 400 440 | 59.1 59.1 50 MW Dema | 0 -10 nd |
| 400 450 100 | 311 348 750 MW | 59.1 59.1 / Demand 59.1 | -63 -89 -102 -3 | 385 400 440 7 205 | 59.1 59.1 50 MW Dema 59.1 | 0 -10 nd 105 |
| 400 450 100 150 | 311 348 750 MW 97 132 | 59.1 59.1 / Demand 59.1 59.1 | -63 -89 -102 -3 -18 | 385 400 440 7 205 230 | 59.1 59.1 50 MW Dema 59.1 59.13 | 0 -10 nd 105 80 |
| 400 450 100 150 200 | 311 348 750 MM 97 132 166 | 59.1 59.1 /Demand 59.1 59.1 59.1 | -63 -89 -102 -3 -18 -34 | 385 400 440 7 205 230 260 | 59.1 59.1 50 MW Dema 59.1 59.13 59.1 | 0 -10 nd 105 80 60 |
| 400 450 100 150 200 250 | 311 348 750 MM 97 132 166 210 | 59.1 59.1 / Demand 59.1 59.1 59.1 | -63 -89 -102 -3 -18 -34 -40 | 385 400 440 7 205 230 260 310 | 59.1 59.1 50 MW Dema 59.1 59.13 59.1 59.1 | 0 -10 nd 105 80 60 |
| 400 450 100 150 200 250 300 | 311 348 750 MM 97 132 166 210 232 | 59.1 59.1 / Demand 59.1 59.1 59.1 59.1 59.1 | -63 -89 -102 -3 -18 -34 -40 -68 | 385 400 440 7 205 230 260 310 338 | 59.1 59.1 50 MW Dema 59.1 59.13 59.1 59.1 59.1 | 0 -10 nd 105 80 60 60 38 |
| 400 450 100 150 200 250 300 350 | 311 348 750 MW 97 132 166 210 232 272 | 59.1 59.1 / Demand 59.1 59.1 59.1 59.1 59.1 59.1 | -63 -89 -102 -3 -18 -34 -40 -68 -78 | 385 400 440 7 205 230 260 310 338 358 | 59.1 59.1 50 MW Dema 59.1 59.1 59.1 59.1 59.1 59.1 | 0 -10 nd 105 80 60 60 38 8 |
| 400 450 100 150 200 250 300 350 400 | 311 348 750 MM 97 132 166 210 232 272 295 325 | 59.1 59.1 / Demand 59.1 59.1 59.1 59.1 59.1 59.1 59.1 | -63 -89 -102 -3 -18 -34 -40 -68 -78 -105 | 385 400 440 7 205 230 260 310 338 358 383 410 | 59.1 59.1 50 MW Dema 59.1 59.13 59.1 59.1 59.1 59.1 59.1 | 0 -10 nd 105 80 60 60 38 8 -17 -40 |
| 400 450 100 150 200 250 300 350 400 | 311 348 750 MM 97 132 166 210 232 272 295 325 | 59.1 59.1 / Demand 59.1 59.1 59.1 59.1 59.1 59.1 59.1 59.1 | -63 -89 -102 -3 -18 -34 -40 -68 -78 -105 | 385 400 440 7 205 230 260 310 338 358 383 410 | 59.1 59.1 59.1 59.1 59.1 59.1 59.1 59.1 | 0 -10 nd 105 80 60 60 38 8 -17 -40 |
| 400 450 100 150 200 250 300 350 400 450 | 311 348 750 MM 97 132 166 210 232 272 295 325 450 MM | 59.1 59.1 / Demand 59.1 59.1 59.1 59.1 59.1 59.1 59.1 59.1 | -63 -89 -102 -3 -18 -34 -40 -68 -78 -105 -125 | 385 400 440 7 205 230 260 310 338 358 383 410 | 59.1 59.1 59.1 59.13 59.1 59.1 59.1 59.1 59.1 59.1 59.1 59.1 | 0 -10 nd 105 80 60 60 38 8 -17 -40 |
| 400 450 100 150 200 250 300 350 400 450 | 311 348 750 MM 97 132 166 210 232 272 295 325 450 MM | 59.1 59.1 / Demand 59.1 59.1 59.1 59.1 59.1 59.1 59.1 59.1 | -63 -89 -102 -3 -18 -34 -40 -68 -78 -105 -125 | 385 400 440 7 205 230 260 310 338 358 383 410 | 59.1 59.1 59.1 59.1 59.1 59.1 59.1 59.1 | 0 -10 nd 105 80 60 60 38 8 -17 -40 nd |

Min gen is limiting - not at max generator unit loading

APPENDIX 1

FINAL UFLS SCHEME


| | | ******* | | | | | _ | | | | | | | | | |
|---------|------------------|--------------|--------------|-------------------|--------------------|-------------|----------------|--------------|----------------|---------------------|--------------------------|--|--------------|----------------|----------------------|--------|
| ****** | ****** | ******** | | ******** | | | ******** | ****** | ****** | ****** | | | ************ | UFLS | | SSEBus |
| | UFLS | %for | | block Frequenc | / 58.2 Hz | | UFLS | %for | | zblock Frequency | / 58.8 Hz PSSE | | (MW) | Frequency (Hz) | # | |
| | (MW) | UFLS | Total MW | | Bus# | | (MW) | UFLS | Total MW | (Hz) | Bus# | | 6.6 | 58.6 | 95432,'L | |
| | 11.575 | 0.25 | 46.3 | 58.2 | 196574, | | 9.723 | 0.21 | 46.3 | | 196574 | | 4.8 | | 95404,'L | |
| | 6.945 2.725 | 0.15 0.05 | 46.3 54.5 | 58.2 58.2 | 196574, 196567, | | 7.408 4.72 | 0.16 0.1 | 46.3 47.2 | | 196574 196572 | | 5 2.6 | | 15407,'L 15435,'L | |
| | 5.995 | 0.03 | 54.5 | 58.2 | 196567, | | 3.776 | 0.08 | 47.2 | | 196572 | | 3 | | 5436,'L | |
| | 6.54 | 0.12 | 54.5 | 58.2 | 196567, | | 3.776 | 0.08 | 47.2 | | 196572 | | 7.7 | | 5437,'L | |
| | 3.878 | 0.14 | 27.7 | 58.2 | 196566, | | 5.691 | 0.21 | 27.1 | | 196571 | | 29.7 M | | | |
| | 4.432 4.501 | 0.16 0.07 | 27.7 64.3 | 58.2 58.2 | 196566, 196563, | | 5.149 6.54 | 0.19 | 27.1 54.5 | | 196571, 196567. | | | | | |
| | 5.787 | 0.09 | 64.3 | 58.2 | 196563, | | 8.359 | 0.12 | 64.3 | | 196563 | | | | | |
| | 10.438 | 0.34 | 30.7 | 58.2 | 196562, | | 3.215 | 0.05 | 64.3 | 58.8 | 196563 | | | | | |
| | 5.775 | 0.15 | 38.5 | 58.2 | 196546, | | 13.188 | 0.21 | 62.8 | | 196561, | | | | | |
| | 1.925 4.62 | 0.05 0.12 | 38.5 38.5 | 58.2 58.2 | 196546, 196546, | | 7.656 4.776 | 0.29 | 26.4 59.7 | | 196560, 196556, | | | | | |
| | 0.781 | 0.11 | 7.1 | 58.2 | 196517, | | 2.394 | 0.19 | 12.6 | | 196540 | | | | | |
| | 2.556 | 0.36 | 7.1 | 58.2 | 196517, | | 1.917 | 0.27 | 7.1 | | 196517 | | | | | |
| | 15.248 16.201 | 0.16 0.17 | 95.3 95.3 | 58.2 58.2 | 195655, 195655, | | 8.052 6.396 | 0.33 | 24.4 16.4 | | 196500, 196221, | | | | | |
| | 5.12 | 0.17 | 102.4 | 58.2 | 195624, | | 10.483 | 0.39 | 95.3 | | 195655 | | | | | |
| | 1.496 | 0.11 | 13.6 | 58.2 | 195169, | | 7.152 | 0.12 | 59.6 | | 195635 | | | | | |
| | 6.36 | 0.3 | 21.2 | 58.2 | 195134, | | 5.805 | 0.43 | 13.5 | | 195169 | | | | | |
| | 4.876 2.702 | 0.23 | 21.2 19.3 | 58.2 58.2 | 195134, 195132, | | 6.125 3.675 | 0.25 | 24.5 24.5 | | 195167, 195167, | | | | | |
| | 2.316 | 0.14 | 19.3 | 58.2 | 195132, | | 5.376 | 0.15 | 67.2 | | 195144 | | | | | |
| | 4.438 | 0.14 | 31.7 | 58.2 | 195130, | | 2.016 | 0.03 | 67.2 | 58.8 | 195144 | | | | | |
| | 7.925 | 0.25 | 31.7 | 58.2 | 195130, | | 3.6 | 0.15 | 24 | | 195127 | | | | | |
| | 9.555 8.645 | 0.21 | 45.5 45.5 | 58.2 58.2 | 195126, 195126, | | 3.84 8.645 | 0.16 | 24 45.5 | | 195127, 195126, | | | | | |
| @58.21 | 163.355 N | 5.15 | .0.0 | 30.2 | .50120, | | 1.957 | 0.19 | 10.3 | | 195120 | | | | | |
| | | | | | / 58.1 Hz | MW @58.8 Hz | | | | | | | | | | |
| | 8.797 | 0.19 | 46.3 | 58.1 | 196574, | | 2.050 | 0.00 | 45.0 | | / 58.6 Hz | | | | | |
| | 8.076 7.403 | 0.12 0.11 | 67.3 67.3 | 58.1 58.1 | 196573, 196573, | | 3.952 4.248 | 0.26 | 15.2 47.2 | | 196576, 196572 | | | | | |
| | 8.749 | 0.13 | 67.3 | 58.1 | 196573, | | 4.72 | 0.03 | 47.2 | | 196572 | | | | | |
| | 8.076 | 0.12 | 67.3 | 58.1 | 196573, | | 9.912 | 0.21 | 47.2 | 58.6 | 196572 | | | | | |
| | 8.401 | 0.31 | 27.1 | 58.1 | 196571, | | 6.87 | 0.15 | 45.8 | | 196570 | | | | | |
| | 4.878 2.981 | 0.18 0.11 | 27.1 27.1 | 58.1 58.1 | 196571, 196571, | | 7.328 5.954 | 0.16 0.13 | 45.8 45.8 | | 196570, 196570, | | | | | |
| | 9.16 | 0.2 | 45.8 | 58.1 | 196570, | | 5.19 | 0.10 | 51.9 | | 196568 | | | | | |
| | 5.709 | 0.11 | 51.9 | 58.1 | 196568, | | 4.152 | 0.08 | 51.9 | | 196568 | | | | | |
| | 2.18 | 0.04 | 54.5 | 58.1 | 196567, | | 3.878 | 0.14 | 27.7 | | 196566 | | | | | |
| @58.1 I | 74.41 N | | look | 57.7 Hz b | / Pook | | 12.81 14.03 | 0.21 | 61 61 | | 196565, 196565, | | | | | |
| | 10.184 | 0.67 | 15.2 | 57.7 | 196576, | | 10.37 | 0.23 | 61 | | 196565 | | | | | |
| | 10.095 | 0.15 | 67.3 | 57.7 | 196573, | | 11.115 | 0.39 | 28.5 | | 196564 | | | | | |
| | 6.73 | 0.1 | 67.3 | 57.7 | 196573, | | 7.061 | 0.23 | 30.7 | | 196562 | | | | | |
| | 10.856 4.152 | 0.23 | 47.2 51.9 | 57.7 57.7 | 196572, 196568, | | 3.582 | 0.06 | 59.7 | | 196556 | | | | | |
| | 6.747 | 0.08 | 51.9 | 57.7 | 196568, | | 6.567 1.791 | 0.11 | 59.7 59.7 | | 196556, 196556, | | | | | |
| | 7.785 | 0.15 | 51.9 | 57.7 | 196568, | | 4.776 | 0.08 | 59.7 | | 196556 | | | | | |
| | 4.152 | 0.08 | 51.9 | 57.7 | 196568, | | 0.77 | 0.02 | 38.5 | | 196546 | | | | | |
| | 5.54 | 0.2 | 27.7 | 57.7 | 196566, | | 2.975 | 0.85 | 3.5 | | 196207 | | | | | |
| | 4.709 5.787 | 0.17 | 27.7 64.3 | 57.7 57.7 | 196566, 196563, | | 4.03 6.21 | 0.26 | 15.5 13.5 | | 195173, 195169, | | | | | |
| | 10.288 | 0.16 | 64.3 | 57.7 | 196563, | | 2.695 | 0.11 | 24.5 | | 195167 | | | | | |
| | 13.188 | 0.21 | 62.8 | 57.7 | 196561, | | 5.481 | 0.27 | 20.3 | 58.6 | 195157 | | | | | |
| · | 5.373 | 0.09 | 59.7 | 57.7 | 196556, | | 2.233 | 0.11 | 20.3 | | 195157 | | | | | |
| @57.7 l | 105.586 M | | | | | | 3.162 3.36 | 0.51 | 6.2 67.2 | | 195155, 195144, | | | | | |
| | | | | | | | 6.572 | 0.05 | 21.2 | | 195144 | | | | | |
| | | | | | | MW @58.6 Hz | | | | | | | | | | |
| | | | | | | | | | | lul a at | / === | | | | | |
| | | | | | | | 9.422 | 0.14 | 67.3 | | / 58.4 Hz 196573. | | | | | |
| | | | | | | | 10.076 | 0.14 | 45.8 | | 196570 | | | | | |
| | | | | | | | 6.412 | 0.14 | 45.8 | 58.4 | 196570, | | | | | |
| | | | | | | | 3.114 | 0.06 | 51.9 | | 196568 | | | | | |
| | | | | | | | 3.633 2.725 | 0.07 | 51.9 54.5 | | 196568, 196567, | | | | | |
| | | | | | | | 10.355 | 0.05 | 54.5 | | 196567 | | | | | |
| | | | | | | | 0.277 | 0.01 | 27.7 | 58.4 | 196566 | | | | | |
| | | | | | | | 10.26 | 0.36 | 28.5 | | 196564 | | | | | |
| | | | | | | | 7.125 4.605 | 0.25 0.15 | 28.5 30.7 | | 196564, 196562 | | | | | |
| | | | | | | | 13.816 | 0.15 | 62.8 | | 196561 | | | | | |
| | | | | | | | 4.179 | 0.07 | 59.7 | 58.4 | 196556 | | | | | |
| | | | | | | | 4.776 | 0.08 | 59.7 | | 196556 | | | | | |
| | | | | | | | 1.925 2.58 | 0.05 | 38.5 | | 196546, 196520, | | | | | |
| | | | | | | | 8.296 | 0.86 | 24.4 | | 196520, | | | | | |
| | | | | | | | 8.052 | 0.33 | 24.4 | | 196500 | | | | | |
| | | | | | | | 4.765 | 0.05 | 95.3 | | 195655 | | | | | |
| | | | | | | | 9.53 | 0.1 | 95.3 | | 195655 | | | | | |
| | | | | | | | 6.144 8.192 | 0.06 | 102.4 102.4 | | 195624 195624 | | | | | |
| | | | | | | | 5.12 | 0.05 | 102.4 | | 195624 | | | | | |
| | | | | | | | 6.293 | 0.31 | 20.3 | 58.4 | 195157 | | | | | |
| | | | | | | | 4.32 | 0.18 | 24 | | 195127 | | | | | |
| | | | | | | | 8.645 | 0.19 | 45.5 | | 195126 | | | | | |
| | | | | | | | 0.515 | 0.05 | 10.3 | 58.4 | 195120 | | | | | |

APPENDIX 2


PLOTS - LIL BIPOLE TRIP AT LIL TRANSFER LIMITS




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 500 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 500 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 400 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 400 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 300 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 300 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 250 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 250 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 150 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 150 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 2000 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 500 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 500 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 400 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 400 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 300 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 300 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 250 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 250 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 150 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 150 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1900 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 500 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 500 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 400 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 400 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 300 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 300 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 250 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 250 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 150 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 150 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1750 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 500 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 500 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 400 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 400 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 300 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 300 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 250 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 250 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 150 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 150 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1500 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 500 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 500 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 400 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 400 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 300 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 300 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 250 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 250 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 150 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 150 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1250 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 500 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 500 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 400 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 400 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 300 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 300 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 250 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 250 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 150 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 150 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 1000 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 500 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 500 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 400 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 400 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 300 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 300 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 250 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 250 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 150 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 150 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 750 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 700 MW - ML dem MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 600 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 600 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 450 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 450 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 500 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 500 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 400 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 400 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 300 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 300 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 250 MW - No LIL restarts enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 250 MW - One LIL restart enabled




Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 150 MW - No LIL restarts enabled



Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 150 MW - One LIL restart enabled



Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Active - No LIL restarts enabled



Loss of LIL Bipole at LIL Transfer Limit - IIS Demand 400 MW - ML 0 MW / ML Runbacks Inactive / ML F/C Inactive - No LIL restarts enabled

