

1 Q. **Reference: Application, Chapter 2, page 2.16**

2 Hydro states *"At the commencement of the spring period in 2026, Hydro was able to reduce*
3 *reliance on Holyrood TGS by reducing operations down to one unit, as planned."* Is this
4 consistent with the information provided in the April 2026 Monthly Energy Supply Report for
5 the IIS indicating that Holyrood TGS Unit 1 was in operation for the entire month of April, and
6 Holyrood TGS Unit 2 was in operation for the first 9 days of the month?

7

8

9 A. Yes; once Unit 2 was brought offline on April 9, 2026, Holyrood Thermal Generating Station
10 operations were reduced to one unit for the remainder of the spring period.