

1 Preamble:

2 We are unable to locate the June 2025 Labrador Operating Load Forecast referenced in
3 Footnote 4. It does not appear to be part of the 2026 GRA.

4 We are unable to confirm whether these load forecasts in Citation #1 and Citation #2 are
5 methodologically or structurally comparable.

6 The recent Supplemental Material to the GRA dated July 17, 2026, does not contain load
7 forecast actuals for the entirety of 2025.

8 a) Please update Schedule A-II to include actuals for the entirety of 2025.

9 b) Please confirm that the 2023 Planning Load Forecast (Citation 2) is the most recent
10 publicly available long term load forecast for the LIS prior to the 2026 GRA.

11 c) Please confirm that the 2023 Planning Load Forecast is a P50 forecast.

12 d) Please indicate if the reference forecast shown in Schedule A-II is a P50 or a P90
13 forecast.

14 e) Please provide in a format similar to Schedule A-II, the unsupplied P50 or P90 forecast
15 for the LIS (including actuals for the entirety of 2025) to facilitate comparison with the
16 2023 Load Forecast and the June 2025 Labrador Operating Load Forecast.

17 f) Please file the June 2025 Labrador Operating Load Forecast for review in this
18 proceeding.

19 g) Please explain any material differences in forecasting methodologies between the 2023
20 Load Forecast, the June 2025 Labrador Operating Load Forecast and the 2026 GRA load
21 forecast for the LIS.

22 h) Please clarify whether Hydro prepared any alternative (e.g., "low", "high", etc.)
23 forecasts to those provided in the 2026 GRA and provide these forecasts for the LIS and
24 the IIS or explain why no alternative forecasts were prepared.

25 i) Please explain and justify the apparent substantial differences in the forecasted
26 increased requirements of the IOC and the transmission losses (totaling more than 30

1 MW) between the 2023 Load Forecast and the 2026 GRA for the forecasted peak
2 demand requirements on the LIS for the years 2026 and 2027.
3
4

5 A. a) Please refer to Schedule A-II of Newfoundland and Labrador Hydro's ("Hydro") 2026 General
6 Rate Application ("GRA") Supplemental Material evidence, which includes the column 2025
7 Actual showing the full year 2025 Actuals.¹

8 b) It is confirmed.

9 c) It is confirmed.

10 d) The reference forecast shown in Schedule A-II is a P50 forecast.

11 e) Hydro plans to a P50 forecast for GRA purposes. Please refer to Hydro's response to
12 LAB-NLH-001, Attachment 1 for the 2025 Operating Load Forecast and Supplemental
13 Material, Schedule A-II for 2025 Actuals.

14 The Reference Case (P50) does not have unsupplied energy in the 2026 and 2027 Test Year
15 forecasts, which is the basis for the 2026 GRA.

16 f) Please refer to Hydro's response to part e).

17 g) There is no change in forecasting methodologies between the 2023 Load Forecast and the
18 June 2025 Labrador Operating Load Forecast used in the 2026 GRA.

19 h) For the 2026 GRA, Hydro relied on the 2025 Operating Load Forecast Reference Case. The
20 2023 Planning Load Forecast² referenced above was part of the *Reliability and Resource*
21 *Adequacy Study Review* proceeding ("*RRA Study Review*") currently before the Board of
22 Commissioners of Public Utilities. Alternate forecast scenarios for both the Labrador

¹ "2026 General Rate Application – Supplemental Material," Newfoundland and Labrador Hydro, July 17, 2026, att. 1, sch. A-II.

² "Long-Term Load Forecast Report – 2023," Newfoundland and Labrador Hydro, March 28, 2024 ("2023 Long-Term Load Forecast Report").

- 1 Interconnected System and Island Interconnected System are prepared as part of a *RRA*
2 *Study Review*, not as part of a GRA rate-setting test year.
- 3 i) The Power on Order for Iron Ore Company for 2026 and 2027 is assumed to be 262 MW;
4 this is consistent with the 2023 Load Forecast. Table A-5 of the 2023 Long-Term Load
5 Forecast Report does not include transmission losses, as noted in footnote 12.

Operating Interconnected Labrador Load Forecast
2025

	Jan-25		Feb-25		Mar-25		Apr-25		May-25		Jun-25		Jul-25		Aug-25		Sep-25		Oct-25		Nov-25		Dec-25		Annual Energy GWh	
	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh		
PROVINCIAL MARKET																										
HYDRO RURAL INTERCONNECTED																										
Goose Bay																										
Churchill Falls																										
Muskrat Falls Site																										
Wabush																										
Labrador City																										
Subtotal																										
DEPT. OF NATIONAL DEFENCE																										
IOC																										
Firm Power																										
Interruptible Demand																										
Imbalance Energy																										
Secondary																										
Subtotal																										
TAKOMA RESOURCES																										
Firm Power																										
Interruptible Demand																										
Imbalance Energy																										
Secondary																										
Subtotal																										
TOTAL HYDRO LABRADOR SALES																										

NOTES:

- Forecast utility energy and peak demands reflect historical average (H50) weather conditions.
- Hydro Rural - Churchill Falls requirements are for NLH General Service customers.
- Monthly Firm Power MW for IOC and Tacora reflects forecasted operational demand. The maximum monthly MW number is reflective of each customer's contract power on Order provision.

Operating Interconnected Labrador Load Forecast
2026

PROVINCIAL MARKET

HYDRO RURAL INTERCONNECTED

	Jan-26		Feb-26		Mar-26		Apr-26		May-26		Jun-26		Jul-26		Aug-26		Sep-26		Oct-26		Nov-26		Dec-26		Annual Energy GWh
	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	
Goose Bay	79.7	45.9	77.6	41.4	68.5	37.8	58.7	29.2	46.2	24.6	37.7	18.8	30.0	16.0	28.6	15.8	37.2	17.4	48.8	24.4	62.2	32.8	72.5	40.2	344.4
Churchill Falls	0.8	0.4	0.8	0.2	0.6	0.2	0.6	0.2	0.5	0.2	0.4	0.1	0.3	0.1	0.3	0.1	0.5	0.1	0.6	0.2	0.8	0.2	0.9	0.3	2.3
Muskrat Falls Site	1.0	0.99	1.0	0.8	1.0	0.7	1.0	0.5	1.0	0.5	1.0	0.2	0.7	0.2	0.7	0.2	1.0	0.2	1.0	0.5	1.0	0.7	1.0	1.0	6.5
Wabush	25.1	14.8	25.1	13.3	22.7	12.7	20.2	9.8	15.0	6.9	10.5	4.2	6.9	3.3	7.0	3.2	10.6	4.8	14.7	7.6	20.3	10.6	23.3	14.0	106.4
Labrador City	60.3	35.8	59.9	33.1	54.4	30.3	47.1	23.2	39.3	19.3	26.0	13.4	21.1	10.4	21.1	11.5	27.9	14.3	35.6	19.6	48.2	26.6	57.6	32.0	269.3
Subtotal	166.8	97.8	164.3	88.9	147.2	81.8	127.6	62.9	101.1	51.4	75.5	36.7	59.1	30.1	57.7	30.9	77.2	36.9	100.6	52.3	132.5	70.9	155.4	87.4	729.0

DEPT. OF NATIONAL DEFENCE

	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
--	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

IOC

Firm Power	262.0	156.0	262.0	142.1	262.0	153.0	262.0	139.5	240.0	138.2	200.0	93.8	200.0	111.9	200.0	119.2	230.0	106.2	246.0	133.3	250.0	140.6	262.0	141.5	1579.4
Interruptible Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Imbalance Energy	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Secondary	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Subtotal	262.0	156.0	262.0	142.1	262.0	153.0	262.0	139.5	240.0	138.2	200.0	93.8	200.0	111.9	200.0	119.2	230.0	106.2	246.0	133.3	250.0	140.6	262.0	141.5	1579.4

TAKORA RESOURCES

Firm Power	55.0	30.2	55.0	30.5	50.0	30.1	50.0	27.5	46.0	30.1	45.0	23.7	45.0	23.9	45.0	24.2	46.0	19.8	50.0	26.7	50.0	28.5	55.0	31.8	377.0
Interruptible Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Imbalance Energy	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Secondary	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Subtotal	55.0	30.2	55.0	30.5	50.0	30.1	50.0	27.5	46.0	30.1	45.0	23.7	45.0	23.9	45.0	24.2	46.0	19.8	50.0	26.7	50.0	28.5	55.0	31.8	377.0

TOTAL HYDRO LABRADOR SALES

	460.1	284.0	447.3	261.5	427.5	264.9	409.6	239.9	360.1	219.7	337.5	164.2	312.6	164.0	311.3	174.3	339.0	162.9	360.1	212.3	402.9	240.0	493.7	260.7	2,699.3
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	---------

NOTES:

- Forecast utility energy and peak demands reflect historical average (H50) weather conditions.
- Hydro Rural: Churchill Falls requirements are for NLH General Service customers.
- Monthly Firm Power MW for IOC and Takora reflects forecasted operational demand. The maximum monthly MW number is reflective of each customer's contract power on order provision.

Operating Interconnected Labrador Load Forecast
2027

PROVINCIAL MARKET

HYDRO RURAL INTERCONNECTED

	Jan-27		Feb-27		Mar-27		Apr-27		May-27		Jun-27		Jul-27		Aug-27		Sep-27		Oct-27		Nov-27		Dec-27		Annual Energy GWh
	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	
Goose Bay	81.1	46.7	79.0	42.2	69.7	38.5	58.7	29.7	45.9	25.1	38.3	19.2	30.5	16.3	24.0	16.1	37.8	17.8	49.6	24.8	63.3	33.4	73.8	40.9	356.6
Churchill Falls	0.8	0.4	0.8	0.2	0.6	0.2	0.6	0.2	0.5	0.2	0.4	0.1	0.3	0.1	0.3	0.1	0.5	0.1	0.6	0.2	0.8	0.2	0.9	0.3	2.3
Muskrat Falls Site	1.0	0.99	1.0	0.8	1.0	0.7	1.0	0.5	1.0	0.5	1.0	0.2	0.7	0.2	0.7	0.2	1.0	0.2	1.0	0.5	1.0	0.7	1.0	1.0	6.5
Wabush	25.4	14.9	25.4	13.4	23.0	12.8	20.5	9.9	15.2	6.9	10.6	4.2	7.0	3.3	7.0	3.3	10.8	4.8	14.9	7.7	20.6	10.6	23.6	14.1	106.9
Labrador City	60.6	35.9	60.1	33.2	54.7	30.4	47.3	23.3	39.5	19.4	26.1	13.5	21.2	10.5	21.2	11.5	28.0	14.3	35.7	19.7	48.5	26.7	57.9	32.1	220.4
Subtotal	168.9	98.9	166.3	89.8	149.0	82.7	129.1	63.6	102.2	51.9	76.4	37.1	53.7	30.4	58.3	31.2	78.0	37.3	102.8	52.8	134.1	71.7	157.2	88.3	738.8

DEPT. OF NATIONAL DEFENCE

	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
--	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

IOC

Firm Power	262.0	156.0	262.0	142.1	262.0	153.0	262.0	139.5	240.0	138.2	200.0	93.8	230.0	111.9	230.0	119.2	239.0	106.2	245.0	133.3	250.0	140.6	262.0	141.5	1579.4
Interruptible Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Imbalance Energy	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Secondary	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Subtotal	262.0	156.0	262.0	142.1	262.0	153.0	262.0	139.5	240.0	138.2	200.0	93.8	230.0	111.9	230.0	119.2	239.0	106.2	245.0	133.3	250.0	140.6	262.0	141.5	1579.4

TAKOMA RESOURCES

Firm Power	55.0	30.2	55.0	30.5	50.0	30.1	50.0	27.5	45.0	30.1	45.0	23.7	45.0	23.9	45.0	24.2	45.0	19.8	50.0	26.7	50.0	28.5	55.0	31.8	377.0
Interruptible Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Imbalance Energy	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Secondary	55.0	30.2	55.0	30.5	50.0	30.1	50.0	27.5	45.0	30.1	45.0	23.7	45.0	23.9	45.0	24.2	45.0	19.8	50.0	26.7	50.0	28.5	55.0	31.8	377.0
Subtotal	55.0	30.2	55.0	30.5	50.0	30.1	50.0	27.5	45.0	30.1	45.0	23.7	45.0	23.9	45.0	24.2	45.0	19.8	50.0	26.7	50.0	28.5	55.0	31.8	377.0

TOTAL HYDRO LABRADOR SALES

	462.0	285.1	449.6	262.4	429.1	262.7	411.0	239.6	360.1	230.2	338.3	154.6	333.1	166.3	311.8	178.7	329.8	163.3	379.2	212.8	404.3	240.8	441.4	261.6	2,429.2
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	---------

NOTES:

- Forecast utility energy and peak demands reflect historical average (HSA) weather conditions.
- Hydro Rural: Churchill Falls requirements are for NLH General Service customers.
- Monthly Firm Power MW for IOC and Tacoma reflects forecasted operational demand. The maximum monthly MW number is reflective of each customer's contract Power on Order provision.

Operating Interconnected Labrador Load Forecast
2028

PROVINCIAL MARKET

HYDRO RURAL INTERCONNECTED

	Jan-28		Feb-28		Mar-28		Apr-28		May-28		Jun-28		Jul-28		Aug-28		Sep-28		Oct-28		Nov-28		Dec-28		Annual Energy GWh
	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	
Goose Bay	82.8	47.0	80.6	42.4	71.1	38.8	66.9	29.9	46.8	25.2	39.0	19.3	31.0	16.4	29.5	16.2	38.4	17.9	50.5	25.0	64.5	33.6	75.3	41.2	338.0
Churchill Falls	0.8	0.4	0.8	0.2	0.6	0.2	0.6	0.2	0.5	0.2	0.4	0.1	0.3	0.1	0.3	0.1	0.5	0.1	0.6	0.2	0.8	0.2	0.9	0.3	2.3
Muskrat Falls Site	1.0	0.99	1.0	0.8	1.0	0.7	1.0	0.5	1.0	0.5	1.0	0.2	0.7	0.2	0.7	0.2	1.0	0.2	1.0	0.5	1.0	0.7	1.0	1.0	6.5
Wabush	25.5	15.0	25.5	13.5	21.1	12.9	20.6	9.9	15.3	6.9	10.7	4.3	7.1	3.4	7.1	3.3	10.8	4.8	14.9	7.7	20.7	10.7	23.8	14.2	106.5
Labrador City	60.9	36.1	60.4	33.4	55.0	30.5	47.5	23.4	39.7	19.5	26.2	13.5	21.3	10.5	21.3	11.6	28.1	14.4	35.9	19.8	48.7	26.8	58.2	32.3	271.8
Subtotal	171.0	99.5	168.3	90.4	150.7	83.1	138.5	64.0	103.3	52.2	77.2	37.3	60.4	30.6	58.9	31.4	78.9	37.5	103.0	53.1	135.7	72.1	159.1	88.8	740.1

DEPT. OF NATIONAL DEFENCE

	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
--	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

IOCC

Firm Power	262.0	156.0	262.0	142.1	262.0	153.0	262.0	139.5	240.0	138.2	200.0	93.8	230.0	111.9	230.0	113.2	230.0	106.2	246.0	133.3	250.0	140.6	262.0	141.5	1579.4
Interruptible Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Imbalance Energy	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Secondary	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Subtotal	262.0	156.0	262.0	142.1	262.0	153.0	262.0	139.5	240.0	138.2	200.0	93.8	230.0	111.9	230.0	113.2	230.0	106.2	246.0	133.3	250.0	140.6	262.0	141.5	1579.4

TAKOMA RESOURCES

Firm Power	55.0	30.2	55.0	30.5	50.0	30.1	50.0	27.5	46.0	30.1	45.0	23.7	45.0	23.9	45.0	24.2	46.0	19.8	50.0	26.7	50.0	28.5	55.0	31.8	377.0
Interruptible Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Imbalance Energy	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Secondary	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Subtotal	55.0	30.2	55.0	30.5	50.0	30.1	50.0	27.5	46.0	30.1	45.0	23.7	45.0	23.9	45.0	24.2	46.0	19.8	50.0	26.7	50.0	28.5	55.0	31.8	377.0

TOTAL HYDRO LABRADOR SALES

	463.8	285.7	461.5	262.9	400.7	266.2	412.4	231.0	362.2	230.5	330.0	164.8	313.7	166.5	312.4	178.9	339.5	160.5	371.3	213.1	405.8	241.2	443.1	262.1	3,468.4
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	---------

NOTES:

- Forecast utility energy and peak demands reflect historical average (H50) weather conditions.
- Hydro Rural: Churchill Falls requirements are for NLH General Service customers.
- Monthly Firm Power MW for IOCC and Tacoma reflects forecasted operational demand. The maximum monthly MW number is reflective of each customer's contract power on order provision.

Operating Interconnected Labrador Load Forecast
2029

PROVINCIAL MARKET

HYDRO RURAL INTERCONNECTED

	Jan-29		Feb-29		Mar-29		Apr-29		May-29		Jun-29		Jul-29		Aug-29		Sep-29		Oct-29		Nov-29		Dec-29		Annual Energy GWh
	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	MW	GWh	
Goose Bay	83.4	47.4	81.2	42.7	71.6	39.0	61.3	30.1	47.1	25.4	39.2	19.4	31.2	16.5	29.7	16.4	38.7	18.0	50.9	25.2	66.0	33.9	75.8	41.5	335.5
Churchill Falls	0.8	0.4	0.8	0.2	0.6	0.2	0.6	0.2	0.5	0.2	0.4	0.1	0.3	0.1	0.3	0.1	0.5	0.1	0.6	0.2	0.8	0.2	0.9	0.3	2.3
Muskrat Falls Site	1.0	0.99	1.0	0.8	1.0	0.7	1.0	0.5	1.0	0.5	1.0	0.2	0.7	0.2	0.7	0.2	1.0	0.2	1.0	0.5	1.0	0.7	1.0	1.0	6.5
Wabush	25.7	15.1	25.7	13.6	23.2	12.9	20.7	10.0	15.4	7.0	10.7	4.3	7.1	3.4	7.1	3.3	10.9	4.9	15.0	7.7	20.8	10.8	23.9	14.2	109.1
Labrador City	61.2	36.3	60.8	33.6	55.3	30.7	47.8	23.5	39.9	19.6	26.4	13.6	21.5	10.6	21.4	11.7	28.3	14.5	36.1	19.9	49.0	27.0	58.5	32.4	279.2
Subtotal	172.1	100.1	169.4	90.9	151.7	83.6	131.4	64.3	108.9	52.6	77.7	37.6	60.7	30.8	59.2	31.6	79.4	37.7	108.6	53.4	136.6	72.5	160.1	89.4	748.7

DEPT. OF NATIONAL DEFENCE

	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7.3	3.3	12.7	6.7	15.9	9.7	18.2	10.5	38.2
--	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	------	-----	------	-----	------	------	------

IOCC

Firm Power	262.0	156.0	262.0	142.1	262.0	153.0	262.0	139.5	240.0	138.2	200.0	93.8	200.0	111.9	200.0	119.2	239.0	106.2	246.0	133.3	250.0	140.6	262.0	141.5	1579.4
Interruptible Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Imbalance Energy	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Secondary	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Subtotal	262.0	156.0	262.0	142.1	262.0	153.0	262.0	139.5	240.0	138.2	200.0	93.8	200.0	111.9	200.0	119.2	239.0	106.2	246.0	133.3	250.0	140.6	262.0	141.5	1579.4

TAKORA RESOURCES

Firm Power	55.0	30.2	55.0	30.5	50.0	30.1	50.0	27.5	45.0	30.1	45.0	23.7	45.0	23.9	45.0	24.2	45.0	19.8	50.0	26.7	50.0	28.5	55.0	31.8	377.0
Interruptible Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Imbalance Energy	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Secondary	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Subtotal	55.0	30.2	55.0	30.5	50.0	30.1	50.0	27.5	45.0	30.1	45.0	23.7	45.0	23.9	45.0	24.2	45.0	19.8	50.0	26.7	50.0	28.5	55.0	31.8	377.0

TOTAL HYDRO LABRADOR SALES

	464.9	286.3	463.5	263.5	431.6	246.7	433.1	231.4	360.8	230.8	339.5	155.0	314.0	166.7	312.7	175.1	337.8	167.0	388.8	230.2	421.4	251.4	465.6	273.2	1477.2
--	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--------

NOTES:

- Forecast utility energy and peak demands reflect historical average (H50) weather conditions.
- Hydro Rural: Churchill Falls requirements are for NLH General Service customers.
- Monthly Firm Power MW for IOCC and Takora reflects forecasted operational demand. The maximum monthly MW number is reflective of each customer's contract power on order provision.