

Q. Reference: Volume I, Section 6.2.3, Section 6.11, and Volume 3, Exhibit 20, Issue Topic:
Newfoundland Power Generation Credit

For each year, 2020 to 2025, please provide in a table how many times Hydro has requested Newfoundland Power to run its generation, whether or not it was maximum generation. For each year, please break down between two periods (i) December to March and (ii) April to November.

A. Please note that Newfoundland and Labrador Hydro ("Hydro") does not request a specific amount of Newfoundland Power Inc. ("Newfoundland Power") generation, but instead, always requests that generation be maximized. The only specification in the request from Hydro to Newfoundland Power is whether to maximize "Avalon Hydro Generation" or "All Hydro Generation" (which includes Avalon Hydro Generation).

Table 1 is consistent with Table 1 presented in Hydro's response to NP-NLH-103 of this proceeding, with the addition of thermal generation requests for the periods in question.

Table 1: Number of Requests to Maximize Hydraulic and Thermal Generation 2020–2025

Period				Number of Requests to Maximize Hydraulic Generation	Number of Requests for Thermal Generation	Total Requests
From		To				
January	2020 ¹	March	2020	34	0	34
April	2020	November	2020	40	0	40
December	2020	March	2021	39	0	39
April	2021	November	2021	76	0	76
December	2021	March	2022	42	2	44
April	2022	November	2022	39	0	39
December	2022	March	2023	58	2	60
April	2023	November	2023	38	0	38
December	2023	March	2024	33	0	33
April	2024	November	2024	50	0	50
December	2024	March	2025	24	3	27
April	2025	November	2025	15	1	16
December	2025	N/A		1	0	1

¹ December 2019 is not included in this table as it is outside of the scope of the request.