

1 Q. **Reference: Volume I, Schedule A-1; Volume II, Exhibit 4**

2 Explain the basis for forecasting Island Industrial Customer energy at 613.4 GWh for both 2026
3 and 2027 considering the forecast Island Industrial Customer demand increases from 84.7 MW
4 in 2026 to 91.3 MW in 2027.

5

6

7 A. In 2026, one Industrial customer was forecasted to be ramping up during the winter peak. In
8 2027, their full Power on Order was incorporated into the winter peak.