

1 Q. **Reference: Volume II, Exhibit 4, Section 2.1.1**

2 a) Provide the energy and peak demand impacts of the installation of the electric boilers at
3 Memorial University on the Newfoundland Power load forecast.

4 b) Is this additional load curtailable during peak times and is it reflected in the 2027TY
5 Curtailable Load of Newfoundland Power? Explain.

6

7

8 A. a) The forecast energy associated with the electric boilers at Memorial University of
9 Newfoundland is 105 GWh. The forecast peak demand impacts are 21.7 MW.

10 b) Please refer to Newfoundland and Labrador Hydro's response to part b) of IIC-NLH-010 of
11 this proceeding.