

- 1 **Q. Reference: “2020 Capital Budget Application,” Newfoundland Power, July 5, 2019,**
 2 **Report 4.1 “Distribution Reliability Initiative,” sec. 3.1, at p. 2, Table 1**
 3

Table 1
Distribution Interruption Statistics
5-Year Average to December 31, 2018

| Feeder | Customers | SAIFI | SAIDI | CHIKM | CIKM |
|------------------------|------------------|--------------|--------------|--------------|-------------|
| DUN-01 | 1,049 | 4.90 | 9.54 | 62 | 32 |
| GBY-03 | 762 | 3.35 | 6.94 | 49 | 24 |
| GDL-04 | 1,472 | 1.27 | 2.23 | 222 | 127 |
| Company Average | - | 1.37 | 1.82 | 55 | 45 |

- 4 **Using the five-year average presented in Table 1 and the data composition used to**
 5 **produce this data, how many and what percentage of Newfoundland Power feeders**
 6 **perform worse than CEA Region 2 for SAIFI?**
 7

- 8 A. As indicated in response to Request for Information NLH-NP-030, the components
 9 included in annual CEA data are not consistent with the composition of the data included
 10 in Table 1 referenced above. Newfoundland Power is therefore unable to provide the
 11 requested comparison to CEA Region 2 for SAIFI.