

- 1 **Reference: "2023 Capital Budget Application," Newfoundland Power Inc., June 29,**
2 **2022, Schedule B, pp. 105–107 (Transmission Line 55L Rebuild).**
3
- 4 **Q. Please provide a list of outages, including duration, on an annualized basis,**
5 **related to component failure on Transmission Line 55L for the period 2017–**
6 **2021. If available, please provide relevant reliability statistics.**
7
- 8 A. Customers served by Transmission line 55L experienced one outage caused by
9 component failure from 2017 to 2021. The outage occurred during a severe wind
10 storm, was approximately 4.5 hours in duration, and resulted in 891,000 customer
11 minutes of outage.